

# **ENERGY SAVINGS IMPROVEMENT PROGRAM**

## **GLOUCESTER TOWNSHIP**



## **ENERGY SAVINGS PLAN**

FINAL

Prepared by:



520 South Burnt Mill Road  
Voorhees, New Jersey 08043

February 20, 2012

## TABLE OF CONTENTS

I. Executive Summary.....	4
II. Introduction .....	7
III. Energy Audit Results.....	8
IV. Historic Energy Consumption and Costs.....	10
V. Energy Conservation Measures (ECM).....	11
VI. Direct Install Program .....	64
VII. Design and Compliance, Maintenance Impacts, and Risks.....	65
VIII. PJM Demand Response & Curtailable Service Programs .....	66
IX. ESIP Cash Flow Summary .....	67
X. Greenhouse Gas Reductions.....	69
XI. Measurement & Verification.....	71

### Appendix:

- **Appendix A** – Project Summary Table
- **Appendix B** – Historic Energy Consumption & Cost
- **Appendix C** - Investment Grade Lighting Audit
  - Lighting Upgrade
  - Lighting Controls
  - Occupancy Sensor Study Results
- **Appendix D** - Direct Install Scope of Work

### **REPORT DISCLAIMER**

The information contained within this report, including any attachment(s), is intended solely for use by the named addressee(s). If you are not the intended recipient, or a person designated as responsible for delivering such messages to the intended recipient, you are not authorized to disclose, copy, distribute or retain this report, in whole or in part, without written authorization from Concord Engineering Group, Inc., 520 S. Burnt Mill Road, Voorhees, NJ 08043.

This report may contain proprietary, confidential or privileged information. If you have received this report in error, please notify the sender immediately. Thank you for your anticipated cooperation.

## I. Executive Summary

This report presents the outline for an Energy Savings Plan for Gloucester Township. This plan will be used as a basis for the Township to initiate an Energy Savings Improvement Program that will encompass multiple energy conservation projects to be implemented at their facilities with the intent to reduce energy usage and costs at those facilities. Based on initial Energy Audit and further analysis performed for the plan the following energy conservation measures will constitute the improvement program for the Township.

ENERGY CONSERVATION MEASURES		
ECM NO.	DESCRIPTION	BUILDINGS
ECM #1	Lighting Upgrade	Library, Recreation, Senior, Academy Hall, Municipal, Public Works, Monroe Pool
ECM #1A	DI - Lighting Upgrade	Recreation, Academy Hall
ECM #2	Lighting Controls	Library, Recreation, Academy Hall, Municipal, Public Works
ECM #3	5-Ton RTU Replacement	Library
ECM #5	x3 1.5 Ton Split Units	Academy Hall
ECM #5A	DI - x1 3ton & x1 2 Ton Unit	Academy Hall
ECM #7	x16 AC Unit Replacement	Municipal
ECM #8	DI - Split Unit Replacements	Senior
ECM #9	x2 1000 MBH Boilers	Municipal
ECM #10	DI - Boiler Replacement	Library
ECM #11	DI - Furnace Replacement	Senior
ECM #12	DI - Boiler Replacement	Academy Hall
ECM #13	DI - Fuel Economizer	Library
ECM #14	DI - Fuel Economizer	Academy Hall
ECM #15	CRT Monitor Replacement	Library, Public Works, Municipal
ECM #16	Pool Pump Time Controls	Monroe Pool
ECM #18	DI - Faucet Aerators	Senior
ECM #19	DI - Programmable Thermostats	Senior
ECM #20	DI - High Efficiency Split System	Recreation
ECM #21	DI - Furnace Replacement	Recreation

The proposed ECM's yield the following results over a fifteen year project life.

Net Project Cost	Utility Savings	Net Present Value	Participant Net Benefit	Benefit-Cost Ratio
\$506,164	\$55,620	\$139,871.44	\$167,872.92	1.36

Table 1 & 2 ECM Summary below shows the associated utility cost savings and energy savings for each measure. Further analysis of cash flow projections are provided in section VII of this report for the fifteen (15) year term of the ESIP.

**Table 1: Energy Cost Savings Summary**

<b>TABLE 1: UTILITY COST SAVINGS</b>					
<b>ECM NO.</b>	<b>BUILDING</b>	<b>DESCRIPTION</b>	<b>ANNUAL UTILITY COST SAVINGS</b>		
			<b>ELECTRIC SAVINGS</b>	<b>NATURAL GAS SAVINGS</b>	<b>TOTAL SAVINGS</b>
<b>ECM #1</b>	All Buildings	Lighting Upgrade	\$26,419	\$0	\$26,419
<b>ECM #1A</b>	Recreation, Academy Hall	DI - Lighting Upgrade	\$2,126	\$0	\$2,126
<b>ECM #2</b>	All Buildings	Lighting Controls	\$5,635	\$0	\$5,635
<b>ECM #3</b>	Library	5-Ton RTU Replacement	\$750	\$0	\$750
<b>ECM #4</b>	Recreation	REMOVED	\$0	\$0	\$0
<b>ECM #5</b>	Academy Hall	x3 1.5 Ton Split Units	\$417	\$0	\$417
<b>ECM #5A</b>	Academy Hall	DI - x1 3ton & x1 2 Ton Unit	\$403	\$0	\$403
<b>ECM #6</b>	Public Works	REMOVED	\$0	\$0	\$0
<b>ECM #7</b>	Municipal	x16 AC Unit Replacement	\$9,159	\$0	\$9,159
<b>ECM #8</b>	Senior	DI - Split Unit Replacements	\$1,916	\$0	\$1,916
<b>ECM #9</b>	Municipal	x2 1000 MBH Boilers	\$0	\$3,194	\$3,194
<b>ECM #10</b>	Library	DI - Boiler Replacement	\$0	\$842	\$842
<b>ECM #11</b>	Senior	DI - Furnace Replacement	\$0	\$727	\$727
<b>ECM #12</b>	Academy Hall	DI - Boiler Replacement	\$0	\$1,196	\$1,196
<b>ECM #13</b>	Library	DI - Fuel Economizer	\$0	\$263	\$263
<b>ECM #14</b>	Academy Hall	DI - Fuel Economizer	\$0	\$260	\$260
<b>ECM #15</b>	Library, Public Work, Municipal	CRT Monitor Replacement	\$313	\$0	\$313
<b>ECM #16</b>	Monroe Pool	Pool Pump Time Controls	\$1,380	\$0	\$1,380
<b>ECM #17</b>	Monroe Pool	REMOVED	\$0	\$0	\$0
<b>ECM #18</b>	Senior	DI - Faucet Aerators	\$0	\$145	\$145
<b>ECM #19</b>	Senior	DI - Programmable Thermostats	\$0	\$0	\$0
<b>TOTAL</b>			<b>\$48,518</b>	<b>\$6,628</b>	<b>\$55,146</b>

**Table 2: Energy Usage Savings Summary**

<b>TABLE 2: ENERGY CONSUMPTION SAVINGS</b>					
<b>ECM NO.</b>	<b>BUILDING</b>	<b>DESCRIPTION</b>	<b>ANNUAL UTILITY REDUCTION</b>		
			<b>ELECTRIC DEMAND (KW)</b>	<b>ELECTRIC CONS. (KWH)</b>	<b>NATURAL GAS (THERMS)</b>
<b>ECM #1</b>	All Buildings	Lighting Upgrade	50.0	149,976	0
<b>ECM #1A</b>	Recreation, Academy Hall	DI - Lighting Upgrade	6.1	11,811	0
<b>ECM #2</b>	All Buildings	Lighting Controls	11.7	32,693	0
<b>ECM #3</b>	Library	5-Ton RTU Replacement	2.1	4,143	0
<b>ECM #4</b>	Recreation	REMOVED	0.0	0	0
<b>ECM #5</b>	Academy Hall	x3 1.5 Ton Split Units	1.4	2,345	0
<b>ECM #5A</b>	Academy Hall	DI - x1 3ton & x1 2 Ton Unit	1.3	2,262	0
<b>ECM #6</b>	Public Works	REMOVED	0.0	0	0
<b>ECM #7</b>	Municipal	x16 AC Unit Replacement	18.6	55,510	0
<b>ECM #8</b>	Senior	DI - Split Unit Replacements	4.8	8,085	0
<b>ECM #9</b>	Municipal	x2 1000 MBH Boilers	0.0	0	1,879
<b>ECM #10</b>	Library	DI - Boiler Replacement	0.0	0	653
<b>ECM #11</b>	Senior	DI - Furnance Replacement	0.0	0	564
<b>ECM #12</b>	Academy Hall	DI - Boiler Replacement	0.0	0	927
<b>ECM #13</b>	Library	DI - Fuel Economizer	0.0	0	204
<b>ECM #14</b>	Academy Hall	DI - Fuel Economizer	0.0	0	202
<b>ECM #15</b>	brary, Public Work, Municip	CRT Monitor Replacement	0.0	1,786	0
<b>ECM #16</b>	Monroe Pool	Pool Pump Time Controls	0.0	6,733	0
<b>ECM #17</b>	Monroe Pool	REMOVED	0.0	0	0
<b>ECM #18</b>	Senior	DI - Faucet Aerators	0.0	0	112
<b>ECM #19</b>	Senior	DI - Programmable Thermostats	0.0	0	0
<b>ECM #20</b>	Recreation	DI - High Efficiency Split System	1.3	2,262	0
<b>ECM #21</b>	Recreation	DI - Furnace Replacement	0.0	0	38
<b>TOTAL</b>			<b>97.4</b>	<b>277,606</b>	<b>4,579</b>

## **II. Introduction**

The New Jersey State Legislature approved Assembly Bill Number 844 that allows certain local public entities to enter into contracts for up to 15 years for energy conservation or provisions of renewable energy production at buildings owned by such entities. Furthermore, this allows government agencies to make these energy related improvements to their facilities and pay for the costs using the energy savings value that result. The enacted Chapter 4 of the Laws of 2009, the “Energy Savings Improvement Program” (ESIP), provides all government agencies in New Jersey with a flexible tool to improve and reduce energy usage with minimal expenditure of new financial resources. Guidelines for implementation of this program have been provided through the Department of Community Affairs Local Finance Notice 2009-11, and subsequent protocols provided by the Board of Public Utilities Docket No. EO09020128 dated 2/24/2009 for computing energy costs savings.

The first step, (after having completed an Energy Audit) to implementing an Energy Savings Improvement Program is creation of the Energy Savings Plan (ESP). The plan is created to further develop what is outlined in the energy audit report to a more detailed scope of work with more refined cost estimates and energy savings to provide the owner with a cash flow analysis over the life of the contract. The ESP identifies and describes each energy conservation measure that will comprise the ESIP, an estimate of greenhouse gas reductions from the resultant savings, identification of all design and compliance issues, maintenance requirements necessary to ensure continued savings, identification of eligibility for PJM demand response and curtailable service programs, and an assessment of any risks associated with implementation of the plan. The plan is used as a reference document to provide information to the local entity for the purposes of soliciting proposals from qualified Energy Services Companies (ESCO) to implement the project or they can choose to self implement and use the plan to secure funding and move into construction services.

### **III. Energy Audit Results**

The Township of Gloucester had an energy audit performed by Concord Engineering at its Municipal Building, Senior Center, Academy Hall, Public Works Building, Library, Recreation Center, and Monroe Avenue Pool facilities in 2010.

The report was consistent with the Board of Public Utilities Local Government Energy Audit Program guidelines. The audit provided a basic list of energy conservation measures for each facility that ranged from small low/no cost measures to more capital intensive measures. Each of the measures was evaluated and assigned an estimated construction cost and a projected energy savings using industry standard practices and engineering judgment.

The report provided a list of recommendations for each Township building and was considered the base scope of energy conservation measures used to develop this Energy Savings Plan. In addition, information regarding building occupancy, operating hours, and utility data was utilized to for creating the baseline building profile.

The Local Government Energy Audit Reports were used in developing the Energy Savings Plan, but were not included as a direct attachment to this report, however a copy can be obtained from the Township of Gloucester.



**Table 3: Summary of Energy Audit Report Recommendations:**

<b>ENERGY AUDIT ECM LIST</b>	
<b>ECM NO.</b>	<b>DESCRIPTION</b>
	<b>Library</b>
ECM #1	Lighting Upgrade
ECM #2	Lighting Controls
ECM #3	Computer Monitors
ECM #4	Condensing Boiler
ECM #5	AC Unit Replacements
ECM #6	Programmable Thermostats
	<b>Recreation Center</b>
ECM #1	Lighting Upgrade
ECM #2	Lighting Controls
ECM #3	Split System AC Upgrades
ECM #4	Energy Recovery Unit Retrofit
	<b>Senior Community Center</b>
ECM #1	Lighting Upgrade
ECM #2	Lighting Controls
ECM #3	Split AC Unit Upgrades
ECM #4	Programmable Thermostat
ECM #5	Condensing Furnace Upgrade
	<b>Academy Hall</b>
ECM #1	Lighting Upgrade
ECM #2	Lighting Controls
ECM #3	Computer Monitors
ECM #4	Condensing Boiler
ECM #5	AC Unit Upgrades
	<b>Public Works Building</b>
ECM #1	Lighting Upgrade
ECM #2	Lighting Controls
ECM #3	Computer Monitors
ECM #4	AC Unit Upgrades
	<b>Municipal Building</b>
ECM #1	Lighting Upgrade
ECM #2	Lighting Controls
ECM #3	Computer Monitors
ECM #4	AC Unit Replacements
ECM #5	Boiler Replacement
	<b>Monroe Pool</b>
ECM #1	Lighting Upgrade
ECM #2	Lighting Controls
ECM #3	Pool Pump Controls
ECM #4	Hot Water Heater Replacement

## IV. Historic Energy Consumption and Costs

The Township facilities are currently delivered electricity from Atlantic City Electric (ACE) and Public Service Electric and Gas (PSEG) under various rate tariffs. Natural Gas is provided by South Jersey Gas (SJG) to all Township facilities. The utility data provided by the Township represents the calendar year from May 2010 to May 2011. Each facility's utility data was tabulated and plotted in graph form and is provided in the **Historic Energy Consumption and Cost Appendix**. The tables below summarize the annual usage and average cost per unit for each facility.

**Table 3: Electric Utility Summary**

<b>ELECTRIC UTILITY SUMMARY</b>			
<b>FACILITY</b>	<b>UTILITY PROVIDER</b>	<b>ELECTRIC USAGE (KWH)</b>	<b>ELECTRIC COST (\$/KWH)</b>
Library	PSEG	132,240	\$0.1810
Recreation Center	ACE	301,000	\$0.1810
Senior Community Center	PSEG	25,980	\$0.2370
Academy Hall	PSEG	53,510	\$0.1780
Municipal Building	PSEG	611,798	\$0.1650
Public Works Building	ACE	243,360	\$0.1800
Monroe Pool	PSEG	26,340	\$0.2050

**Table 4: Natural Gas Utility Summary**

<b>NATURAL GAS UTILITY SUMMARY</b>			
<b>FACILITY</b>	<b>UTILITY PROVIDER</b>	<b>NATURAL GAS USAGE (THERM)</b>	<b>NATURAL GAS COST (\$/THERM)</b>
Library	SJG	3,017	\$1.2900
Recreation Center	SJG	7,163	\$1.7300
Senior Community Center	SJG	3,212	\$1.2900
Academy Hall	SJG	2,872	\$1.2900
Municipal Building	SJG	9,649	\$1.7000
Public Works Building	SJG	6,897	\$1.7300
Monroe Pool	SJG	37	\$8.5300

## V. Energy Conservation Measures (ECM)

### ECM #1: All Buildings – Lighting Upgrade

#### Description:

Lighting throughout the buildings at Gloucester Township is comprised of a variety of fixture types. Some facilities have a majority of T-12 lamps with magnetic ballasts, such as the Recreation Center & Academy Hall. While in other buildings such as Public Works and Library, the lighting is made up of a mixture of older T-12 fixtures and T-8 fixtures. Finally the Municipal, Police, Senior Center and Monroe Pool is primarily lit with newer T-8 fixtures or compact fluorescent fixtures with electronic ballasts.

This ECM includes replacement of the existing fixtures containing T12 lamps and magnetic ballasts with fixtures containing T8 lamps and electronic ballasts. The new energy efficient, T8 fixtures will provide adequate lighting and will save the owner on electrical costs due to the better performance of the lamp and ballasts. This ECM also includes the replacement of all incandescent lamps to compact fluorescent lamps. The energy usage of an incandescent compared to a compact fluorescent approximately 3 to 4 times greater. In addition to the energy savings, compact fluorescent fixtures burn-hours are 8 to 15 times longer than incandescent fixtures ranging from 6,000 to 15,000 burn-hours compared to incandescent fixtures ranging from 750 to 1000 burn-hours.

The existing and proposed lighting retrofits are shown per space in the **Investment Grade Lighting Audit Appendix** of this analysis.

#### Description of Scope:

It is recommended the Township staff consider installing the lighting recommendations at Monroe Pool, Academy Hall, Senior Center, and potentially the Library due to the minimal amount of work to be performed.

#### Preliminary Scope

- Engineering specifications / documentation of proposed lighting system & controls
- Thorough site survey by HVAC / Electrical Contractor to review existing conditions
- Bid proposals requested from contractors
- Fixtures & Lighting Controls submittals

#### Construction Scope

Construction scope includes:

- Remove existing fixtures where replacement fixtures are proposed.

- Install new fixture and electrical connections as required
- Install new fixture retrofit kit where applicable
- Remove existing wall switch for wall mount occupancy sensor locations.
- Install new dual technology occupancy sensor in wall switch electrical box.
- Install ceiling mounted occupancy sensors where indicated on the lighting appendix or where wall mounted occupancy sensor coverage is not adequate.
- Install additional occupancy sensors for additional coverage as needed per the manufacturer's installation instructions.
- Test operation of all new light fixtures.

### **Energy Savings Calculations / Results:**

The energy savings have been tabulated based on occupancy profiles recorded through data loggers. The information includes total burn hours for each space measured as well as total occupied burn hours for each space measured. The total measured burn hours were used to calculate the existing lighting energy. The total measured occupied burn hours were used to calculate the proposed lighting energy. The proposed lighting energy was calculated based on the installation of all proposed fixture retrofits, as well as installation of occupancy sensors for all proposed areas. All areas proposed for a retrofit or sensor installation are shown in the **Investment Grade Lighting Audit Appendix.**

Energy savings calculations are based on the difference between the existing and proposed facility energy use. The following summary is broken down by building:

<b>LIGHTING CALCULATIONS</b>				
<b>ECM INPUTS</b>		<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Building</b>	<b>Parameter</b>	Existing Lighting System	Lighting Upgrade	
Library	Electric Consumption (kWh)	48,747	39,641	9,106
	Electric Cost (\$)	\$8,823	\$7,175	\$1,648
Recreation	Electric Consumption (kWh)	118,006	60,182	57,824
	Electric Cost (\$)	\$21,359	\$10,893	\$10,466
Senior	Electric Consumption (kWh)	11,013	10,680	333
	Electric Cost (\$)	\$2,610	\$2,531	\$79
Academy Hall	Electric Consumption (kWh)	10,660	10,486	174
	Electric Cost (\$)	\$1,897	\$1,867	\$31
Municipal	Electric Consumption (kWh)	208,431	162,107	46,324
	Electric Cost (\$)	\$34,391	\$26,748	\$7,643
Public Works	Electric Consumption (kWh)	155,744	120,847	34,897
	Electric Cost (\$)	\$28,034	\$21,752	\$6,281
Monroe Pool	Electric Consumption (kWh)	5,144	3,827	1,317
	Electric Cost (\$)	\$1,055	\$785	\$270
<b>ENERGY SAVINGS CALCULATIONS</b>				
<b>ECM RESULTS</b>		<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Total Energy (kWh)</b>		557,745	407,770	149,975
<b>Energy Cost (\$)</b>		\$98,169	\$71,750	\$26,419
<b>COMMENTS:</b>	Hours of operation are based on logged hours.			

## **ECM #1A: Direct Install – Lighting Upgrade**

### **Description:**

The Direct Install (DI) program shall include lighting scope for the Recreation Center and Academy Hall. The Lighting Audit Appendix shows the scope of work to be covered by the Direct Install Contractor as well as all remaining scope, at these facilities that will be coordinated and installed in the project bid package as part of ECM #1. In general the DI scope of work covers replacement of all linear fluorescent type fixtures, 13 watt CFL lamp replacements, and some occupancy sensor lighting controls in general areas.

Any Lighting upgrade work excluded under Direct Install for the Recreation Center and Academy Hall has been included in ECM #1.

The existing and proposed lighting retrofits are shown per space in the **Investment Grade Lighting Audit Appendix** of this analysis.

### **Description of Scope:**

Retrofit, Remove, and/or Replace of existing units lighting fixtures to be performed by Direct Install Contractor.

Equipment efficiency levels are stipulated by the NJ Clean Energy Program Direct Install guidelines for this ECM implementation.

### **Energy Savings Calculations / Results:**

The energy savings have been tabulated based on occupancy profiles recorded through data loggers. The information includes total burn hours for each space measured as well as total occupied burn hours for each space measured. The total measured burn hours were used to calculate the existing lighting energy. The total measured occupied burn hours were used to calculate the proposed lighting energy. The proposed lighting energy was calculated based on the installation of all proposed fixture retrofits, as well as installation of occupancy sensors for all proposed areas. All areas proposed for a retrofit or sensor installation are shown in the **Investment Grade Lighting Audit Appendix**.

Energy savings calculations are based on the difference between the existing and proposed facility energy use. The following summary is broken down by building:

<b>DIRECT INSTALL LIGHTING CALCULATIONS</b>				
<b>ECM INPUTS</b>		<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Building</b>	<b>Parameter</b>	Existing Lighting System	Lighting Upgrade	
Recreation	Electric Consumption (kWh)	118,006	110,153	7,853
	Electric Cost (\$)	\$21,359	\$19,938	\$1,421
Academy Hall	Electric Consumption (kWh)	10,660	6,702	3,958
	Electric Cost (\$)	\$1,897	\$1,193	\$705
<b>ENERGY SAVINGS CALCULATIONS</b>				
<b>ECM RESULTS</b>		<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Total Energy (kWh)</b>		128,666	116,855	11,811
<b>Energy Cost (\$)</b>		\$23,257	\$21,131	\$2,126
<b>COMMENTS:</b>	Hours of operation are based on logged hours.			

## **ECM #2: Lighting Controls**

### **Description:**

The lighting controls required within these facilities are minimal. The lighting is primarily controlled by manual wall switches. This ECM includes the installation of occupancy sensors for all applicable spaces in the Library, Recreation Center, Academy Hall, Municipal and Public works Building. The lighting is primarily controlled by manual wall switches. This ECM includes the installation of occupancy sensors for all applicable spaces.

This ECM includes replacement of existing wall mounted switches with dual technology wall and remote mounted occupancy sensors. The existing and proposed lighting retrofits and lighting controls are shown per space in the **Investment Grade Lighting Audit Appendix** of this analysis.

### **Description of Scope:**

#### Preliminary Scope

- Engineering specifications / documentation of proposed lighting system & controls
- Thorough site survey by HVAC / Electrical Contractor to review existing conditions
- Bid proposals requested from contractors
- Fixtures & Lighting Controls submittals

#### Construction Scope

Construction scope includes:

- Remove existing wall switch for wall mount occupancy sensor locations.
- Install new dual technology occupancy sensor in wall switch electrical box.
- Install ceiling mounted occupancy sensors where indicated on the lighting appendix or where wall mounted occupancy sensor coverage is not adequate.
- Install additional occupancy sensors for additional coverage as needed per the manufacturer's installation instructions.
- Test operation of all new occupancy controls.

### **Energy Savings Calculations / Results:**

The energy savings have been tabulated based on occupancy profiles recorded through data loggers. The information includes total burn hours for each space measured as well as total occupied burn hours for each space measured. The total measured burn hours were used to calculate the existing lighting energy. The total measured occupied burn hours were used to calculate the proposed lighting energy. The proposed lighting energy was calculated based on the installation of all proposed fixture retrofits, as well as installation of occupancy sensors for all



proposed areas. All areas proposed for a retrofit or sensor installation are shown in the **Investment Grade Lighting Audit Appendix.**

Energy savings calculations are based on the difference between the existing and proposed facility energy use. The following summary is broken down by building:

<b>LIGHTING CALCULATIONS</b>				
<b>ECM INPUTS</b>		<b>PROPOSED</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Building</b>	<b>Parameter</b>	Lighting Upgrade	Lighting Controls	
Library	Electric Consumption (kWh)	39,641	38,650	991
	Electric Cost (\$)	\$7,175	\$6,996	\$179
Recreation	Electric Consumption (kWh)	52,329	46,103	6,226
	Electric Cost (\$)	\$9,472	\$8,345	\$1,127
Academy Hall	Electric Consumption (kWh)	6,528	5,760	768
	Electric Cost (\$)	\$1,162	\$1,025	\$137
Municipal	Electric Consumption (kWh)	162,107	145,042	17,065
	Electric Cost (\$)	\$26,748	\$23,932	\$2,816
Public Works	Electric Consumption (kWh)	120,847	113,204	7,643
	Electric Cost (\$)	\$21,752	\$20,377	\$1,376
<b>ENERGY SAVINGS CALCULATIONS</b>				
<b>ECM RESULTS</b>		<b>PROPOSED</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Total Energy (kWh)</b>		381,452	348,759	32,694
<b>Energy Cost (\$)</b>		\$66,309	\$60,674	\$5,635
<b>COMMENTS:</b>	Lighting Controls Savings based on lighting upgrade reduction			

### ECM #3: Library - High-Efficiency Rooftop Unit

**Description:**

The Library meeting room is conditioned by a single Carrier 4-ton cooling only rooftop unit with no economizer controls. The unit is rated at 1700 CFM of supply air, and ARI SEER rating of 8.0.

This ECM includes replacing the Carrier rooftop with York 15 SEER 4-ton cooling only unit with economizer controls. The system will include new outside air dampers and controls to ensure outside air is only provided during occupied periods. This ECM also includes programmable thermostats to provide night setback of 7-8°F during unoccupied periods and will be required to tie into the new energy management system being installed by the Township.

EQUIPMENT INFORMATION	
ECM INPUT	EXISTING
Unit Tag	AC-2
Unit Location	Roof
Service For	Meeting Room
Unit Type	Packaged AC
Number of Units	1
Cooling Capacity, Btu/hr	48,000
Total Capacity, Tons	4
Manufacturer	Carrier
Model Number	48LD005
Efficiency (S/EER)	8 SEER

**Description of Scope:**

Preliminary Scope

- Engineering design documentation
- Thorough site survey by HVAC / Electrical Contractor to review existing conditions.
- Bid proposals requested from contractors
- Equipment submittals

Construction Scope

- Remove existing packaged AC unit.
- Remove associated electric wiring to AC unit, except where reused.
- Modifications to existing supply and return duct connections as required.
- Install proposed air conditioning unit as per the equipment list below including:
  - Roof curb adaptor as required.
  - Ductwork connection to new equipment and insulation.

- One 7-day Programmable Thermostats. As required with new control system.
- Controls integration capability with new energy management system being installed by the Township.
- Packaged Economizer controls for the rooftop units
- Provide equipment start-up and training.

This ECM includes replacement of one rooftop unit with a high efficiency unit of like size. The equipment list below is the basis of design and represents the efficiency and capacity minimum requirements for this ECM implementation:

<b>IMPLEMENTATION SUMMARY</b>	
<b>ECM INPUT</b>	<b>PROPOSED</b>
Unit Tag	AC-2
Unit Location	Roof
Service For	Meeting Room
Unit Type	Packaged AC
Number of Units	1
Cooling Capacity, Btu/hr	48,000
Total Capacity, Tons	4
Manufacturer	York
Model Number	DEX048A25
Efficiency (S/EER)	15 SEER

**Energy Savings Calculations / Results:**

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the existing efficiency rating and stipulated values in the protocols for operating hours and comparing them to the proposed units' efficiency ratings.

*Air Conditioning Upgrade Calculations:*

$$Demand\ Savings = \left( \frac{Btu/h}{1000} \right) \times \left( \frac{1}{EER_E} - \frac{1}{EER_P} \right) \times CF$$

$$Electric\ Savings = \left( \frac{Btu/h}{1000} \right) \times \left( \frac{1}{EER_E} - \frac{1}{EER_P} \right) \times Full\ Load\ Hours$$

EER = Energy Efficiency Ratio, Existing (E) and Proposed (P)

CF = Coincidence Factor = 0.67

Full Load Hours = Equivalent Full Load Cooling Hours = 1,131 hours

*Economizer Controls Calculations:*

$$\text{Electric Savings} = \text{OTF} \times \text{SF} \times \text{Capacity} / \text{Efficiency}$$

OTF = Operational Testing Factor = 0.8

SF = Savings Factor based on regional temperature bin data = 4,576 for equipment under 5.4 tons and 3,318 otherwise.

Capacity = Equipment Cooling Capacity in Tons

Efficiency = Energy Efficiency Ratio (EER) of equipment

ENERGY SAVINGS CALCULATIONS - UNIT REPLACEMENT							
ECM INPUTS	COOLING CAPACITY, BTU/Hr	ANNUAL COOLING HOURS	EXISTING UNITS (S)EER	NEW UNITS (S)EER	# OF UNITS	ENERGY SAVINGS kWh	DEMAND SAVINGS kW
AC-2	48,000	1,131	8 SEER	15 SEER	1	3,167	1.9
<b>Total</b>					1	3,167	1.9

ENERGY SAVINGS CALCULATIONS - ECONOMIZER CONTROLS					
ECM INPUTS	COOLING CAPACITY, TONS	ANNUAL COOLING HOURS	NEW UNITS (S)EER	ENERGY SAVINGS KWH	DEMAND SAVINGS kW
AC-2	4.0	4,438	15 SEER	976	0.2
<b>Total</b>	4.0			976	0.2

## **ECM #4: Recreation – Ice Rink Unit Replacement**

**REMOVED**

## ECM #5: Academy Hall – High Efficiency Split Systems

### Description:

Academy Hall has three 18,000 Btu/h cooling only Carrier Split Systems with outdoor condensing units and indoor air handling units mounted in the ceiling.

This ECM includes replacing the existing Carrier Split units with Mitsubishi Mr. Slim 14.3 SEER 1.5-ton cooling only mini split system units. The system will include a new outdoor unit and new above the ceiling horizontal unit. This ECM also includes programmable thermostats to provide night setback of 7-8°F during unoccupied periods.

EQUIPMENT INFORMATION			
ECM INPUT	EXISTING		
Unit Tag	CU-1	CU-3	CU-6
Unit Location	Outdoor Side Entrance	Outdoor Side Entrance	Outdoor Courtyard
Service For	Front Office Space	1st Floor Back Offices	1st Floor
Unit Type	Split System CU	Split System CU	Split System CU
Number of Units	1	1	1
Cooling Capacity, Btu/hr	18,000	18,000	18,000
Total Capacity, Tons	1.5	1.5	1.5
Manufacturer	Carrier	Carrier	Carrier
Model Number	38EH018310DL	BRCS0181BD	38CKC0183330
Efficiency (S/EER)	8 SEER	10 SEER	10 SEER

### Description of Scope:

#### Preliminary Scope

- Engineering design documentation
- Thorough site survey by HVAC / Electrical Contractor to review existing conditions.
- Bid proposals requested from contractors
- Equipment submittals

#### Construction Scope

- Remove existing outdoor condensing units.
- Remove existing indoor air handling units in 1<sup>st</sup> Floor ceiling.
- Remove associated electric wiring to AC unit, except where reused.
- Modifications to existing supply and return duct connections as required.
- Install proposed air conditioning unit as per the equipment list below including:
  - Curb adaptor as required.
  - Ductwork connection to new equipment and insulation.
  - One 7-day Programmable Thermostats. As required with new control system.

- Install new refrigerant lines.
- Provide equipment start-up and training.

This ECM includes replacement of three split indoor/outdoor units with a high efficiency unit of like size. The equipment list below is the basis of design and represents the efficiency and capacity minimum requirements for this ECM implementation:

<b>IMPLEMENTATION SUMMARY</b>			
<b>ECM INPUT</b>	<b>PROPOSED</b>		
Unit Tag	CU-1	CU-3	CU-6
Unit Location	Outdoor Side Entrance	Outdoor Side Entrance	Outdoor Courtyard
Service For	Front Office Space	1st Floor Back Offices	1st Floor
Unit Type	Split System CU	Split System CU	Split System CU
Number of Units	1	1	1
Cooling Capacity, Btu/hr	18,000	18,000	18,000
Total Capacity, Tons	1.5	1.5	1.5
Manufacturer	Mitsubishi	Mitsubishi	Mitsubishi
Model Number	PEA-A18AA/PUY-A18	PEA-A18AA/PUY-A18	PEA-A18AA/PUY-A18
Efficiency (S/EER)	14.3 SEER	14.3 SEER	14.3 SEER

### Energy Savings Calculations / Results:

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the existing efficiency rating and stipulated values in the protocols for operating hours and comparing them to the proposed units' efficiency ratings.

#### *Air Conditioning Upgrade Calculations:*

$$Demand\ Savings = \left(\frac{Btu/h}{1000}\right) \times \left(\frac{1}{EER_E} - \frac{1}{EER_P}\right) \times CF$$

$$Electric\ Savings = \left(\frac{Btu/h}{1000}\right) \times \left(\frac{1}{EER_E} - \frac{1}{EER_P}\right) \times Full\ Load\ Hours$$

EER = Energy Efficiency Ratio, Existing (E) and Proposed (P)

CF = Coincidence Factor = 0.67

Full Load Hours = Equivalent Full Load Cooling Hours = 1,131 hours

<b>ENERGY SAVINGS CALCULATIONS - UNIT REPLACEMENT</b>							
<b>ECM INPUTS</b>	<b>COOLING CAPACITY, BTU/Hr</b>	<b>ANNUAL COOLING HOURS</b>	<b>EXISTING UNITS (S)EER</b>	<b>NEW UNITS (S)EER</b>	<b># OF UNITS</b>	<b>ENERGY SAVINGS kWh</b>	<b>DEMAND SAVINGS kW</b>
<b>CU-1</b>	18,000	1,131	8 SEER	14.3 SEER	1	1,121	0.7
<b>CU-3</b>	18,000	1,131	10 SEER	14.3 SEER	1	612	0.4
<b>CU-6</b>	18,000	1,131	10 SEER	14.3 SEER	1	612	0.4
<b>Total</b>					3	2,345	1.4



## ECM #5A: Academy Hall – Direct Install High Efficiency Split Systems

### Description:

The Direct Install Program will be replacing two split system air conditioning units based on the scope of work provided by Hutchinson Mechanical on 9/19/2011. The two units being replaced are CU-2 and CU-4.

EQUIPMENT INFORMATION		
ECM INPUT	EXISTING	
Unit Tag	CU-2	CU-4
Unit Location	Outdoor Side Entrance	Outdoor Side Entrance
Service For	Front Office Space	1st Floor Back Offices
Unit Type	Split System CU	Split System CU
Number of Units	1	1
Cooling Capacity, Btu/hr	24,000	36,000
Total Capacity, Tons	2.0	3.0
Manufacturer	Carrier	Carrier
Model Number	38CKC024	C036X1021G
Efficiency (S/EER)	8 SEER	10 SEER

### Description of Scope:

Remove and Replace of existing units to be performed by Direct Install Contractor.

This ECM includes replacement of two split indoor/outdoor units with high efficiency units of like size. The equipment list below is the basis of design and represents the efficiency levels stipulated by the NJ Clean Energy Program Direct Install guidelines and capacity requirements for this ECM implementation:

IMPLEMENTATION SUMMARY		
ECM INPUT	PROPOSED	
Unit Tag	CU-2	CU-4
Unit Location	Outdoor Side Entrance	Outdoor Side Entrance
Service For	Front Office Space	1st Floor Back Offices
Unit Type	Split System CU	Split System CU
Number of Units	1	1
Cooling Capacity, Btu/hr	24,000	36,000
Total Capacity, Tons	2	3
Manufacturer	N/A	N/A
Model Number	N/A	N/A
Efficiency (S/EER)	15 SEER	15 SEER

**Energy Savings Calculations / Results:**

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the existing efficiency rating and stipulated values in the protocols for operating hours and comparing them to the proposed units' efficiency ratings.

*Air Conditioning Upgrade Calculations:*

$$Demand\ Savings = \left(\frac{Btu/h}{1000}\right) \times \left(\frac{1}{EER_E} - \frac{1}{EER_P}\right) \times CF$$

$$Electric\ Savings = \left(\frac{Btu/h}{1000}\right) \times \left(\frac{1}{EER_E} - \frac{1}{EER_P}\right) \times Full\ Load\ Hours$$

EER = Energy Efficiency Ratio, Existing (E) and Proposed (P)

Existing efficiency based on Program stipulated values based on unit age and capacity.

CF = Coincidence Factor = 0.67

Full Load Hours = Equivalent Full Load Cooling Hours = 1,131 hours

ENERGY SAVINGS CALCULATIONS - UNIT REPLACEMENT							
ECM INPUTS	COOLING CAPACITY, BTU/Hr	ANNUAL COOLING HOURS	EXISTING UNITS (S)EER	NEW UNITS (S)EER	# OF UNITS	ENERGY SAVINGS kWh	DEMAND SAVINGS kW
CU-2	24,000	1,131	10 SEER	15 SEER	1	905	0.5
CU-4	36,000	1,131	10 SEER	15 SEER	1	1,357	0.8
<b>Total</b>					2	2,262	1.3

## **ECM #6: Public Works – Split Unit Replacements**

**REMOVED**

## ECM #7: Municipal - High-Efficiency AC Units

### Description:

The Municipal Building Annex is cooled via fourteen (14) rooftop air handling units. The HVAC units service offices, corridors, restrooms, and the council room. Heating is supplied by hot water baseboard; additionally electric heating coils are in many of the rooftop units for backup only purposes. The HVAC units serving this space are past their useful life in some instances and in need of replacement.

This ECM would replace the existing rooftop units and split systems on a one for one basis with a more efficient unit. The council room unit will be swapped out with a packaged cooling unit and require removal of the existing condensing units, additional roof support, and any required duct work modifications. The new units will also be fitted with economizer controls and the council unit will also be fitted with CO2 controls.

The combination of these measures over the existing system will provide a vast improvement on electrical energy use. The existing equipment list is as follows:

EXISTING EQUIPMENT INFORMATION			
Unit Tag	HP-1 (UR)	HP-2 (UR)	HP-3 (UR)
Unit Location	Upper Roof	Upper Roof	Upper Roof
Service For	2nd Floor Offices	2nd Floor Offices	2nd Floor Offices
Unit Type	Packaged AC	Packaged AC	Packaged AC
Number of Units	1	1	1
Cooling Capacity, Btu/hr	30,000	30,000	36,000
Total Capacity, Tons	2.5	2.5	3
Manufacturer	York (Coleman)	York (Coleman)	York (Coleman)
Model Number	DAPB-F030AB	DAPB-F030AB	DAPB-F036AB
Efficiency, (S)EER	10 SEER	10 SEER	10 SEER

EXISTING EQUIPMENT INFORMATION			
Unit Tag	HP-4 (UR)	AC-2 (PR)	AC-1 (PR)
Unit Location	Upper Roof	Police Roof	Police Roof
Service For	2nd Floor Offices & Corridor	2nd Floor Police Offices	2nd Floor Police Offices
Unit Type	Packaged AC	Packaged AC/Gas Heat	Packaged AC/Gas Heat
Number of Units	1	1	1
Cooling Capacity, Btu/hr	60,000	240,000	150,000
Total Capacity, Tons	5	20	12.5
Manufacturer	General Electric	McQuay (Snyder)	ArcoAire (McQuay)
Model Number	BWC060C300B0	R200D0N401	N/A
Efficiency, (S)EER	9.4 SEER	9 EER	9 EER

<b>EXISTING EQUIPMENT INFORMATION</b>			
Unit Tag	AC-3 (PR)	HP-7 (FR)	HP-9 (FR)
Unit Location	Police Roof	Finance Roof	Finance Roof
Service For	2nd Floor Police Offices	Clerks Office & Finance Offices	Large Open Area Finance Offices
Unit Type	Packaged AC/Gas Heat	Packaged AC	Packaged AC
Number of Units	1	1	1
Cooling Capacity, Btu/hr	60,000	30,000	36,000
Total Capacity, Tons	5	2.5	3
Manufacturer	York	York (Coleman)	York (Coleman)
Model Number	D6CG060N09925A	DAPB-F030AB	DAPB-F036AB
Efficiency, (S)EER	9.1 EER	10 SEER	10 SEER

<b>EXISTING EQUIPMENT INFORMATION</b>			
Unit Tag	HP-10 (FR)	HP-11 (FR)	HP-12 (FR)
Unit Location	Finance Roof	Finance Roof	Finance Roof
Service For	Perimeter Finance Offices	Corner Finance Offices	Lobby
Unit Type	Packaged AC	Packaged AC	Packaged AC
Number of Units	1	1	1
Cooling Capacity, Btu/hr	30,000	30,000	30,000
Total Capacity, Tons	2.5	2.5	2.5
Manufacturer	York (Coleman)	York (Coleman)	York (Coleman)
Model Number	DAPB-F030AB	DAPB-F030AB	DAPB-F030AB
Efficiency, (S)EER	10 SEER	10 SEER	10 SEER

<b>EXISTING EQUIPMENT INFORMATION</b>			
Unit Tag	HP-14 (CR)	HP-5 (MR)	HP-6 (MR)
Unit Location	Council Roof	Mayor Roof	Mayor Roof
Service For	Council Room		
Unit Type	Split System /Outdoor	Packaged AC	Packaged AC
Number of Units	1	1	1
Cooling Capacity, Btu/hr	360,000	30,000	30,000
Total Capacity, Tons	30	2.5	2.5
Manufacturer	GE/ Trane	York (Coleman)	York (Coleman)
Model Number	BRB008/TTA180	DAPB-F030AB	DAPB-F030AB
Efficiency, (S)EER	9.5 EER	10 SEER	10 SEER

EXISTING EQUIPMENT INFORMATION	
Unit Tag	HP-13 (MR)
Unit Location	Mayor Roof
Service For	
Unit Type	Split System CU/Indoor
Number of Units	1
Cooling Capacity, Btu/hr	30,000
Total Capacity, Tons	2.5
Manufacturer	GE
Model Number	N/A / BHW930015860
Efficiency, (S)EER	9.4 SEER

### Description of Scope:

#### Preliminary Scope

- Engineering design documentation
- Thorough site survey by HVAC / Electrical Contractor to review existing conditions.
- Bid proposals requested from contractors
- Equipment submittals

#### Construction Scope

- Remove existing packaged AC units and split system AC units.
- Remove associated electric wiring to AC units, except where reused.
- Install new packaged unit for Council Room (HP-14) with CO2 controls and add additional roof supports required for new unit.
- Modifications to existing supply and return duct connections as required.
- Install proposed rooftop units as per the equipment list below including:
  - Roof curb adaptors as required.
  - Ductwork connection to new equipment and insulation.
  - Five 7-day Programmable Thermostats; one per unit. As required with new control system.
  - Controls integration capability with new energy management system being installed by the Township.
  - Packaged Economizer controls for the rooftop units
- Provide equipment start-up and training.

The equipment list below is the basis of design and represents the efficiency and capacity minimum requirements for this ECM implementation:

PROPOSED EQUIPMENT INFORMATION			
Unit Tag	HP-1 (UR)	HP-2 (UR)	HP-3 (UR)
Unit Location	Upper Roof	Upper Roof	Upper Roof
Service For	2nd Floor Offices	2nd Floor Offices	2nd Floor Offices
Unit Type	Packaged AC	Packaged AC	Packaged AC
Number of Units	1	1	1
Cooling Capacity, Btu/hr	30000	30000	36000
Total Capacity, Tons	2.5	2.5	3
Manufacturer	York	York	York
Model Number	DEX030A06	DEX030A06	DEX036A06
Efficiency, (S)EER	15 SEER	15 SEER	15 SEER

PROPOSED EQUIPMENT INFORMATION			
Unit Tag	HP-4 (UR)	AC-2 (PR)	AC-1 (PR)
Unit Location	Upper Roof	Police Roof	Police Roof
Service For	2nd Floor Offices	2nd Floor Police Offices	2nd Floor Police Offices
Unit Type	Packaged AC	Packaged AC/Gas Heat	Packaged AC/Gas Heat
Number of Units	1	1	1
Cooling Capacity, Btu/hr	60000	240000	150000
Total Capacity, Tons	5	20	12.5
Manufacturer	York	York	York
Model Number	DEY060A25	ZJ240S32B2	ZJ150N20E
Efficiency, (S)EER	14.5 SEER	11.6 EER	12.2 EER

PROPOSED EQUIPMENT INFORMATION			
Unit Tag	AC-3 (PR)	HP-7 (FR)	HP-9 (FR)
Unit Location	Police Roof	Finance Roof	Finance Roof
Service For	2nd Floor Police Offices	Clerks Office & Finance	Large Open Area Finance
Unit Type	Packaged AC/Gas Heat	Packaged AC	Packaged AC
Number of Units	1	1	1
Cooling Capacity, Btu/hr	60000	30000	36000
Total Capacity, Tons	5	2.5	3
Manufacturer	York	York	York
Model Number	ZJ061N13E	DEX030A06	DEX036A06
Efficiency, (S)EER	12.2 EER	15 SEER	15 SEER

PROPOSED EQUIPMENT INFORMATION			
Unit Tag	HP-10 (FR)	HP-11 (FR)	HP-12 (FR)
Unit Location	Finance Roof	Finance Roof	Finance Roof
Service For	Perimeter Finance Offices	Corner Finance Offices	Lobby
Unit Type	Packaged AC	Packaged AC	Packaged AC
Number of Units	1	1	1
Cooling Capacity, Btu/hr	30000	30000	30000
Total Capacity, Tons	2.5	2.5	2.5
Manufacturer	York	York	York
Model Number	DEX030A06	DEX030A06	DEX030A06
Efficiency, (S)EER	15 SEER	15 SEER	15 SEER

PROPOSED EQUIPMENT INFORMATION			
Unit Tag	HP-14 (CR)	HP-5 (MR)	HP-6 (MR)
Unit Location	Council Roof	Mayor Roof	Mayor Roof
Service For	Council Room	0	0
Unit Type	Packaged AC	Packaged AC	Packaged AC
Number of Units	1	1	1
Cooling Capacity, Btu/hr	360000	30000	30000
Total Capacity, Tons	30	2.5	2.5
Manufacturer	York	York	York
Model Number	ZI360C00B2	DEX030A06	DEX030A06
Efficiency, (S)EER	10.4 EER	15 SEER	15 SEER

PROPOSED EQUIPMENT INFORMATION	
Unit Tag	HP-13 (MR)
Unit Location	Mayor Roof
Service For	0
Unit Type	Split System CU/Indoor
Number of Units	1
Cooling Capacity, Btu/hr	30000
Total Capacity, Tons	2.5
Manufacturer	York
Model Number	CZH030 / AVG
Efficiency, (S)EER	18 SEER

### Energy Savings Calculations / Results:

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the existing efficiency rating and stipulated values in the protocols for operating hours and comparing them to the proposed units' efficiency ratings.

#### Air Conditioning Upgrade Calculations:

$$Demand\ Savings = \left(\frac{Btu/h}{1000}\right) \times \left(\frac{1}{EER_E} - \frac{1}{EER_P}\right) \times CF$$

$$Electric\ Savings = \left(\frac{Btu/h}{1000}\right) \times \left(\frac{1}{EER_E} - \frac{1}{EER_P}\right) \times Full\ Load\ Hours$$

EER = Energy Efficiency Ratio, Existing (E) and Proposed (P)

CF = Coincidence Factor = 0.67

Full Load Hours = Equivalent Full Load Cooling Hours = 1,131 hours



*Economizer Controls Calculations:*

$$\text{Electric Savings} = \text{OTF} \times \text{SF} \times \text{Capacity} / \text{Efficiency}$$

OTF = Operational Testing Factor = 0.8

SF = Savings Factor based on regional temperature bin data = 4,576 for equipment under 5.4 tons and 3,318 otherwise.

Capacity = Equipment Cooling Capacity in Tons

Efficiency = Energy Efficiency Ratio (EER) of equipment

ENERGY SAVINGS CALCULATIONS - UNIT REPLACEMENT							
ECM INPUTS	COOLING CAPACITY, BTU/Hr	ANNUAL COOLING HOURS	EXISTING UNITS (S)EER	NEW UNITS (S)EER	# OF UNITS	ENERGY SAVINGS kWh	DEMAND SAVINGS kW
HP-1 (UR)	30,000	1,131	10 SEER	15 SEER	1	1,131	0.7
HP-2 (UR)	30,000	1,131	10 SEER	15 SEER	1	1,131	0.7
HP-3 (UR)	36,000	1,131	10 SEER	15 SEER	1	1,357	0.8
HP-4 (UR)	60,000	1,131	9.4 SEER	14.5 SEER	1	2,539	1.5
AC-2 (PR)	240,000	1,131	9 EER	11.6 EER	1	6,760	4.0
AC-1 (PR)	150,000	1,131	9 EER	12.2 EER	1	3,059	1.8
AC-3 (PR)	60,000	1,131	9.1 EER	12.2 EER	1	1,895	1.1
HP-7 (FR)	30,000	1,131	10 SEER	15 SEER	1	1,131	0.7
HP-9 (FR)	36,000	1,131	10 SEER	15 SEER	1	1,357	0.8
HP-10 (FR)	30,000	1,131	10 SEER	15 SEER	1	1,131	0.7
HP-11 (FR)	30,000	1,131	10 SEER	15 SEER	1	1,131	0.7
HP-12 (FR)	30,000	1,131	10 SEER	15 SEER	1	1,131	0.7
HP-14 (CR)	360,000	1,131	9.5 EER	10.4 EER	1	3,709	2.2
HP-5 (MR)	30,000	1,131	10 SEER	15 SEER	1	1,131	0.7
HP-6 (MR)	30,000	1,131	10 SEER	15 SEER	1	1,131	0.7
HP-13 (MR)	30,000	1,131	9.4 SEER	18 SEER	1	1,725	1.0
<b>Total</b>					16	31,449	18.6

<b>ENERGY SAVINGS CALCULATIONS - ECONOMIZER CONTROLS</b>					
<b>ECM INPUTS</b>	<b>COOLING CAPACITY, TONS</b>	<b>ANNUAL COOLING HOURS</b>	<b>NEW UNITS (S)EER</b>	<b>ENERGY SAVINGS KWH</b>	<b>DEMAND SAVINGS kW</b>
<b>HP-1 (UR)</b>	2.5	4,438	15 SEER	610	0.1
<b>HP-2 (UR)</b>	2.5	4,438	15 SEER	610	0.1
<b>HP-3 (UR)</b>	3.0	4,438	15 SEER	732	0.2
<b>HP-4 (UR)</b>	5.0	4,438	14.5 SEER	1,262	0.3
<b>AC-2 (PR)</b>	20.0	4,438	11.6 EER	4,577	1.0
<b>AC-1 (PR)</b>	12.5	4,438	12.2 EER	2,720	0.6
<b>AC-3 (PR)</b>	5.0	4,438	12.2 EER	1,500	0.3
<b>HP-7 (FR)</b>	2.5	4,438	15 SEER	610	0.1
<b>HP-9 (FR)</b>	3.0	4,438	15 SEER	732	0.2
<b>HP-10 (FR)</b>	2.5	4,438	15 SEER	610	0.1
<b>HP-11 (FR)</b>	2.5	4,438	15 SEER	610	0.1
<b>HP-12 (FR)</b>	2.5	4,438	15 SEER	610	0.1
<b>HP-14 (CR)</b>	30.0	4,438	10.4 EER	7,657	1.7
<b>HP-5 (MR)</b>	2.5	4,438	15 SEER	610	0.1
<b>HP-6 (MR)</b>	2.5	4,438	15 SEER	610	0.1
<b>HP-13 (MR)</b>	0.0	0	18 SEER	0	0.0
<b>Total</b>	98.5			24,061	5.4

## ECM #8: Senior – Direct Install Split Unit Replacement

### Description:

The Direct Install Program will be replacing three split system air conditioning units based on the scope of work provided by Hutchinson Mechanical on 9/19/2011.

EQUIPMENT INFORMATION			
ECM INPUT	EXISTING		
Unit Tag	CU-1	CU-2	CU-3
Unit Location	Outdoor Side Rear	Outdoor Side Rear	Outdoor Side Rear
Service For	Interior	Interior	Interior
Unit Type	Split System CU	Split System CU	Split System CU
Number of Units	1	1	1
Cooling Capacity, Btu/hr	60,000	60,000	60,000
Total Capacity, Tons	5.0	5.0	5.0
Manufacturer	Carrier	Carrier	Carrier
Model Number	38ED060306	38ED060306	38ED060306
Efficiency (S/EER)	9.4 SEER	9.4 SEER	9.4 SEER

### Description of Scope:

Remove and Replace of existing units to be performed by Direct Install Contractor.

This ECM includes replacement of three split indoor/outdoor units with high efficiency units of like size. The equipment list below is the basis of design and represents the efficiency levels stipulated by the NJ Clean Energy Program Direct Install guidelines and capacity requirements for this ECM implementation:

IMPLEMENTATION SUMMARY			
ECM INPUT	PROPOSED		
Unit Tag	CU-1	CU-2	CU-3
Unit Location	Outdoor Side Rear	Outdoor Side Rear	Outdoor Side Rear
Service For	Interior	Interior	Interior
Unit Type	Split System CU	Split System CU	Split System CU
Number of Units	1	1	1
Cooling Capacity, Btu/hr	60,000	60,000	60,000
Total Capacity, Tons	5.0	5.0	5.0
Manufacturer	N/A	N/A	N/A
Model Number	N/A	N/A	N/A
Efficiency (S/EER)	15 SEER	15 SEER	15 SEER

**Energy Savings Calculations / Results:**

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the existing efficiency rating and stipulated values in the protocols for operating hours and comparing them to the proposed units' efficiency ratings.

*Air Conditioning Upgrade Calculations:*

$$Demand\ Savings = \left(\frac{Btu/h}{1000}\right) \times \left(\frac{1}{EER_E} - \frac{1}{EER_P}\right) \times CF$$

$$Electric\ Savings = \left(\frac{Btu/h}{1000}\right) \times \left(\frac{1}{EER_E} - \frac{1}{EER_P}\right) \times Full\ Load\ Hours$$

EER = Energy Efficiency Ratio, Existing (E) and Proposed (P)

Existing efficiency based on Program stipulated values based on unit age and capacity.

CF = Coincidence Factor = 0.67

Full Load Hours = Equivalent Full Load Cooling Hours = 1,131 hours

ENERGY SAVINGS CALCULATIONS - UNIT REPLACEMENT							
ECM INPUTS	COOLING CAPACITY, BTU/Hr	ANNUAL COOLING HOURS	EXISTING UNITS (S)EER	NEW UNITS (S)EER	# OF UNITS	ENERGY SAVINGS kWh	DEMAND SAVINGS kW
CU-1	60,000	1,131	9.4 SEER	15 SEER	1	2,695	1.6
CU-2	60,000	1,131	9.4 SEER	15 SEER	1	2,695	1.6
CU-3	60,000	1,131	9.4 SEER	15 SEER	1	2,695	1.6
<b>Total</b>					3	8,085	4.8

## **ECM #9: Municipal – Boiler Replacement**

### **Description:**

The Municipal Building is heated via a single natural gas fired Weil McLain hot water boiler located in a basement mechanical room adjacent to the Courtroom. The boiler has a nameplate input rating of 2,049 MBH. Hot Water is circulated via two sets of dedicated hot water pumps, one set circulated heating hot water to the Police side of the building for the northeast and southwest zones of the building, a second set pumps supplies hot water to the Municipal side of the building.

This ECM includes replacement of the existing Weil McLain with two Hydrotherm KN-10 boilers rated at 1,000 MBH input capacity. The boilers will be piped to a common header to service the entire building load and reuse the existing pumping arrangement. The installation will include all necessary additional piping, venting, insulation, and electrical wiring for operation of the new boilers.

### **Description of Scope:**

#### Preliminary Scope

- Engineering design documentation
- Thorough site survey by HVAC / Electrical Contractor to review existing conditions.
- Bid proposals requested from contractors
- Equipment submittals

#### Construction Scope

- Demo and dispose of existing Weil McLain Boiler.
- Reuse existing boiler pad.
- Install two new Hydrotherm KN-10 Boilers with controls.
- Pipe boilers to common header and tie into existing boiler pumps.
- Cap existing boiler flue stack and install new flue and combustion air vent per manufacturers specifications.
- Provide equipment start-up and training.

The equipment list below is the basis of design and represents the efficiency and capacity minimum requirements for this ECM implementation:

<b>ECM IMPLEMENTATION SUMMARY</b>		
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>
Quantity	1	2
Boiler Manufacturer	Weil McLain	HydroTherm
Model	788	KN-10
Boiler Fuel	Natural Gas	Natural Gas
Nameplate Input Rating (MBH)	2049	1000
Nameplate Output Rating (MBH)	1632	927
Efficiency	75%	88%
Total Input Capacity (MBH)	2049	2000
Total Output Capacity (MBH)	1632	1854

**Energy Savings Calculations / Results:**

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the existing efficiency rating and utility usage data for the Municipal Building.

Annual Natural Gas Use: 9,649.38 Therms (From 6/3/2010 to 6/3/2011)

Baseline Hot Water Gas Use: 38.43 Therms (Ave from May thru September Gas Use)  
1.2743 Therms/day

Existing Heating Natural Gas: 9,649.38 Therms - 465.04 Therms (Annual DHW Load) =  
9,184.34 Therms

$$Bldg \text{ Heat Required} = Existing \text{ Nat Gas (Therms)} \times Heating \text{ Eff.}(\%) \times Fuel \text{ Heat Value} \left( \frac{BTU}{Therm} \right)$$

$$Pr \text{ oposed Heating Gas Usage} = \frac{Bldg \text{ Heat Required (BTU)}}{Heating \text{ Eff.}(\%) \times Fuel \text{ Heat Value} \left( \frac{BTU}{Therm} \right)}$$

$$Energy \text{ Cost} = Heating \text{ Gas Usage(Therms)} \times Ave \text{ Fuel Cost} \left( \frac{\$}{Therm} \right)$$

<b>NATURAL GAS LOAD BREAKOUT</b>								
<b>Previous Read Date</b>	<b>Current Read Date</b>	<b>Utility Use, Therms</b>	<b>HDD (65F)</b>	<b>Days</b>	<b>DHW, Therms</b>	<b>DHW LOAD Therms / Day</b>	<b>DHW Calc Load, Therms</b>	<b>Heating Load, Therms</b>
06/03/10	07/06/10	36.1	6	33.0	36.1	1.0936	36.09	0.00
07/06/10	08/03/10	32.8	2	28.0	32.8	1.1725	32.83	0.00
08/03/10	09/03/10	38.9	2	31.0	38.9	1.2552	38.91	0.00
09/03/10	10/01/10	35.9	23	28.0	35.9	1.2825	35.91	0.00
10/01/10	11/01/10	44.1	228	31.0			39.50	4.58
11/01/10	12/02/10	715.1	496	31.0			39.50	675.60
12/02/10	01/05/11	2,551.5	992	34.0			43.33	2,508.13
01/05/11	02/03/11	2,413.3	1098	29.0			36.95	2,376.31
02/03/11	03/03/11	1,786.0	772	28.0			35.68	1,750.27
03/03/11	04/04/11	1,474.8	641	32.0			40.78	1,433.99
04/04/11	05/03/11	472.4	303	29.0			36.95	435.47
05/03/11	06/03/11	48.6	88	31.0	48.6	1.5677	48.60	0.00
<b>AVERAGE</b>					38.4680	1.2743		
<b>TOTAL</b>		9,649.4	4651				465.04	9,184.34

<b>CONDENSING BOILER CALCULATIONS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	Existing Cast Iron Boilers	New Condensing Boilers	
<b>Existing Nat Gas (Therms)</b>	9,184	0	
<b>Boiler Efficiency (%)</b>	75%	88%	13%
<b>Nat Gas Heat Value (BTU/Therm)</b>	100,000	100,000	
<b>Equivalent Building Heat Usage (MMBTUs)</b>	689	689	
<b>Gas Cost (\$/Therm)</b>	1.70	1.70	
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Natural Gas Usage (Therms)</b>	9,184	7,828	1,357
<b>Energy Cost (\$)</b>	\$15,613	\$13,307	\$2,307
<b>COMMENTS:</b>	Boiler Efficiency Based on age of boiler		

## ECM #10: Library – Boiler Replacement

### Description:

The Direct Install Program will be replacing one 325 MBH natural gas fired hot water boiler based on the scope of work provided by Hutchinson Mechanical on 9/19/2011 at the Library.

### Description of Scope:

Remove and Replace of existing boiler to be performed by Direct Install Contractor. New unit will be based on installation of same size boiler with a minimum efficiency requirement of 93% per Direct Install guidelines.

### Energy Savings Calculations / Results:

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the Direct Install stipulated efficiency based on age and type of boiler and using the Protocols heating savings formula.

$$\text{Gas Savings} = \left( \frac{0.8 \times \text{CAPY}_{in} \times \text{HDD}_{MOD} \times 24}{\Delta T \times 100,000} \right) \times \left( 1 - \frac{\text{AFUE}_b}{\text{AFUE}_q} \right)$$

PHL = Philadelphia Weather Location

0.8 = Oversize Factor of standard boiler or furnace, equivalent to 25% of capacity

AFUE<sub>b</sub> = Annual Fuel Utilization Efficiency of the existing boiler

AFUE<sub>q</sub> = Annual Fuel Utilization Efficiency of the proposed boiler

CAPY<sub>in</sub> = Capacity of the boiler (Btu/h)

HDD<sub>MOD</sub> = Heating Degree Days Modified based on building type

ΔT = Design Temperature difference with balance temperature of 65 °F and outdoor temperature based on location.



<b>DIRECT INSTALL BOILER/FURNACE CALCULATION</b>	
<b>ECM INPUTS</b>	<b>RESULTS</b>
Location	PHL
Building Type	Public Assembly
Building Type Number	8
Manufacturer	Weil McLain
Unit Type	Boiler
Year Built	1988
Fuel Type	Gas
Input Capacity (Btu/hr)	325,000
Existing Efficiency (%)	77%
Proposed Efficiency (%)	93%
Fuel Conversion Factor	100,000
$\Delta T$	50
HDD <sub>mod</sub>	3042
Oversize Factor	0.8
Gas Savings (therms)	653
Fuel Cost (\$/Unit)	\$1.29
Cost Savings	\$843

## ECM #11: Senior – Direct Install Furnace Replacement

### Description:

The Direct Install Program will be replacing two 132 MBH natural gas fired furnaces based on the scope of work provided by Hutchinson Mechanical on 9/19/2011 at the Senior Center.

### Description of Scope:

Remove and Replace of existing furnace to be performed by Direct Install Contractor. New unit will be based on installation of same size furnaces with a minimum efficiency requirement of 93% per Direct Install guidelines.

### Energy Savings Calculations / Results:

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the Direct Install stipulated efficiency based on age and type of boiler and using the Protocols heating savings formula.

$$\text{Gas Savings} = \left( \frac{0.8 \times \text{CAPY}_{in} \times \text{HDD}_{MOD} \times 24}{\Delta T \times 100,000} \right) \times \left( 1 - \frac{\text{AFUE}_b}{\text{AFUE}_q} \right)$$

PHL = Philadelphia Weather Location

0.8 = Oversize Factor of standard boiler or furnace, equivalent to 25% of capacity

AFUE<sub>b</sub> = Annual Fuel Utilization Efficiency of the existing furnace

AFUE<sub>q</sub> = Annual Fuel Utilization Efficiency of the proposed furnace

CAPY<sub>in</sub> = Capacity of the furnace (Btu/h)

HDD<sub>MOD</sub> = Heating Degree Days Modified based on building type

ΔT = Design Temperature difference with balance temperature of 65 °F and outdoor temperature based on location.

<b>DIRECT INSTALL BOILER/FURNACE CALCULATION</b>	
<b>ECM INPUTS</b>	<b>RESULTS</b>
Location	PHL
Building Type	Public Assembly
Building Type Number	8
Manufacturer	Carrier
Unit Type	Furnace
Year Built	1988
Fuel Type	Gas
Input Capacity (Btu/hr)	264,000
Existing Efficiency (%)	76%
Proposed Efficiency (%)	93%
Fuel Conversion Factor	100,000
$\Delta T$	50
HDD <sub>mod</sub>	3042
Oversize Factor	0.8
Gas Savings (therms)	564
Fuel Cost (\$/Unit)	\$1.29
Cost Savings	\$727

## ECM #12: Academy Hall – Direct Install Boiler Replacement

### Description:

The Direct Install Program will be replacing one 450 MBH natural gas fired hot water boiler based on the scope of work provided by Hutchinson Mechanical on 9/19/2011 at Academy Hall, which is utilized by public safety.

### Description of Scope:

Remove and Replace of existing boiler to be performed by Direct Install Contractor. New unit will be based on installation of same size boiler with a minimum efficiency requirement of 93% per Direct Install guidelines.

### Energy Savings Calculations / Results:

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the Direct Install stipulated efficiency based on age and type of boiler and using the Protocols heating savings formula.

$$Gas\ Savings = \left( \frac{0.8 \times CAPY_{in} \times HDD_{MOD} \times 24}{\Delta T \times 100,000} \right) \times \left( 1 - \frac{AFUE_b}{AFUE_q} \right)$$

PHL = Philadelphia Weather Location

0.8 = Oversize Factor of standard boiler or furnace, equivalent to 25% of capacity

AFUE<sub>b</sub> = Annual Fuel Utilization Efficiency of the existing boiler

AFUE<sub>q</sub> = Annual Fuel Utilization Efficiency of the proposed boiler

CAPY<sub>in</sub> = Capacity of the boiler (Btu/h)

HDD<sub>MOD</sub> = Heating Degree Days Modified based on building type

ΔT = Design Temperature difference with balance temperature of 65 °F and outdoor temperature based on location.

<b>DIRECT INSTALL BOILER/FURNACE CALCULATION</b>	
<b>ECM INPUTS</b>	<b>RESULTS</b>
Location	PHL
Building Type	Public Order/Safety
Building Type Number	9
Manufacturer	Weil McLain
Unit Type	Boiler
Year Built	1985
Fuel Type	Gas
Input Capacity (Btu/hr)	450,000
Existing Efficiency (%)	70%
Proposed Efficiency (%)	93%
Fuel Conversion Factor	100,000
$\Delta T$	50
HDD <sub>mod</sub>	2169
Oversize Factor	0.8
Gas Savings (therms)	927
Fuel Cost (\$/Unit)	\$1.29
Cost Savings	\$1,196

## ECM #13: Library – Direct Install Fuel Economizer

### Description:

The Direct Install Program will be installing fuel economizer controls on the gas fired hot water boiler based on the scope of work provided by Hutchinson Mechanical on 9/19/2011 at the Library.

### Description of Scope:

Install new fuel use economizer controls on boiler to be performed by Direct Install Contractor. New unit will be based on Intellidyne IntelliCon Controller or equivalent per Direct Install guidelines.

### Energy Savings Calculations / Results:

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the Direct Install stipulated efficiency based on age and type of boiler and using the Protocols heating savings formula in order to calculation annual usage. The manufacturer suggests a savings of 10% to 20% can be realized for installing the device; however a 5% savings factor was used in order to calculate savings.

$$\text{Gas Savings} = \left( \frac{0.8 \times \text{CAPY}_{in} \times \text{HDD}_{MOD} \times 24}{\Delta T \times 100,000} \right) \times \left( \frac{1}{\text{AFUE}_q} \right) \times \text{SF}$$

PHL = Philadelphia Weather Location

0.8 = Oversize Factor of standard boiler or furnace, equivalent to 25% of capacity

AFUE<sub>q</sub> = Annual Fuel Utilization Efficiency of the proposed boiler

CAPY<sub>in</sub> = Capacity of the boiler (Btu/h)

HDD<sub>MOD</sub> = Heating Degree Days Modified based on building type

ΔT = Design Temperature difference with balance temperature of 65 °F and outdoor temperature based on location.

SF = Savings Factor (5%)

<b>DIRECT INSTALL CALCULATION</b>	
<b>ECM INPUTS</b>	<b>RESULTS</b>
Location	PHL
Building Type	Public Assembly
Building Type Number	8
Unit Type	Boiler
Year Built	1988
Fuel Type	Gas
Input Capacity (Btu/hr)	325,000
Existing Efficiency (%)	93%
Fuel Economizer Savings Factor (%)	5%
Fuel Conversion Factor	100,000
$\Delta T$	50
HDD <sub>mod</sub>	3042
Oversize Factor	0.8
Gas Savings (therms)	204
Fuel Cost (\$/Unit)	\$1.29
Cost Savings	\$263

## ECM #14: Academy Hall – Direct Install Fuel Economizer

### Description:

The Direct Install Program will be installing fuel economizer controls on the gas fired hot water boiler based on the scope of work provided by Hutchinson Mechanical on 9/19/2011 at Academy Hall.

### Description of Scope:

Install new fuel use economizer controls on boiler to be performed by Direct Install Contractor. New unit will be based on Intellidyne IntelliCon Controller or equivalent per Direct Install guidelines.

### Energy Savings Calculations / Results:

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the Direct Install stipulated efficiency based on age and type of boiler and using the Protocols heating savings formula in order to calculation annual usage. The manufacturer suggests a savings of 10% to 20% can be realized for installing the device; however a 5% savings factor was used in order to calculate savings.

$$Gas\ Savings = \left( \frac{0.8 \times CAPY_{in} \times HDD_{MOD} \times 24}{\Delta T \times 100,000} \right) \times \left( \frac{1}{AFUE_q} \right) \times SF$$

PHL = Philadelphia Weather Location

0.8 = Oversize Factor of standard boiler or furnace, equivalent to 25% of capacity

AFUE<sub>q</sub> = Annual Fuel Utilization Efficiency of the proposed boiler

CAPY<sub>in</sub> = Capacity of the boiler (Btu/h)

HDD<sub>MOD</sub> = Heating Degree Days Modified based on building type

ΔT = Design Temperature difference with balance temperature of 65 °F and outdoor temperature based on location.

SF = Savings Factor (5%)



<b>DIRECT INSTALL CALCULATION</b>	
<b>ECM INPUTS</b>	<b>RESULTS</b>
Location	PHL
Building Type	Public Order/Safety
Building Type Number	9
Unit Type	Boiler
Year Built	1988
Fuel Type	Gas
Input Capacity (Btu/hr)	450,000
Existing Efficiency (%)	93%
Fuel Economizer Savings Factor (%)	5%
Fuel Conversion Factor	100,000
$\Delta T$	50
HDD <sub>mod</sub>	2169
Oversize Factor	0.8
Gas Savings (therms)	202
Fuel Cost (\$/Unit)	\$1.29
Cost Savings	\$260

---

## **ECM #15: All Buildings – CRT Monitor Replacement**

### **Description:**

The Township still utilizes a small amount of CRT Monitors for use by its staff. These monitors not only utilize more energy in operating mode, but also while being in idle mode. Typical monitors throughout the buildings consisted of 17 inch size monitors.

This ECM will replace all remaining thirteen (13) existing CRT monitors at the Library, Municipal, and DPW buildings with new 17” Dell LCD Model P170S monitors.

### **Description of Scope:**

- Verify quantity and location of replacement monitors.
- Verify manufacturer and model to be purchased with Township Technical Support personnel.
- Township staff installs new monitors.

### **Energy Savings Calculations / Results:**

Savings calculations were based on operating occupied hours per week of operating staff, and estimated idle time of monitors per week outside occupied hours. Power consumption data is based on actual monitor characteristics for a Dell CRT Model E773c, and Dell LCD Model P170S.

$$\text{Energy Savings} = Qty \times Op\ Hrs \times P_o + Qty \times IdleHrs \times P_i$$

Qty = Quantity

Op Hrs = Operating Hours per Year

Idle Hrs = Idle Hours per Year

P<sub>O</sub> = Operating Power Consumption Watts

P<sub>I</sub> = Idle Power Consumption Watts

Library:

<b>CRT MONITOR REPLACEMENT CALCULATIONS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	17" CRT	17" LCD	
<b># of Monitors</b>	8	8	
<b>Power Cons. (W)</b>	71	22	49
<b>Idle Power Cons. (W)</b>	5	0.56	4.44
<b>Operating Hrs per Week</b>	40	40	
<b>Operating Weeks per Yr</b>	50	50	
<b>Idle Hrs per Week</b>	128	128	
<b>Idle Weeks per Yr</b>	52	52	
<b>Elec Cost (\$/kWh)</b>	0.181	0.181	
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Electric Usage (kWh)</b>	1,402	382	1,020
<b>Energy Cost (\$)</b>	\$254	\$69	\$185
<b>COMMENTS:</b>	Savings Based on Dell 17: CRT Monitor Compared with Dell 17 " LCD Model P170S		

*Municipal*

<b>CRT MONITOR REPLACEMENT CALCULATIONS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	17" CRT	17" LCD	
<b># of Monitors</b>	5	5	
<b>Power Cons. (W)</b>	71	22	49
<b>Idle Power Cons. (W)</b>	5	0.56	4.44
<b>Operating Hrs per Week</b>	40	40	
<b>Operating Weeks per Yr</b>	50	50	
<b>Idle Hrs per Week</b>	128	128	
<b>Idle Weeks per Yr</b>	52	52	
<b>Elec Cost (\$/kWh)</b>	0.165	0.165	
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Electric Usage (kWh)</b>	876	239	638
<b>Energy Cost (\$)</b>	\$145	\$39	\$105
<b>COMMENTS:</b>	Savings Based on Dell 17: CRT Monitor Compared with Dell 17 " LCD Model P170S		

*Public Works*

<b>CRT MONITOR REPLACEMENT CALCULATIONS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	17" CRT	17" LCD	
<b># of Monitors</b>	1	1	
<b>Power Cons. (W)</b>	71	22	49
<b>Idle Power Cons. (W)</b>	5	0.56	4.44
<b>Operating Hrs per Week</b>	40	40	
<b>Operating Weeks per Yr</b>	50	50	
<b>Idle Hrs per Week</b>	128	128	
<b>Idle Weeks per Yr</b>	52	52	
<b>Elec Cost (\$/kWh)</b>	0.180	0.180	
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Electric Usage (kWh)</b>	175	48	128
<b>Energy Cost (\$)</b>	\$32	\$9	\$23
<b>COMMENTS:</b>	Savings Based on Dell 17: CRT Monitor Compared with Dell 17 " LCD Model P170S		

## **ECM #16: Monroe Pool – Pool Pump Time Controls**

### **Description:**

The Monroe Pool is an outdoor public swimming pool that operated from Memorial Day to Labor Day during the hours of 12 p.m. to 8 p.m. on weekdays, and 11 a.m. to 6 p.m. on weekends; and swimming lessons occurring on Fridays and Saturdays starting at 9 a.m. The pool has two 5 horsepower filtration pumping system that operate 24/7 during summer operating. It is recommended that the pumps be operated off a timer that would shut the pumps down at 9:00 p.m. and start the pumps at 6 a.m. This will provide 3 to 6 hours prior to pool opening of filtration operation.

This ECM would utilize the existing StingL SR500 controllers that are capable of timed control. The controls will be programmed to Timed Start and End per the instruction provided in the SR500 operating manual. In addition the two 5 horsepower motors will be replaced with premium efficiency pump motors. *It is expected the Townships Public Works Department's Staff is capable of performing the pool timer programming and motor replacement in order to reduce the costs of this ECM.*

### **Description of Scope:**

#### Construction Scope

- Demo and dispose of existing Marathon 5 HP pump motors.
- Reuse existing pump and mount bracket and order motor frame adapter if necessary.
- Install two new Baldor Model EL3608T 5 horsepower motors rated at 85% efficient, 230 volt single phase, 3500 rpm, and 184T frame.
- Reuse existing electrical wiring to motor and SR500 controller.
- Program SR500 to operate off Timed Start and set start to 06:00 AM and set stop to 09:00 PM.

The equipment list below is the basis of design and represents the efficiency and capacity minimum requirements for this ECM implementation:

<b>ECM IMPLEMENTATION SUMMARY</b>		
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>
Quantity	2	2
Motor Horsepower (HP)	5	5
Manufacturer	Marathon	Badlor
Model Number	1D184TCDR7910AR	EL3608T
Voltage	208-230	230
Phase-Hertz	Single -60 Hz	Single -60 Hz
Frame	184TDZ	184T
Enclosure	ODP	TEFC
RPM	3,510	3,450
NEMA Full Load Efficiency	80%	85%

**Energy Savings Calculations / Results:**

The energy savings are calculated by using the existing equipment information and operating information.

Assumptions include 24 hour operation per day based on existing controls for a total of 95 days at an 85% load factor.

$$\text{Energy Use, kWh} = \frac{\text{Pump HP} \times 0.746 \frac{\text{kW}}{\text{HP}} \times \text{Operating Hrs} \times \text{Load Factor}}{\text{Motor Efficiency \%}}$$

$$\text{Cost Savings} = \text{Energy Savings, kWh} \times \text{Cost of Electricity, } \left( \frac{\$}{\text{kWh}} \right)$$

<b>POOL PUMP CONTROL CALCULATIONS</b>			
<b>ECM INPUTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>ECM INPUTS</b>	Continuous Operation	Pump Time Clock Control	
<b>Quantity</b>	2	2	
<b>Pump Power (HP)</b>	5	5	
<b>Estimated Load Factor (%)</b>	85%	85%	
<b>Conversion Factor (kW/HP)</b>	0.746	0.746	
<b>Operating Hrs</b>	2,280	1,520	760
<b>Motor Efficiency</b>	80.0%	85.0%	
<b>Elec Cost (\$/kWh)</b>	\$0.205	\$0.205	
<b>ENERGY SAVINGS CALCULATIONS</b>			
<b>ECM RESULTS</b>	<b>EXISTING</b>	<b>PROPOSED</b>	<b>SAVINGS</b>
<b>Energy Use (kWh)</b>	18,072	11,339	6,733
<b>Energy Cost (\$)</b>	\$3,705	\$2,325	\$1,380
<b>COMMENTS:</b>	Assume 95 Days of Operation Memorial Day to Labor Day. Timeclock will operate pool from 6 AM to 10 PM.		



## **ECM #17: Monroe Pool – DHW Conversion to Gas**

**REMOVED**

## ECM #18: Senior – Direct Install Faucet Aerators

### Description:

The Direct Install Program will be installing three faucet aerators (lavatory) based on the scope of work provided by Hutchinson Mechanical on 9/19/2011 at Academy Hall.

### Description of Scope:

Install new faucet aerators to be performed by Direct Install Contractor. New unit will be based on Direct Install guidelines.

### Energy Savings Calculations / Results:

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the Direct Install protocols for

$$Savings = \frac{(60 \times H \times D \times (F_{base} - F_{eff}) \times 8.33 \times \Delta T \times \frac{1}{Eff})}{C}$$

60 = Conversion from Hours to Minutes

H = Hours per Day of Device Usage (Stipulated by Direct Install Guidelines at 30 minutes for Aerators).

D = Days per Year of Facility Operation

F<sub>base</sub> = Baseline device flow rate (gallons per minute)

F<sub>eff</sub> = Low Flow device flow rate (gallons per minute)

8.33 = Heat Content of Water (Btu/gal/°F)

ΔT = Temperature difference between cold water intake and output

Eff = Efficiency percentage of water heating equipment

C = Conversion Factor from Btu to Therms or kWh (100,000 Btu/Therm; 3,413 Btu/kWh)

<b>DIRECT INSTALL LOW FLOW DEVICES CALCULATION</b>	
<b>ECM INPUTS</b>	<b>RESULTS</b>
Device Type	Faucet Aerators
Water Heating Type	Gas
Quantity	3
Hours per Day of Device Usage	0.5
Days per Year of Facility Operation	200
Baseline Device Flow Rate (gpm)	2.2
Low Flow Device Flow Rate (gpm)	1
$\Delta T$	50
Efficiency of Water Heater	80%
Conversion Factor	100,000
Heat Content of Water (Btu/gal <sup>o</sup> F)	8.33
Energy Savings (Fuel Unit)	112
Energy Cost (\$ per Fuel Unit)	\$1.290
Cost Savings	\$145.07

## ECM #20: Recreation – Direct Install High Efficiency Split System

### Description:

The Direct Install Program will be replacing one split system air conditioning unit based on the scope of work provided by Hutchinson Mechanical on 10/10/2011. The unit being replaced is CU-1.

### Description of Scope:

Remove and Replace of existing unit to be performed by Direct Install Contractor.

This ECM includes replacement of two split indoor/outdoor units with high efficiency units of like size. The equipment list below is the basis of design and represents the efficiency levels stipulated by the NJ Clean Energy Program Direct Install guidelines and capacity requirements for this ECM implementation:

EQUIPMENT INFORMATION	
ECM INPUT	EXISTING
Unit Tag	CU-1
Unit Location	Outdoor Side
Service For	Office Area
Unit Type	Split System CU
Number of Units	1
Cooling Capacity, Btu/hr	60,000
Total Capacity, Tons	5.0
Manufacturer	Lennox
Model Number	HS19-653V-3Y
Efficiency (S/EER)	10 SEER

### Energy Savings Calculations / Results:

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the existing efficiency rating and stipulated values in the protocols for operating hours and comparing them to the proposed units' efficiency ratings.

#### Air Conditioning Upgrade Calculations:

$$Demand\ Savings = \left( \frac{Btu/h}{1000} \right) \times \left( \frac{1}{EER_E} - \frac{1}{EER_P} \right) \times CF$$

$$Electric\ Savings = \left(\frac{Btu/h}{1000}\right) \times \left(\frac{1}{EER_E} - \frac{1}{EER_P}\right) \times Full\ Load\ Hours$$

EER = Energy Efficiency Ratio, Existing (E) and Proposed (P)

Existing efficiency based on Program stipulated values based on unit age and capacity.

CF = Coincidence Factor = 0.67

Full Load Hours = Equivalent Full Load Cooling Hours = 1,131 hours

ENERGY SAVINGS CALCULATIONS - UNIT REPLACEMENT							
ECM INPUTS	COOLING CAPACITY, BTU/Hr	ANNUAL COOLING HOURS	EXISTING UNITS (S)EER	NEW UNITS (S)EER	# OF UNITS	ENERGY SAVINGS kWh	DEMAND SAVINGS kW
CU-1	60,000	1,131	10 SEER	15 SEER	1	2,262	1.3
<b>Total</b>					1	2,262	1.3

## ECM #21: Recreation – Direct Install Furnace Replacement

### Description:

The Direct Install Program will be replacing one 100 MBH natural gas fired furnace based on the scope of work provided by Hutchinson Mechanical on 10/10/2011 at the Recreation Center.

### Description of Scope:

Remove and Replace of existing furnace to be performed by Direct Install Contractor. New unit will be based on installation of same size furnaces with a minimum efficiency requirement of 93% per Direct Install guidelines.

### Energy Savings Calculations / Results:

Energy savings calculations are based on New Jersey Board of Public Utilities Protocols to Measure Resource Savings. The energy savings are calculated by using the Direct Install stipulated efficiency based on age and type of boiler and using the Protocols heating savings formula.

$$\text{Gas Savings} = \left( \frac{0.8 \times \text{CAPY}_{in} \times \text{HDD}_{MOD} \times 24}{\Delta T \times 100,000} \right) \times \left( 1 - \frac{\text{AFUE}_b}{\text{AFUE}_q} \right)$$

PHL = Philadelphia Weather Location

0.8 = Oversize Factor of standard boiler or furnace, equivalent to 25% of capacity

AFUE<sub>b</sub> = Annual Fuel Utilization Efficiency of the existing furnace

AFUE<sub>q</sub> = Annual Fuel Utilization Efficiency of the proposed furnace

CAPY<sub>in</sub> = Capacity of the furnace (Btu/h)

HDD<sub>MOD</sub> = Heating Degree Days Modified based on building type

ΔT = Design Temperature difference with balance temperature of 65 °F and outdoor temperature based on location.

<b>DIRECT INSTALL BOILER/FURNACE CALCULATION</b>	
<b>ECM INPUTS</b>	<b>RESULTS</b>
Location	PHL
Building Type	Public Assembly
Building Type Number	8
Manufacturer	Lennox
Unit Type	Furnace
Year Built	1992
Fuel Type	Gas
Input Capacity (Btu/hr)	100,000
Existing Efficiency (%)	90%
Proposed Efficiency (%)	93%
Fuel Conversion Factor	100,000
$\Delta T$	50
HDD <sub>mod</sub>	3042
Oversize Factor	0.8
Gas Savings (therms)	38
Fuel Cost (\$/Unit)	\$1.73
Cost Savings	\$65

## VI. Direct Install Program

The New Jersey Board of Public Utilities Clean Energy Program currently offers a Direct Install Program for customers whose buildings have a peak demand of less than 100 kilowatts. The program has enlisted specific contractors throughout the state of New Jersey who implement the program in assigned regions. Customers contact the appropriate contractor and a free energy assessment is performed to identify energy upgrades. Once the assessment is completed it provides the customer with a scope of work to be performed, energy savings, project costs, and incentives. The program provides incentives to customers to install energy upgrades by a 60/40 percentage of construction cost split, with 40% of the cost burden on the customer and 60% being covered by the program.

The Township has four buildings that qualify for the Direct Install Program being the Library, Recreation Center, Academy Hall, and Senior Center. The intent is to incorporate the Direct Install Program into the Energy Savings Improvement Program to assist the Township in paying the remaining 40% cost share. The local program provider Hutchinson Mechanical was contacted to provide the required documentation for the program and the scope of work that could be incentivized through the Direct Install Program. Based on the input from Hutchinson the following summarized scope of work can be partially funded through the Direct Install program and thus will be included in with the ESIP. (See **Appendix D** for detailed Direct Install Energy Assessment Reports):

- Library Building
  - ECM #10 - Boiler Replacement
  - ECM #13 - Fuel Economizer Controls
- Recreation Center
  - ECM #1A - Lighting Upgrade
  - ECM #20 – High Efficiency Split System
  - ECM #21 – Furnace Replacement
- Academy Hall
  - ECM #1A - Lighting Upgrade
  - ECM #5A - Split System Replacement
  - ECM #12 - Boiler Replacement
  - ECM #14 – Fuel Economizer
- Senior Center
  - ECM #8 – Split System Replacement
  - ECM #11 – Furnace Replacement
  - ECM #18 – Faucet Aerators
  - ECM #19 – Programmable Thermostats

The Direct Install scope of work will be performed by Hutchinson Mechanical based on program guidelines and is intended to begin once the Township gives final approval on the energy savings plan and secures the necessary funding. The remaining energy improvements not included in Direct Install scope of work will be separated out and publicly bid according to ESIP guidelines.



## **VII. Design and Compliance, Maintenance Impacts, and Risks**

### *Design and Compliance Issues:*

As part of the ESP development Concord Engineering has licensed professional engineers on staff to ensure that all design and compliance issues are encompassed in the Plan and that recommended measures will meet all applicable State of New Jersey Codes.

### *Maintenance Impacts:*

The installation of the recommended measures will provide the Township with a reduction in the amount of emergency maintenance required through the installation of new equipment, of which the cost savings were not accounted for due to the difficulty in calculating a specific annual cost benefit. The Township will be required to perform preventative maintenance on all equipment to ensure correction operation and to reach expected equipment life. Based on the recommendations it is foreseen that no additional maintenance will be required beyond their current practices.

### *Risks:*

The installation of the recommended measures will provide the Township with new equipment to replace existing equipment nearing and at the end of its useful life, therefore reducing the risk for a near term capital replacement project cost. The measures also present a minimal to no risk in affecting current facility comfort conditions, and will likely improve these conditions through better equipment performance.

## **VIII. PJM Demand Response & Curtailable Service Programs**

The regional transmission organization PJM oversees the electricity grid in all or parts of Delaware, Illinois, Indiana, Kentucky, Maryland, Michigan, New Jersey, North Carolina, Ohio, Pennsylvania, Tennessee, Virginia, West Virginia, and the District of Columbia. PJM currently offers various demand response programs to end users on the grid an opportunity to generate revenue through curtailing electric load in their facility from the grid. There are various levels of commitment that can be accepted by the end user to participate in the program. Three of the most common programs offered by PJM currently are the Emergency Load Response Program, Economic Load Response Program, and Synchronized Reserves Market. The Emergency Response Program allows end-users to receive financial incentives through agreeing to reduce a set amount of electricity consumption during system emergencies on the grid. The Economic Load Response Program allows end users to receive financial incentives for voluntarily reducing electricity consumption during times of high wholesale prices. The Synchronized Reserves Market allows end users to receive financial incentives for reducing electricity consumption on short notice in case of an unexpected emergency event. Each of these programs has stipulations in order participate such as number of events one must participate, amount of load to be curtailed, and response time.

The current Township electric loads and potential load shedding due to energy savings are not substantial enough to provide economic benefit to utilize the PJM programs.

## **IX. ESIP Cash Flow Summary**

Financing an Energy Savings Improvement Program is based on the principle that the cost of the improvements will be paid through the value of the reduced energy costs. Entities are able to finance these ESIP projects for a period not to exceed fifteen (15) years. The Board of Public Utilities has provided protocols in order to ensure with which to ensure these projects will cash flow within the project term. These protocols provide fixed values for energy cost escalation and discount rate, as well as methods for calculating the Participant Net Benefit, and Cost Benefit ratio. These guidelines are published in Board of Public Utilities Docket No. EO09020128 dated 2/24/2009. The proceeding Table 3 shows the Cash Flow Summary for the Township's Energy Savings Projects pursuant to the protocols guidelines.

The presented project cash flows provide a positive net cash flow annually over the life of the loan. Meaning after payment of all annual project expenses, the Township will be left with additional savings or "In Pocket" dollars annually over the life of ESIP.

*(Note: Interest rate subject to change once financing is finalized)*

<b>Project Name:</b>		<b>Gloucester Township Energy Savings Improvements</b>								
<b># of Measures Installed:</b>		20								
<b>Projects Costs</b>		-	<b>Incentives</b>		=	<b>Net Project Costs</b>				
\$609,641			\$103,477			\$506,164				
<b>Electric Savings</b>		+	<b>Natural Gas Savings</b>		=	<b>Net Utility Savings</b>				
\$48,927			\$6,693			\$55,620				
<b>Maintenance Savings or (Costs):</b>		\$0								
<b>Interest Rate:</b>		4.0%				<b>Percent Financed:</b>		100.0%		
<b>Electric Escalation Rate:</b>		2.2%				<b>Discount Rate:</b>		8.0%		
<b>Natural Gas Escalation Rate:</b>		2.4%								
Term Years	Additional Cash Outlay	Energy Savings	Maintenance Savings	Total Savings	Interest Expense	Loan Principal	Total Payments	Net Cash Flow	Cumulative Cash Flow	
0	\$ -						\$ -	\$ -		
1	\$ -	\$ 55,620	\$ -	\$ 55,620	\$ 20,246.56	\$ 25,278	\$ 45,525	\$ 10,095	\$ 10,095	
2	\$ -	\$ 56,857	\$ -	\$ 56,857	\$ 19,235.42	\$ 26,290	\$ 45,525	\$ 11,332	\$ 21,426	
3	\$ -	\$ 58,121	\$ -	\$ 58,121	\$ 18,183.84	\$ 27,341	\$ 45,525	\$ 12,596	\$ 34,022	
4	\$ -	\$ 59,414	\$ -	\$ 59,414	\$ 17,090.20	\$ 28,435	\$ 45,525	\$ 13,889	\$ 47,911	
5	\$ -	\$ 60,735	\$ -	\$ 60,735	\$ 15,952.81	\$ 29,572	\$ 45,525	\$ 15,210	\$ 63,121	
6	\$ -	\$ 62,086	\$ -	\$ 62,086	\$ 14,769.92	\$ 30,755	\$ 45,525	\$ 16,561	\$ 79,683	
7	\$ -	\$ 63,467	\$ -	\$ 63,467	\$ 13,539.72	\$ 31,985	\$ 45,525	\$ 17,942	\$ 97,625	
8	\$ -	\$ 64,879	\$ -	\$ 64,879	\$ 12,260.31	\$ 33,265	\$ 45,525	\$ 19,354	\$ 116,979	
9	\$ -	\$ 66,322	\$ -	\$ 66,322	\$ 10,929.73	\$ 34,595	\$ 45,525	\$ 20,797	\$ 137,776	
10	\$ -	\$ 67,797	\$ -	\$ 67,797	\$ 9,545.92	\$ 35,979	\$ 45,525	\$ 22,272	\$ 160,048	
11	\$ -	\$ 69,305	\$ -	\$ 69,305	\$ 8,106.76	\$ 37,418	\$ 45,525	\$ 23,780	\$ 183,828	
12	\$ -	\$ 70,847	\$ -	\$ 70,847	\$ 6,610.03	\$ 38,915	\$ 45,525	\$ 25,322	\$ 209,150	
13	\$ -	\$ 72,423	\$ -	\$ 72,423	\$ 5,053.43	\$ 40,472	\$ 45,525	\$ 26,898	\$ 236,048	
14	\$ -	\$ 74,034	\$ -	\$ 74,034	\$ 3,434.57	\$ 42,090	\$ 45,525	\$ 28,509	\$ 264,557	
15	\$ -	\$ 75,681	\$ -	\$ 75,681	\$ 1,750.96	\$ 43,774	\$ 45,525	\$ 30,156	\$ 294,714	
<b>Totals:</b>		\$ 977,588	\$ -	\$ 977,588	\$ 176,710	\$ 506,164	\$ 682,874	\$ 294,714		
<b>Net Present Value (NPV):</b>						\$139,871.44				
<b>Participant Net Benefit:</b>						\$167,872.92				
<b>Benefit-Cost Ratio:</b>						1.36				


## X. Greenhouse Gas Reductions

An additional goal beyond merely saving energy, is the reduction of greenhouse gas emissions. A reduction in these emissions is important as they have impact on the environment around us. The Carbon Emissions Reductions were calculated based on emissions factor data published by the New Jersey Department of Environmental Protection. These factors show equivalent pounds of Carbon Dioxide per unit of fuel usage based on system average air emissions for July 2003 to present. The following Tables show the emission factors and greenhouse gas emissions reductions for the conservation measures.

**Table 5: NJDEP Emissions Factors**

EMISSIONS FACTORS		
ENERGY TYPE	CONVERSION FACTOR	
Electricity	1.52	lbs CO <sub>2</sub> / kWh
Natural Gas	11.7	lbs CO <sub>2</sub> / therm

**Figure 1  
 Pre & Post Measure Emissions**



**Table 6**  
**Emission Reductions per Measure**  
**CO<sub>2</sub>/GREENHOUSE GAS REDUCTION**

ECM NO.	BUILDING	DESCRIPTION	Electric CO <sub>2</sub> , lbs	Natural Gas CO <sub>2</sub> , lbs	Total CO <sub>2</sub> Emissions, lbs
ECM #1	All Buildings	Lighting Upgrade	227,963.5	0.0	227,963.5
ECM #1A	Recreation, Academy Hall	DI - Lighting Upgrade	17,952.7	0.0	17,952.7
ECM #2	All Buildings	Lighting Controls	49,693.4	0.0	49,693.4
ECM #3	Library	5-Ton RTU Replacement	6,297.4	0.0	6,297.4
ECM #4	Recreation	REMOVED	0.0	0.0	0.0
ECM #5	Academy Hall	x3 1.5 Ton Split Units	3,564.4	0.0	3,564.4
ECM #5A	Academy Hall	DI - x1 3ton & x1 2 Ton Unit	3,438.2	0.0	3,438.2
ECM #6	Public Works	REMOVED	0.0	0.0	0.0
ECM #7	Municipal	x16 AC Unit Replacement	84,375.2	0.0	84,375.2
ECM #8	Senior	DI - Split Unit Replacements	12,289.2	0.0	12,289.2
ECM #9	Municipal	x2 1000 MBH Boilers	0.0	21,984.3	21,984.3
ECM #10	Library	DI - Boiler Replacement	0.0	7,640.1	7,640.1
ECM #11	Senior	DI - Furnace Replacement	0.0	6,598.8	6,598.8
ECM #12	Academy Hall	DI - Boiler Replacement	0.0	10,845.9	10,845.9
ECM #13	Library	DI - Fuel Economizer	0.0	2,386.8	2,386.8
ECM #14	Academy Hall	DI - Fuel Economizer	0.0	2,363.4	2,363.4
ECM #15	Library, Public Work, Municipal	CRT Monitor Replacement	2,714.7	0.0	2,714.7
ECM #16	Monroe Pool	Pool Pump Time Controls	10,234.2	0.0	10,234.2
ECM #17	Monroe Pool	REMOVED	0.0	0.0	0.0
ECM #18	Senior	DI - Faucet Aerators	0.0	1,310.4	1,310.4
ECM #19	Senior	DI - Programmable Thermostats	0.0	0.0	0.0
ECM #20	Recreation	DI - High Efficiency Split System	3,438.2	0.0	3,438.2
ECM #21	Recreation	DI - Furnace Replacement	0.0	444.6	444.6
<b>TOTAL</b>			<b>418,523</b>	<b>53,130</b>	<b>471,653</b>

## XI. Measurement & Verification

The primary purpose of Measurement and Verification (M&V) is to validate performance of energy efficiency upgrades and payments made towards these upgrades. M&V should not be used to derive a precise energy savings for every project, but to assess whether or not the properly installed projects are reasonable close to the projected savings. Careful consideration should be taken in selecting an M&V plan based on risk and cost benefit to the Township for the proposed projects. The U.S. Department of Energy has produced and published Measurement and Verification Guidelines for Federal Energy Projects. These guidelines have been used as a base reference for this report and a full copy of the U.S. DOE guidelines are available at [www.eere.energy.gov/femp](http://www.eere.energy.gov/femp).

The following Table outlines the four most common approaches for Measurement and Verification.

**Table 7: Measurement and Verification Approach**

<b>MEASUREMENT AND VERIFICATION APPROACH</b>		
<b>M&amp;V OPTION</b>	<b>PERFORMANCE &amp; USAGE FACTORS MEASUREMENTS</b>	<b>SAVINGS CALCULATION METHODOLOGY</b>
<b>Option A –</b> Retrofit Isolation with Key Parameter Measurement	This option is based on a combination of measured and estimated factors when variations in factors are not expected. Measurements are spot or short-term and are taken at the component or system level, both in the baseline and post-installation cases. Measurements should include the key performance parameter(s) which define the energy use of the ECM. Estimated factors are supported by historical or manufacturer’s data. Savings are determined by means of engineering calculations of baseline and post-installation energy use based on measured and estimated values.	Direct measurements and estimated values, engineering calculations and/or component or system models often developed through regression analysis Adjustments to models are not typically required.
<b>Option B –</b> Retrofit Isolation with All Parameter Measurement	This option is based on periodic or continuous measurements of energy use taken at the component or system level when variations in factors are expected. Energy or proxies of energy use are measured continuously. Periodic spot or short-term measurements may suffice when variations in factors are not expected. Savings are determined from analysis of baseline and reporting period energy use or proxies of energy use.	Direct measurements, engineering calculations, and/or component or system models often developed through regression analysis Adjustments to models may be required.

<p><b>Option C – Utility Data Analysis</b></p>	<p>This option is based on long-term, continuous, whole-building utility meter, facility level, or sub-meter energy (or water) data. Savings are determined from analysis of baseline and reporting period energy data. Typically, regression analysis is conducted to correlate with and adjust energy use to independent variables such as weather, but simple comparisons may also be used.</p>	<p>Based on regression analysis of utility meter data to account for factors that drive energy use Adjustments to models are typically required.</p>
<p><b>Option D – Calibrated Computer Simulation</b></p>	<p>Computer simulation software is used to model energy performance of a whole-facility (or sub-facility). Models must be calibrated with actual hourly or monthly billing data from the facility. Implementation of simulation modeling requires engineering expertise. Inputs to the model include facility characteristics; performance specifications of new and existing equipment or systems; engineering estimates, spot-, short-term, or long-term measurements of system components; and long-term whole-building utility meter data. After the model has been calibrated, savings are determined by comparing a simulation of the baseline with either a simulation of the performance period or actual utility data.</p>	<p>Based on computer simulation model (such as eQUEST or Trane Trace 700) calibrated with whole-building or end-use metered data or both. Adjustments to models are required.</p>

Each of the above approaches can be used for a wide array of energy efficiency upgrades, and each has different costs and complexities associated with it. When selecting an M&V approach the following general rules of thumb can be applied.

- **Option A - Retrofit Isolation with Key Parameter Measurement**
  - When magnitude of savings is low for the entire project or a portion of the project.
  - The risk for not achieving savings is low.
  
- **Option B - Retrofit Isolation with All Parameter Measurement**
  - For simple equipment replacement projects.
  - When energy savings values per individual measure are desired.
  - When interactive effects are to be ignored or are estimated using estimating methods that do not involve long term measurements.
  - When independent variables that affect energy use are not complex and excessively difficult or expensive to monitor.
  - When sub meters already existing that record the energy use of subsystems under consideration.



➤ **Option C - Utility Data Analysis**

- For complex equipment replacement and controls projects.
- When predicted energy savings are in excess of 10 to 20 percent as compared with the record energy use.
- When energy savings per individual measure are not desired.
- When interactive effects are to be included.
- When the independent variables that affect energy use are complex and excessively difficult or expensive to monitor.

➤ **Option D - Calibrated Computer Simulation**

- When new construction projects are involved.
- When energy savings values per measure are desired.
- When Option C tools cannot cost effectively evaluate particular measures or their interactions with the building.
- When complex baseline adjustments are anticipated.

Overall, Measurement and Verification is the key to realizing actual savings from the implementation of any energy conservation measure or renewable energy measure. Combined with a detailed construction management plan, the Owner will be able to benefit fully from the energy and cost savings associated with their commitment to saving energy and reducing greenhouse gases. The proceeding section provides recommended M&V option scopes of work that the commission should consider for each measure.

**Measurement & Verification Recommended Scopes of Work:**

*Scope 1: (Option A)*

Measurement and Verification of this ECM can be provided upon request. Pre and post watt measurements on a sample size of fixtures that will verify the reduction in energy consumption. Post implementation measurement and verification of occupancy sensor operation can be provided through the use of occupancy sensor data loggers to ensure lighting energy savings is achieved and proper operation of occupancy sensors is verified.

*Scope 2: (Option C)*

Measurement and verification of this ECM can be provided on a whole building energy conservation approach with respect to the heating and cooling systems in the building. The recommended M&V plan for this ECM is a comparison based on the annual facility energy use through monitoring of the utility bills. The baseline consists of the utilization of the historical energy usage for these facilities.

Post implementation measurement and verification is recommended through the use of the utility bill normalization and comparing to the baseline. Additionally, this can be achieved through the use of inputting utility data into Energy Star Portfolio Manager for pre and post installation periods to track changes in energy performance.

MEASUREMENT AND VERIFICATION PLAN					
ECM NO.	DESCRIPTION	OPTION A	OPTION B	OPTION C	OPTION D
ECM #1	Lighting Upgrade	X			
ECM #1A	DI - Lighting Upgrade	X			
ECM #2	Lighting Controls	X			
ECM #3	5-Ton RTU Replacement			X	
ECM #4	REMOVED			X	
ECM #5	x3 1.5 Ton Split Units			X	
ECM #5A	DI - x1 3ton & x1 2 Ton Unit			X	
ECM #6	REMOVED			X	
ECM #7	x16 AC Unit Replacement			X	
ECM #8	DI - Split Unit Replacements			X	
ECM #9	x2 1000 MBH Boilers			X	
ECM #10	DI - Boiler Replacement			X	
ECM #11	DI - Furnace Replacement			X	
ECM #12	DI - Boiler Replacement			X	
ECM #13	DI - Fuel Economizer			X	
ECM #14	DI - Fuel Economizer			X	
ECM #15	CRT Monitor Replacement	X			
ECM #16	Pool Pump Time Controls	X		X	
ECM #17	REMOVED				
ECM #18	DI - Faucet Aerators	X			
ECM #19	DI - Programmable Thermostats			X	
ECM #20	DI - High Efficiency Split System			X	
ECM #21	DI - Furnace Replacement			X	

**APPENDIX A**

PROPOSED ENERGY CONSERVATION MEASURES (ECM's)														
ECM NO.	BUILDING	DESCRIPTION	ANNUAL UTILITY REDUCTION			ANNUAL UTILITY COST SAVINGS			PJM REVENUE	MAINT. COST SAVINGS	PROJECT COST	REBATES, INCENTIVES	TOTAL PROJECT COST	SIMPLE PAYBACK (YRS)
			ELECTRIC DEMAND (KW)	ELECTRIC CONS. (KWH)	NATURAL GAS (THERMS)	ELECTRIC COST SAVINGS	NATURAL GAS COST SAVINGS	TOTAL COST SAVINGS						
<b>ECM #1</b>	<b>All Buildings</b>	<b>Lighting Upgrade</b>	<b>50.0</b>	<b>149,976</b>	<b>0</b>	<b>\$26,419</b>	<b>\$0</b>	<b>\$26,419</b>	<b>\$0</b>	<b>\$0</b>	<b>\$57,942</b>	<b>\$5,240</b>	<b>\$52,702</b>	<b>2.0</b>
	Library		2.6	9,106	0	\$1,648	\$0	\$1,648	\$0	\$0	\$5,349	\$708	\$4,641	2.8
	Recreation		24.1	57,825	0	\$10,466	\$0	\$10,466	\$0	\$0	\$13,170	\$0	\$13,170	1.3
	Senior		0.4	333	0	\$79	\$0	\$79	\$0	\$0	\$860	\$367	\$493	6.2
	Academy Hall		0.8	174	0	\$31	\$0	\$31	\$0	\$0	\$300	\$0	\$300	9.7
	Municipal		13.1	46,324	0	\$7,643	\$0	\$7,643	\$0	\$0	\$21,259	\$1,154	\$20,105	2.6
	Public Works		8.4	34,897	0	\$6,281	\$0	\$6,281	\$0	\$0	\$16,376	\$2,850	\$13,526	2.2
	Monroe Pool		0.6	1,317	0	\$270	\$0	\$270	\$0	\$0	\$628	\$161	\$467	1.7
<b>ECM #1A</b>	<b>Recreation, Academy Hall</b>	<b>DI - Lighting Upgrade</b>	<b>6.1</b>	<b>11,811</b>	<b>0</b>	<b>\$2,126</b>	<b>\$0</b>	<b>\$2,126</b>	<b>\$0</b>	<b>\$0</b>	<b>\$36,004</b>	<b>\$21,602</b>	<b>\$14,402</b>	<b>6.8</b>
	<del>Library</del>													
	Recreation		2.8	7,853	0	\$1,421	\$0	\$1,421	\$0	\$0	\$11,431	\$6,859	\$4,572	3.2
	<del>Senior</del>													
	Academy Hall		3.4	3,958	0	\$705	\$0	\$705	\$0	\$0	\$24,573	\$14,744	\$9,829	14.0
	<del>Municipal</del>													
	<del>Public Works</del>													
	<del>Monroe Pool</del>													
<b>ECM #2</b>	<b>All Buildings</b>	<b>Lighting Controls</b>	<b>11.7</b>	<b>32,693</b>	<b>0</b>	<b>\$5,635</b>	<b>\$0</b>	<b>\$5,635</b>	<b>\$0</b>	<b>\$0</b>	<b>\$15,235</b>	<b>\$0</b>	<b>\$15,235</b>	<b>2.7</b>
	Library		0.3	991	0	\$179	\$0	\$179	\$0	\$0	\$304	\$0	\$304	1.7
	Recreation		2.6	6,226	0	\$1,127	\$0	\$1,127	\$0	\$0	\$4,057	\$200	\$3,857	3.4
	<del>Senior</del>													
	Academy Hall		0.8	768	0	\$137	\$0	\$137	\$0	\$0	\$1,215	\$240	\$975	7.1
	Municipal		5.9	17,065	0	\$2,816	\$0	\$2,816	\$0	\$0	\$7,310	\$1,145	\$6,165	2.2
	Public Works		2.2	7,643		\$1,376	\$0	\$1,376	\$0	\$0	\$2,349	\$395	\$1,954	1.4
	<del>Monroe Pool</del>													

PROPOSED ENERGY CONSERVATION MEASURES (ECM's)														
ECM NO.	BUILDING	DESCRIPTION	ANNUAL UTILITY REDUCTION			ANNUAL UTILITY COST SAVINGS			PJM REVENUE	MAINT. COST SAVINGS	PROJECT COST	REBATES, INCENTIVES	TOTAL PROJECT COST	SIMPLE PAYBACK (YRS)
			ELECTRIC DEMAND (KW)	ELECTRIC CONS. (KWH)	NATURAL GAS (THERMS)	ELECTRIC COST SAVINGS	NATURAL GAS COST SAVINGS	TOTAL COST SAVINGS						
ECM #3	Library	5-Ton RTU Replacement	2.1	4,143	0	\$750	\$0	\$750			\$14,800	\$368	\$14,432	19.2
ECM #4	Recreation	REMOVED											\$0	
ECM #5	Academy Hall	x3 1.5 Ton Split Units	1.4	2,345	0	\$417	\$0	\$417			\$15,123	\$414	\$14,709	35.2
ECM #5A	Academy Hall	DI - x1 3ton & x1 2 Ton Unit	1.3	2262	0	\$403	0	\$403	\$0	\$0	\$12,627	\$7,576	\$5,051	12.5
ECM #6	Public Works	REMOVED						\$0					\$0	
ECM #7	Municipal	x16 AC Unit Replacement	18.6	55,510	0	\$9,159	\$0	\$9,159			\$262,348	\$5,730	\$256,618	28.0
ECM #8	Senior	DI - Split Unit Replacements	4.8	8,085	0	\$1,916	\$0	\$1,916	\$0	\$0	\$24,414	\$14,648	\$9,766	5.1
ECM #9	Municipal	x2 1000 MBH Boilers	0.0	0	1,879	\$0	\$3,194	\$3,194	\$0	\$0	\$91,540	\$3,500	\$88,040	27.6
ECM #10	Library	DI - Boiler Replacement	0.0	0	653	\$0	\$842	\$842	\$0	\$0	\$20,483	\$12,290	\$8,193	9.7
ECM #11	Senior	DI - Furnace Replacement	0.0	0	564	\$0	\$727	\$727	\$0	\$0	\$12,392	\$7,435	\$4,957	6.8
ECM #12	Academy Hall	DI - Boiler Replacement	0.0	0	927	\$0	\$1,196	\$1,196	\$0	\$0	\$24,399	\$14,640	\$9,760	8.2
ECM #13	Library	DI - Fuel Economizer	0.0	0	204	\$0	\$263	\$263	\$0	\$0	\$425	\$255	\$170	0.6
ECM #14	Academy Hall	DI - Fuel Economizer	0.0	0	202	\$0	\$260	\$260	\$0	\$0	\$1,861	\$1,117	\$744	2.9
ECM #15	Library, Public Work, Municipal	CRT Monitor Replacement	0.0	1,786	0	\$313	\$0	\$313	\$0	\$0	\$2,100	\$0	\$2,100	6.7
	Library		0.0	1,020	0	\$185	\$0	\$185	\$0	\$0	\$1,200	\$0	\$1,200	6.5
	<del>Recreation</del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>
	<del>Senior</del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>
	<del>Academy Hall</del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>
	Public Works		0.0	128	0	\$23	\$0	\$23	\$0	\$0	\$150	\$0	\$150	6.5
	<del>Monroe Pool</del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>	<del></del>
	Municipal		0.0	638	0	\$105	\$0	\$105	\$0	\$0	\$750	\$0	\$750	7.1
ECM #16	Monroe Pool	Pool Pump Time Controls	0.0	6,733	0	\$1,380	\$0	\$1,380	\$0	\$0	\$3,511	\$0	\$3,511	2.5
ECM #17	Monroe Pool	REMOVED						\$0					\$0	
ECM #18	Senior	DI - Faucet Aerators	0.0	0	112	\$0	\$145	\$145	\$0	\$0	\$197	\$118	\$79	0.5
ECM #19	Senior	DI - Programmable Thermostats						\$0	\$0	\$0	\$668	\$401	\$267	
ECM #20	Recreation	DI - High Efficiency Split System	1.3	2,262	0	\$409	\$0	\$409	\$0	\$0	\$8,138	\$4,883	\$3,255	8.0
ECM #21	Recreation	DI - Furnace Replacement	0.0	0	38	\$0	\$65	\$65	\$0	\$0	\$5,434	\$3,261	\$2,174	33.4
<b>TOTAL</b>		<b>TOTAL</b>	<b>97.4</b>	<b>277,606</b>	<b>4,579</b>	<b>\$48,927</b>	<b>\$6,693</b>	<b>\$55,620</b>			<b>\$609,641</b>	<b>\$103,477</b>	<b>\$506,164</b>	<b>9.1</b>

**APPENDIX B**

**ELECTRIC USAGE SUMMARY**

Utility Provider: PSE&G  
 Rate: GLP  
 Meter No: 226014030  
 Account # 65 041 660 05  
 Third Party Utility N/A  
 TPS Meter / Acct No: N/A

<b>MONTH OF USE</b>	<b>CONSUMPTION KWH</b>	<b>DEMAND KW</b>	<b>TOTAL BILL</b>
Jun-10	6,756	18.2	\$1,203
Jul-10	6,786	19.1	\$1,240
Aug-10	5,958	19.6	\$1,137
Sep-10	5,454	18.8	\$1,092
Oct-10	3,576	12.6	\$585
Nov-10	3,678	14.8	\$600
Dec-10	3,828	12.1	\$607
Jan-11	3,036	10.6	\$514
Feb-11	3,348	10.9	\$580
Mar-11	2,832	8.6	\$505
Apr-11	3,300	13.9	\$572
Jun-11	4,958	0.0	\$888
<b>Totals</b>	<b>53,510</b>	<b>19.6 Max</b>	<b>\$9,521</b>

**AVERAGE DEMAND**      **13.3 KW average**  
**AVERAGE RATE**      **\$0.178 \$/kWh**

Academy Hall

**NATURAL GAS USAGE SUMMARY**

Utility Provider: South Jersey Gas  
 Rate: General Service Gas  
 Meter No: 486378  
 Point of Delivery ID: 2 06 30 3000 0 0  
 Third Party Utility Provider: N/A  
 TPS Meter No: N/A

<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
May-10	17.48	\$42.01
Jun-10	16.50	\$41.35
Jul-10	15.39	\$38.06
Aug-10	17.41	\$44.46
Sep-10	46.17	\$78.28
Oct-10	201.93	\$264.80
Nov-10	648.97	\$804.13
Dec-10	705.54	\$868.69
Jan-11	546.28	\$676.39
Feb-11	385.13	\$486.58
Mar-11	204.37	\$268.54
Apr-11	66.76	\$102.16
<b>TOTALS</b>	<b>2,871.93</b>	<b>\$3,715.45</b>
<b>AVERAGE RATE:</b>	<b>\$1.29</b>	<b>\$/THERM</b>



**ELECTRIC USAGE SUMMARY**

Utility Provider: ACE  
 Rate: MGS  
 Meter No: 83431432  
 Account # 0388 9889 9976  
 Third Party Utility  
 TPS Meter / Acct No:

MONTH OF USE	CONSUMPTION KWH	DEMAND KW	TOTAL BILL
Jul-10	18,120	59.2	\$3,700
Aug-10	16,040	59.2	\$3,276
Sep-10	16,720	59.2	\$3,418
Oct-10	14,560	0.0	\$841
Nov-10	22,440	66.4	\$1,133
Dec-10	33,440	63.6	\$1,606
Jan-11	27,640	63.6	\$1,590
Feb-11	20,800	66.0	\$1,283
Mar-11	24,080	65.2	\$1,458
Apr-11	22,960	63.6	\$1,388
May-11	11,720	48.0	\$766
Jun-11	14,840	52.4	\$1,029
<b>Totals</b>	<b>243,360</b>	<b>66.4 Max</b>	<b>\$21,487</b>

**AVERAGE DEMAND      55.5 KW average**  
**AVERAGE RATE      \$0.088 \$/kWh**

**NATURAL GAS USAGE SUMMARY**

Utility Provider: South Jersey Gas  
 Rate: Firm Transportation  
 Meter No: 0536110  
 Point of Delivery ID: 2 05 37 2930 1 9  
 Third Party Utility Provider: Woodruff Energy  
 TPS Meter No: N/A

<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
May-10	214.85	\$372.38
Jun-10	177.33	\$312.51
Jul-10	208.28	\$360.96
Aug-10	155.65	\$281.35
Sep-10	175.45	\$320.90
Oct-10	82.00	\$161.47
Nov-10	1,295.90	\$2,228.34
Dec-10	1,631.23	\$2,793.80
Jan-11	1,379.00	\$2,363.91
Feb-11	975.65	\$1,679.76
Mar-11	601.82	\$1,038.26
Jan-00	0.00	\$0.00
<b>TOTALS</b>	<b>6,897.16</b>	<b>\$11,913.64</b>
<b>AVERAGE RATE:</b>	<b>\$1.73</b>	<b>\$/THERM</b>

LIBRARY

<b>ELECTRIC USAGE SUMMARY</b>			
Utility Provider: PSE&G			
Rate: GLP			
Meter No: 278005298			
Account # 66 134 995 01			
Third Party Utility N/A			
TPS Meter / Acct No: N/A			
<b>MONTH OF USE</b>	<b>CONSUMPTION KWH</b>	<b>DEMAND KW</b>	<b>TOTAL BILL</b>
Jun-10	14,730	46.2	\$2,768
Jul-10	13,395	48.0	\$2,665
Aug-10	15,795	49.8	\$3,010
Sep-10	12,300	51.6	\$2,643
Oct-10	9,285	42.5	\$1,587
Nov-10	9,345	43.8	\$1,583
Dec-10	7,605	21.3	\$1,288
Jan-11	8,925	24.6	\$1,463
Feb-11	9,570	34.5	\$1,660
Mar-11	9,450	37.8	\$1,654
Apr-11	10,935	37.8	\$1,794
May-11	10,905	36.3	\$1,758
<b>Totals</b>	<b>132,240</b>	<b>51.6 Max</b>	<b>\$23,871</b>
<b>AVERAGE DEMAND</b>		<b>39.5 KW average</b>	
<b>AVERAGE RATE</b>		<b>\$0.181 \$/kWh</b>	

LIBRARY

**NATURAL GAS USAGE SUMMARY**

Utility Provider: South Jersey Gas  
 Rate: General Service Gas  
 Meter No: 0199120  
 Point of Delivery ID: 2 06 30 3002 0 8  
 Third Party Utility Provider: N/A  
 TPS Meter No: N/A

<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
May-10	11.31	\$34.01
Jun-10	11.34	\$34.66
Jul-10	10.26	\$31.41
Aug-10	12.29	\$37.98
Sep-10	10.26	\$35.29
Oct-10	154.78	\$208.36
Nov-10	867.68	\$1,066.02
Dec-10	951.30	\$1,162.99
Jan-11	413.88	\$517.83
Feb-11	200.27	\$265.22
Mar-11	108.86	\$154.16
Apr-11	264.70	\$339.20
<b>TOTALS</b>	<b>3,016.93</b>	<b>\$3,887.13</b>

**AVERAGE RATE:                      \$1.29                      \$/THERM**

Monroe Pool

<b>ELECTRIC USAGE SUMMARY</b>			
Utility Provider: PSE&G Rate: LPLS Meter No: 778005122 Account # 42 009 606 05 Third Party Utility N/A TPS Meter / Acct No: N/A			
<b>MONTH OF USE</b>	<b>CONSUMPTION KWH</b>	<b>DEMAND KW</b>	<b>TOTAL BILL</b>
Jun-10	3,756	14.0	\$745
Jul-10	8,262	14.5	\$1,369
Aug-10	7,554	14.6	\$1,277
Sep-10	4,902	14.8	\$934
Oct-10	390	2.0	\$150
Nov-10	438	4.4	\$164
Dec-10	486	1.7	\$159
Jan-11	552	2.0	\$169
Feb-11	0	2.0	\$105
Mar-11	0	2.0	\$107
Apr-11	0	2.0	\$107
May-11	0	2.0	\$107
<b>Totals</b>	<b>26,340</b>	<b>14.8 Max</b>	<b>\$5,393</b>
<b>AVERAGE DEMAND</b>		<b>6.3 KW average</b>	
<b>AVERAGE RATE</b>		<b>\$0.205 \$/kWh</b>	

Monroe Pool

**NATURAL GAS USAGE SUMMARY**

Utility Provider: South Jersey Gas  
 Rate: General Service Gas  
 Meter No: 0469133  
 Point of Delivery ID: 2 05 31 2550 1 4  
 Third Party Utility Provider: N/A  
 TPS Meter No: N/A

<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
May-10	2.06	\$21.39
Jun-10	6.19	\$28.61
Jul-10	5.13	\$24.13
Aug-10	5.12	\$26.15
Sep-10	7.18	\$33.98
Oct-10	5.13	\$28.36
Nov-10	5.11	\$30.73
Dec-10	0.00	\$26.19
Jan-11	0.00	\$23.01
Feb-11	0.00	\$22.22
Mar-11	0.00	\$26.19
Apr-11	1.03	\$24.23
<b>TOTALS</b>	<b>36.95</b>	<b>\$315.19</b>

**AVERAGE RATE:                    \$8.53                    \$/THERM**

Municipal Building

<b>ELECTRIC USAGE SUMMARY</b>			
Utility Provider: PSE&G			
Rate: LPLS			
Meter No: 778005122			
Account # 42 009 606 05			
Third Party Utility N/A			
TPS Meter / Acct No: N/A			
<b>MONTH OF USE</b>	<b>CONSUMPTION KWH</b>	<b>DEMAND KW</b>	<b>TOTAL BILL</b>
Jun-10	58,600	176.0	\$10,708
Jul-10	70,400	198.0	\$12,601
Aug-10	62,200	190.0	\$11,622
Sep-10	59,000	0.0	\$3,884
Oct-10	49,400	148.0	\$2,204
Nov-10	43,400	128.0	\$2,040
Jan-11	59,000	0.0	\$2,625
Jan-11	33,200	0.0	\$1,417
Feb-11	48,800	0.0	\$1,995
Mar-11	40,200	0.0	\$1,644
Apr-11	46,667	0.0	\$2,173
May-11	40,931	0.0	\$1,906
<b>Totals</b>	<b>611,798</b>	<b>198.0 Max</b>	<b>\$54,818</b>
<b>AVERAGE DEMAND</b>		<b>70.0 KW average</b>	
<b>AVERAGE RATE</b>		<b>\$0.090 \$/kWh</b>	

Municipal Building

**NATURAL GAS USAGE SUMMARY**

Utility Provider: South Jersey Gas  
 Rate: Firm Transportation  
 Meter No: 0372100  
 Point of Delivery ID: 2 05 34 2750 0 1  
 Third Party Utility Provider: N/A  
 TPS Meter No: N/A

<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
Jun-10	36.09	\$80.03
Jul-10	32.83	\$71.54
Aug-10	38.91	\$83.41
Sep-10	35.91	\$80.10
Oct-10	44.08	\$99.46
Nov-10	715.10	\$1,235.94
Dec-10	2,551.46	\$4,189.81
Jan-11	2,413.26	\$4,120.97
Feb-11	1,785.95	\$3,054.95
Mar-11	1,474.77	\$2,505.51
Apr-11	472.42	\$817.48
May-11	48.60	\$106.32
<b>TOTALS</b>	<b>9,649.38</b>	<b>\$16,445.52</b>
<b>AVERAGE RATE:</b>	<b>\$1.70</b>	<b>\$/THERM</b>



Senior Center

**ELECTRIC USAGE SUMMARY**

Utility Provider: PSE&G

Rate: GLP

Meter No: 626 007 783

Account # 66 637 421 08

Third Party Utility

TPS Meter / Acct No:

MONTH OF USE	CONSUMPTION KWH	DEMAND KW	TOTAL BILL
Jul-10	4,254	20.3	\$926
Aug-10	4,338	20.0	\$934
Sep-10	2,976	19.4	\$745
Oct-10	1,470	17.8	\$369
Nov-10	1,092	18.5	\$322
Dec-10	1,374	8.0	\$312
Jan-11	1,464	8.0	\$327
Feb-11	1,338	7.7	\$323
Mar-11	1,176	11.2	\$320
Apr-11	1,344	17.0	\$360
May-11	1,476	18.9	\$380
Jun-11	3,678	20.8	\$846
<b>Totals</b>	<b>25,980</b>	<b>20.8 Max</b>	<b>\$6,164</b>

**AVERAGE DEMAND      15.6 KW average**

**AVERAGE RATE      \$0.237 \$/kWh**

**NATURAL GAS USAGE SUMMARY**

Utility Provider: South Jersey Gas

Rate: General Service Gas

Meter No: 0147770

Point of Delivery ID: 2 05 34 3489 0 7

Third Party Utility Provider:

TPS Meter No:

<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
Jun-10	19.59	\$45.99
Jul-10	13.34	\$34.77
Aug-10	15.36	\$39.28
Sep-10	18.47	\$42.97
Oct-10	70.73	\$109.26
Nov-10	364.90	\$452.48
Dec-10	835.58	\$1,027.61
Jan-11	799.00	\$1,001.82
Feb-11	471.39	\$586.69
Mar-11	464.20	\$581.27
Apr-11	112.97	\$158.28
May-11	26.88	\$56.79
<b>TOTALS</b>	<b>3,212.41</b>	<b>\$4,137.21</b>
<b>AVERAGE RATE:</b>	<b>\$1.29</b>	<b>\$/THERM</b>

Recreation

<b>ELECTRIC USAGE SUMMARY</b>			
Utility Provider: ACE			
Rate: Annual General Service			
Meter No: 57131792 / 11892066			
Account # 1143 3009 9994			
Third Party Utility N/A			
TPS Meter / Acct No: N/A			
<b>MONTH OF USE</b>	<b>CONSUMPTION KWH</b>	<b>DEMAND KW</b>	<b>TOTAL BILL</b>
Jul-10	42,740	139.8	\$7,544
Aug-10	41,700	140.6	\$7,569
Sep-10	30,040	140.6	\$5,537
Oct-10	18,740	140.6	\$3,459
Nov-10	18,420	140.6	\$3,588
Dec-10	20,300	65.4	\$3,580
Jan-11	19,360	64.4	\$3,438
Feb-11	18,000	65.4	\$3,431
Apr-11	15,900	65.4	\$3,056
Apr-11	15,180	99.2	\$2,996
May-11	23,380	139.8	\$4,311
Jun-11	37,240	162.4	\$5,842
<b>Totals</b>	<b>301,000</b>	<b>162.4 Max</b>	<b>\$54,352</b>
<b>AVERAGE DEMAND</b>		<b>113.7 KW average</b>	
<b>AVERAGE RATE</b>		<b>\$0.181 \$/kWh</b>	

Recreation

**NATURAL GAS USAGE SUMMARY**

Utility Provider: South Jersey Gas  
 Rate: Firm Transportation  
 Meter No: 0325952  
 Point of Delivery ID: 2 05 39 5601 0 0  
 Third Party Utility Provider: Woodruff Energy  
 TPS Meter No:

<b>MONTH OF USE</b>	<b>CONSUMPTION (THERMS)</b>	<b>TOTAL BILL</b>
Jun-10	0.00	\$0.00
Jul-10	1.03	\$39.92
Aug-10	24.58	\$61.06
Sep-10	8.21	\$34.50
Oct-10	138.38	\$257.95
Nov-10	632.62	\$1,098.05
Dec-10	2,069.50	\$3,541.21
Jan-11	2,026.56	\$3,463.52
Feb-11	1,318.67	\$2,262.23
Mar-11	540.20	\$933.06
Apr-11	392.31	\$683.56
May-11	11.37	\$45.32
<b>TOTALS</b>	<b>7,163.43</b>	<b>\$12,420.38</b>
<b>AVERAGE RATE:</b>	<b>\$1.73</b>	<b>\$/THERM</b>

**APPENDIX C**

## Investment Grade Lighting Audit

CEG Job #: 1C11039

Project: Academy Hall

Academy Hall

KWH COST: \$0.178

27 S. Black Horse Pike

Gloucester Township, NJ

Bldg. Sq. Ft. 5,376

### ECM: Lighting Upgrade - General

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS				In DI Scope (D)
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback	
D127.21	Front Office/ Reception	1040	14	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	1.09	1,135.7	\$202.15	14	3	T8 Lamps w/Electronic Ballast	47	0.66	684.32	\$121.81	\$277.42	\$166.45	\$1,553.55	0.43	451.36	\$80.34	19.34	D
3015	Rest Room	156	1	2	Wall Mnt., Glass Cover, 100w A Lamp	100	0.10	15.6	\$2.78	1	1	26w CFL Lamp	26	0.03	4.056	\$0.72	\$20.00	\$0.00	\$20.00	0.07	11.544	\$2.05	9.73	D
D127.21	Det. Sergeant Office	1040	4	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.31	324.5	\$57.76	4	3	T8 Lamps w/Electronic Ballast	47	0.19	195.52	\$34.80	\$277.42	\$166.45	\$443.87	0.12	128.96	\$22.95	19.34	D
D127.21	Hall	3000	4	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.31	936.0	\$166.61	4	3	T8 Lamps w/Electronic Ballast	47	0.19	564	\$100.39	\$277.42	\$166.45	\$443.87	0.12	372	\$66.22	6.70	D
D127.21	Small Office - 1st Floor	1040	3	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.23	243.4	\$43.32	3	3	T8 Lamps w/Electronic Ballast	47	0.14	146.64	\$26.10	\$277.42	\$166.45	\$332.90	0.09	96.72	\$17.22	19.34	D
D127.21	Storage Room	156	3	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.23	36.5	\$6.50	3	3	T8 Lamps w/Electronic Ballast	47	0.14	21.996	\$3.92	\$277.42	\$166.45	\$332.90	0.09	14.508	\$2.58	128.91	D
D127.21	Lunch Room	1040	10	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.78	811.2	\$144.39	10	3	T8 Lamps w/Electronic Ballast	47	0.47	488.8	\$87.01	\$277.42	\$166.45	\$1,109.68	0.31	322.4	\$57.39	19.34	D
D613	Men's Rest Room	156	1	1	Socket , 100w A19 Lamp	100	0.10	15.6	\$2.78	1	1	(1) 13W CFL Screw In	13	0.01	2.028	\$0.36	\$32.43	\$19.46	\$12.97	0.09	13.572	\$2.42	5.37	D
D613	Women's Rest Room	156	1	1	Socket , 100w A19 Lamp	100	0.10	15.6	\$2.78	1	1	(1) 13W CFL Screw In	13	0.01	2.028	\$0.36	\$32.43	\$19.46	\$12.97	0.09	13.572	\$2.42	5.37	D
D127.21	Hall	3000	2	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.16	468.0	\$83.30	2	3	T8 Lamps w/Electronic Ballast	47	0.09	282	\$50.20	\$277.42	\$166.45	\$221.94	0.06	186	\$33.11	6.70	D
D127.21	Large Office - 1st Floor	1040	6	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.47	486.7	\$86.64	6	3	T8 Lamps w/Electronic Ballast	47	0.28	293.28	\$52.20	\$277.42	\$166.45	\$665.81	0.19	193.44	\$34.43	19.34	D
D127.21	Stairway	3000	2	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.16	468.0	\$83.30	2	3	T8 Lamps w/Electronic Ballast	47	0.09	282	\$50.20	\$277.42	\$166.45	\$221.94	0.06	186	\$33.11	6.70	D
D127.21	Office - 2nd Floor	1040	9	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.70	730.1	\$129.95	9	3	T8 Lamps w/Electronic Ballast	47	0.42	439.92	\$78.31	\$277.42	\$166.45	\$998.71	0.28	290.16	\$51.65	19.34	D
D127.21	Office - 2nd Floor	1040	4	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.31	324.5	\$57.76	4	3	T8 Lamps w/Electronic Ballast	47	0.19	195.52	\$34.80	\$277.42	\$166.45	\$443.87	0.12	128.96	\$22.95	19.34	D
D127.21	Office - 2nd Floor	1040	5	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.39	405.6	\$72.20	5	3	T8 Lamps w/Electronic Ballast	47	0.24	244.4	\$43.50	\$277.42	\$166.45	\$554.84	0.16	161.2	\$28.69	19.34	D
D127.21	2nd Floor Hall	3000	5	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.39	1,170.0	\$208.26	5	3	T8 Lamps w/Electronic Ballast	47	0.24	705	\$125.49	\$277.42	\$166.45	\$554.84	0.16	465	\$82.77	6.70	D
D127.21	Break Room - 2nd Floor	1040	6	2	2x2, 2 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.47	486.7	\$86.64	6	3	T8 Lamps w/Electronic Ballast	47	0.28	293.28	\$52.20	\$277.42	\$166.45	\$665.81	0.19	193.44	\$34.43	19.34	D
D121.11	Rest Room	156	1	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	78	0.08	12.2	\$2.17	1	2	4' T8 Lamps w/Electronic Ballast	50	0.05	7.8	\$1.39	\$68.70	\$41.22	\$27.48	0.03	4.368	\$0.78	35.34	D
D613	Closet	156	1	1	Socket , 100w A19 Lamp	100	0.10	15.6	\$2.78	1	1	(1) 13W CFL Screw In	13	0.01	2.028	\$0.36	\$32.43	\$19.46	\$12.97	0.09	13.572	\$2.42	5.37	D
D613	Stairway	3000	1	1	Socket , 100w A19 Lamp	100	0.10	300.0	\$53.40	1	1	(1) 13W CFL Screw In	13	0.01	39	\$6.94	\$32.43	\$19.46	\$12.97	0.09	261	\$46.46	0.28	D
D121.11	Office - 3rd Floor	1040	2	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	78	0.16	162.2	\$28.88	2	2	4' T8 Lamps w/Electronic Ballast	50	0.10	104	\$18.51	\$68.70	\$41.22	\$54.96	0.06	58.24	\$10.37	5.30	D

## Investment Grade Lighting Audit

EXISTING LIGHTING					PROPOSED LIGHTING												SAVINGS							
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback	In DI Scope (D)
D613	Mech. Room - 3rd Floor	156	1	1	Socket , 100w A19 Lamp	100	0.10	15.6	\$2.78	1	1	(1) 13W CFL Screw In	13	0.01	2.028	\$0.36	\$32.43	\$19.46	\$12.97	0.09	13.572	\$2.42	5.37	D
D121.11	Com Room - 3rd Floor	1040	1	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	78	0.08	81.1	\$14.44	1	2	4' T8 Lamps w/Electronic Ballast	50	0.05	52	\$9.26	\$68.70	\$41.22	\$27.48	0.03	29.12	\$5.18	5.30	D
D121.11	Center Office - 3rd Floor	1040	2	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	78	0.16	162.2	\$28.88	2	2	4' T8 Lamps w/Electronic Ballast	50	0.10	104	\$18.51	\$68.70	\$41.22	\$54.96	0.06	58.24	\$10.37	5.30	D
D121.11	Left Office - 3rd Floor	1040	3	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	78	0.23	243.4	\$43.32	3	2	4' T8 Lamps w/Electronic Ballast	50	0.15	156	\$27.77	\$68.70	\$41.22	\$82.44	0.08	87.36	\$15.55	5.30	D
D121.11	Office - 3rd Floor	1040	7	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	78	0.55	567.8	\$101.08	7	2	4' T8 Lamps w/Electronic Ballast	50	0.35	364	\$64.79	\$68.70	\$41.22	\$192.36	0.20	203.84	\$36.28	5.30	D
613	Basement	156	15	1	Socket , 100w A19 Lamp	100	1.50	234.0	\$41.65	15	1	(1) 26w CFL Lamp	26	0.39	60.84	\$10.83	\$20.00	\$0.00	\$300.00	1.11	173.16	\$30.82	9.73	
650	Exterior	4400	10	1	Wall Mnt. Light, 18w CFL Lamp	18	0.18	792.0	\$140.98	10	0	No Change	18	0.18	792	\$140.98	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
<b>Totals</b>			124	49			9.53	10,660	\$1,897	124	61			5.1	6,528	\$1,162			\$9,369	4.5	4,131	\$735	12.74	

CEG Job #: 1C11039  
 Project: Academy Hall  
 Address: 27 S. Black Horse Pike  
 Gloucester Township, NJ  
 Building SF: 5,376

Academy Hall

KWH COST: \$0.178

ECM: Lighting Controls

EXISTING LIGHTING								PROPOSED LIGHTING CONTROLS											SAVINGS						
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback		
D127.21	Front Office/ Reception	1040	14	2	T8 Lamps w/Electronic Ballast	47	0.66	684.32	\$121.81	14	0	No Change	47	0.66	0%	684.32	\$121.81	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
3015	Rest Room	156	1	2	26w CFL Lamp	26	0.03	4.056	\$2.78	1	0	No Change	26	0.03	0%	4.056	\$0.72	\$0.00	\$0.00	0.00	0	\$2.05	0.00		
D127.21	Det. Sergeant Office	1040	4	2	T8 Lamps w/Electronic Ballast	47	0.19	195.52	\$57.76	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	47	0.13	30%	136.864	\$24.36	\$75.00	\$75.00	0.06	58.656	\$33.40	2.25		
D127.21	Hall	3000	4	2	T8 Lamps w/Electronic Ballast	47	0.19	564	\$166.61	4	0	No Change	47	0.19	0%	564	\$100.39	\$0.00	\$0.00	0.00	0	\$66.22	0.00		
D127.21	Small Office - 1st Floor	1040	3	2	T8 Lamps w/Electronic Ballast	47	0.14	146.64	\$43.32	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	47	0.10	30%	102.648	\$18.27	\$75.00	\$75.00	0.04	43.992	\$25.05	2.99		
D127.21	Storage Room	156	3	2	T8 Lamps w/Electronic Ballast	47	0.14	21.996	\$6.50	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	47	0.09	35%	14.2974	\$2.54	\$75.00	\$75.00	0.05	7.6986	\$3.95	18.97		
D127.21	Lunch Room	1040	10	2	T8 Lamps w/Electronic Ballast	47	0.47	488.8	\$144.39	10	0	No Change	47	0.47	0%	488.8	\$87.01	\$0.00	\$0.00	0.00	0	\$57.39	0.00		
D613	Men's Rest Room	156	1	1	(1) 13W CFL Screw In	13	0.01	2.028	\$2.78	1	0	No Change	13	0.01	0%	2.028	\$0.36	\$0.00	\$0.00	0.00	0	\$2.42	0.00		
D613	Women's Rest Room	156	1	1	(1) 13W CFL Screw In	13	0.01	2.028	\$2.78	1	0	No Change	13	0.01	0%	2.028	\$0.36	\$0.00	\$0.00	0.00	0	\$2.42	0.00		
D127.21	Hall	3000	2	2	T8 Lamps w/Electronic Ballast	47	0.09	282	\$83.30	2	0	No Change	47	0.09	0%	282	\$50.20	\$0.00	\$0.00	0.00	0	\$33.11	0.00		
D127.21	Large Office - 1st Floor	1040	6	2	T8 Lamps w/Electronic Ballast	47	0.28	293.28	\$86.64	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	47	0.20	30%	205.296	\$36.54	\$75.00	\$75.00	0.08	87.984	\$50.09	1.50		
D127.21	Stairway	3000	2	2	T8 Lamps w/Electronic Ballast	47	0.09	282	\$83.30	2	0	No Change	47	0.09	0%	282	\$50.20	\$0.00	\$0.00	0.00	0	\$33.11	0.00		
D127.21	Office - 2nd Floor	1040	9	2	T8 Lamps w/Electronic Ballast	47	0.42	439.92	\$129.95	9	1	Dual Technology Occupancy Sensor - Switch Mnt.	47	0.30	30%	307.944	\$54.81	\$75.00	\$75.00	0.13	131.976	\$75.14	1.00		
D127.21	Office - 2nd Floor	1040	4	2	T8 Lamps w/Electronic Ballast	47	0.19	195.52	\$57.76	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	47	0.13	30%	136.864	\$24.36	\$75.00	\$75.00	0.06	58.656	\$33.40	2.25		
D127.21	Office - 2nd Floor	1040	5	2	T8 Lamps w/Electronic Ballast	47	0.24	244.4	\$72.20	5	1	Dual Technology Occupancy Sensor - Switch Mnt.	47	0.16	30%	171.08	\$30.45	\$75.00	\$75.00	0.07	73.32	\$41.74	1.80		
D127.21	2nd Floor Hall	3000	5	2	T8 Lamps w/Electronic Ballast	47	0.24	705	\$208.26	5	0	No Change	47	0.24	0%	705	\$125.49	\$0.00	\$0.00	0.00	0	\$82.77	0.00		
D127.21	Break Room - 2nd Floor	1040	6	2	T8 Lamps w/Electronic Ballast	47	0.28	293.28	\$86.64	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	47	0.20	30%	205.296	\$36.54	\$75.00	\$75.00	0.08	87.984	\$50.09	1.50		
D121.11	Rest Room	156	1	2	4' T8 Lamps w/Electronic Ballast	50	0.05	7.8	\$2.17	1	0	No Change	50	0.05	0%	7.8	\$1.39	\$0.00	\$0.00	0.00	0	\$0.78	0.00		
D613	Closet	156	1	1	(1) 13W CFL Screw In	13	0.01	2.028	\$2.78	1	0	No Change	13	0.01	0%	2.028	\$0.36	\$0.00	\$0.00	0.00	0	\$2.42	0.00		
D613	Stairway	3000	1	1	(1) 13W CFL Screw In	13	0.01	39	\$53.40	1	0	No Change	13	0.01	0%	39	\$6.94	\$0.00	\$0.00	0.00	0	\$46.46	0.00		
D121.11	Office - 3rd Floor	1040	2	2	4' T8 Lamps w/Electronic Ballast	50	0.10	104	\$28.88	2	1	Dual Technology Occupancy Sensor - Switch Mnt.	50	0.07	30%	72.8	\$12.96	\$75.00	\$75.00	0.03	31.2	\$15.92	4.71		
D613	Mech. Room - 3rd Floor	156	1	1	(1) 13W CFL Screw In	13	0.01	2.028	\$2.78	1	0	No Change	13	0.01	0%	2.028	\$0.36	\$0.00	\$0.00	0.00	0	\$2.42	0.00		
D121.11	Com Room - 3rd Floor	1040	1	2	4' T8 Lamps w/Electronic Ballast	50	0.05	52	\$14.44	1	0	No Change	50	0.05	0%	52	\$9.26	\$0.00	\$0.00	0.00	0	\$5.18	0.00		
D121.11	Center Office - 3rd Floor	1040	2	2	4' T8 Lamps w/Electronic Ballast	50	0.10	104	\$28.88	2	1	Dual Technology Occupancy Sensor - Switch Mnt.	50	0.07	30%	72.8	\$12.96	\$75.00	\$75.00	0.03	31.2	\$15.92	4.71		
D121.11	Left Office - 3rd Floor	1040	3	2	4' T8 Lamps w/Electronic Ballast	50	0.15	156	\$43.32	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	50	0.11	30%	109.2	\$19.44	\$75.00	\$75.00	0.05	46.8	\$23.88	3.14		
D121.11	Office - 3rd Floor	1040	7	2	4' T8 Lamps w/Electronic Ballast	50	0.35	364	\$101.08	7	1	Dual Technology Occupancy Sensor - Switch Mnt.	50	0.25	30%	254.8	\$45.35	\$75.00	\$75.00	0.11	109.2	\$55.72	1.35		
613	Basement	156	15	1	(1) 26w CFL Lamp	26	0.39	60.84	\$41.65	15	0	No Change	26	0.39	0%	60.84	\$10.83	\$0.00	\$0.00	0.00	0	\$30.82	0.00		
650	Exterior	4400	10	1	No Change	18	0.18	792	\$140.98	10	0	No Change	18	0.18	0%	792	\$140.98	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
Totals			124	49			5.1	6,528.5	\$1,817	124	12			4.3		5,759.8	\$1,025.25	\$900	\$900	0.78	769	\$792	1.14		



## Investment Grade Lighting Audit

CEG Job #: IC11039  
Project: Library

Library

KWH COST: \$0.181

### ECM: Lighting Upgrade - General

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
264.21	Book Stacks	3400	62	6	4x4, 6 Lamp, 32w 700 Series T8, Elect. Ballast, Pendant Mnt., Prismatic Lens	172	10.66	36,257.6	\$6,562.63	62	6	Relamp - Sylvania Lamp FO28/841/SS/ECO	148	9.18	31198.4	\$5,646.91	\$42.00	\$620.00	\$2,604.00	1.49	5059.2	\$915.72	2.84
227.21	Periodicals	3400	9	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.59	1,989.0	\$360.01	9	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.44	1499.4	\$271.39	\$30.00	\$0.00	\$270.00	0.14	489.6	\$88.62	3.05
111.14	Utility Room	500	3	1	1x4, 1-Lamp, 34w T12, Mag. Ballast, Surface Mnt., No Lens	48	0.14	72.0	\$13.03	3	1	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	25	0.08	37.5	\$6.79	\$80.00	\$30.00	\$240.00	0.07	34.5	\$6.24	38.43
227.21	Librarian's Office	3120	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	1,216.8	\$220.24	6	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	917.28	\$166.03	\$30.00	\$0.00	\$180.00	0.10	299.52	\$54.21	3.32
227.21	Office	3120	7	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.46	1,419.6	\$256.95	7	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.34	1070.16	\$193.70	\$30.00	\$0.00	\$210.00	0.11	349.44	\$63.25	3.32
100	Men's Rest Room	3400	1	2	2' Vanity Light, 2-Lamp, 20w T12, Mag. Ballast, Wall Mnt., Glass Lens	42	0.04	142.8	\$25.85	1	2	Reballast & Relamp; 17w T8 Elec. Ballast	33	0.03	112.2	\$20.31	\$60.00	\$10.00	\$60.00	0.01	30.6	\$5.54	10.83
100	Staff Rest Room	3120	1	2	2' Vanity Light, 2-Lamp, 20w T12, Mag. Ballast, Wall Mnt., Glass Lens	42	0.04	131.0	\$23.72	1	2	Reballast & Relamp; 17w T8 Elec. Ballast	33	0.03	102.96	\$18.64	\$60.00	\$10.00	\$60.00	0.01	28.08	\$5.08	11.81
227.21	Staff Lunch Room	2860	7	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.46	1,301.3	\$235.54	7	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.34	980.98	\$177.56	\$30.00	\$0.00	\$210.00	0.11	320.32	\$57.98	3.62
227.21	Meeting Room	2860	18	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	1.17	3,346.2	\$605.66	18	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.88	2522.52	\$456.58	\$30.00	\$0.00	\$540.00	0.29	823.68	\$149.09	3.62
623		1800	4	1	Track Head, 65w BR30	65	0.26	468.0	\$84.71	4	1	Energy Star Rated, 26w CFL Flood Lamp	26	0.10	187.2	\$33.88	\$20.00	\$28.00	\$80.00	0.16	280.8	\$50.82	1.57
560	Lobby	3400	6	1	Recessed Down Light, 26w CFL Lamp	26	0.16	530.4	\$96.00	6	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
560	Vestibule	3400	6	1	Recessed Down Light, 26w CFL Lamp	26	0.16	530.4	\$96.00	6	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Men's Rest Room	3400	3	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.20	663.0	\$120.00	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	499.8	\$90.46	\$30.00	\$0.00	\$90.00	0.05	163.2	\$29.54	3.05
227.21	Woman's Rest Room	3400	3	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.20	663.0	\$120.00	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	499.8	\$90.46	\$30.00	\$0.00	\$90.00	0.05	163.2	\$29.54	3.05
211.44	Maintenance Room	500	1	1	1x4, 1 Lamp, 32w T8, Elect. Ballast, Wall Mnt., No Lens	32	0.03	16.0	\$2.90	1	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	25	0.03	12.5	\$2.26	\$7.00	\$10.00	\$7.00	0.01	3.5	\$0.63	11.05
725	Exterior	4400	4	1	150w HPS Wallpack	188	0.75	3,308.8	\$598.89	4	0	No Change	0	0.00	0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
<b>Totals</b>			137	29			14.94	48,747	\$8,823	137	27			12.0	39,641	\$7,175	\$479	\$708	\$4,641	2.6	8,046	\$1,456	3.19

ECM: Lighting Controls

EXISTING LIGHTING										PROPOSED LIGHTING CONTROLS										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
264.21	Book Stacks	3400	62	6	Relamp - Sylvania Lamp FO28/841/SS/ECO	148	9.18	31198.4	\$5,646.91	62	0	No Change	148	9.18	0%	31198.4	\$5,646.91	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Periodicals	3400	9	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.44	1499.4	\$271.39	9	0	No Change	49	0.44	0%	1499.4	\$271.39	\$0.00	\$0.00	0.00	0	\$0.00	0.00
111.14	Utility Room	500	3	1	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	25	0.08	37.5	\$6.79	3	0	No Change	25	0.08	0%	37.5	\$6.79	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Librarian's Office	3120	6	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	917.28	\$166.03	6	0	No Change	49	0.29	0%	917.28	\$166.03	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Office	3120	7	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.34	1070.16	\$193.70	7	1	No Change	49	0.34	0%	1070.16	\$193.70	\$0.00	\$0.00	0.00	0	\$0.00	0.00
100	Men's Rest Room	3400	1	2	Reballast & Relamp; 17w T8 Elec. Ballast	33	0.03	112.2	\$20.31	1	0	No Change	33	0.03	0%	112.2	\$20.31	\$0.00	\$0.00	0.00	0	\$0.00	0.00
100	Staff Rest Room	3120	1	2	Reballast & Relamp; 17w T8 Elec. Ballast	33	0.03	102.96	\$18.64	1	0	No Change	33	0.03	0%	102.96	\$18.64	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Staff Lunch Room	2860	7	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.34	980.98	\$177.56	7	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.17	50%	490.49	\$88.78	\$75.00	\$75.00	0.17	490.49	\$88.78	0.84
227.21	Meeting Room	2860	18	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.88	2522.52	\$456.58	18	0	No Change	49	0.88	0%	2522.52	\$456.58	\$0.00	\$0.00	0.00	0	\$0.00	0.00
623		1800	4	1	Energy Star Rated, 26w CFL Flood Lamp	26	0.10	187.2	\$33.88	4	0	No Change	26	0.10	0%	187.2	\$33.88	\$0.00	\$0.00	0.00	0	\$0.00	0.00
560	Lobby	3400	6	1	No Change	0	0.00	0	\$0.00	6	0	No Change	0	0.00	0%	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
560	Vestibule	3400	6	1	No Change	0	0.00	0	\$0.00	6	0	No Change	0	0.00	0%	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Men's Rest Room	3400	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	499.8	\$90.46	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.07	50%	249.9	\$45.23	\$75.00	\$75.00	0.07	249.9	\$45.23	1.66
227.21	Woman's Rest Room	3400	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	499.8	\$90.46	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.07	50%	249.9	\$45.23	\$75.00	\$75.00	0.07	249.9	\$45.23	1.66
211.44	Maintenance Room	500	1	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	25	0.03	12.5	\$2.26	1	0	No Change	25	0.03	0%	12.5	\$2.26	\$0.00	\$0.00	0.00	0	\$0.00	0.00
Totals			137	29			12.0	39,640.7	\$7,175	137	4			11.7		38,650.4	\$6,995.72		\$225	0.32	990	\$179	1.26

## Investment Grade Lighting Audit

CEG Job #: 1C11039

Project: Municipal Building

1261 Chews Landing Road  
Gloucester Township, NJ

Municipal Building

KWH COST: \$0.165

### ECM: Lighting Upgrade - General

EXISTING LIGHTING					PROPOSED LIGHTING										SAVINGS								
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
227.21	Open Office - 1st Floor	2080	35	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	2.28	4,732.0	\$780.78	35	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	1.72	3567.2	\$588.59	\$30.00	\$0.00	\$1,050.00	0.56	1164.8	\$192.19	5.46
227.21	Counter Area	2080	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	270.4	\$44.62	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	203.84	\$33.63	\$30.00	\$0.00	\$60.00	0.03	66.56	\$10.98	5.46
227.21	Tax Collector	2080	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	540.8	\$89.23	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	407.68	\$67.27	\$30.00	\$0.00	\$120.00	0.06	133.12	\$21.96	5.46
227.21	Muni. Assessors Office	2080	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	540.8	\$89.23	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	407.68	\$67.27	\$30.00	\$0.00	\$120.00	0.06	133.12	\$21.96	5.46
227.21	Side Office	2080	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	811.2	\$133.85	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	611.52	\$100.90	\$30.00	\$0.00	\$180.00	0.10	199.68	\$32.95	5.46
227.21	Side Office	2080	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	811.2	\$133.85	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	611.52	\$100.90	\$30.00	\$0.00	\$180.00	0.10	199.68	\$32.95	5.46
227.21	Corner Office	2080	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	811.2	\$133.85	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	611.52	\$100.90	\$30.00	\$0.00	\$180.00	0.10	199.68	\$32.95	5.46
227.21	Printer/ Copy Room	2080	11	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.72	1,487.2	\$245.39	11	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.54	1121.12	\$184.98	\$30.00	\$0.00	\$330.00	0.18	366.08	\$60.40	5.46
237.22		2080	1	3	2x2, 3 Lamp, 31w T8 Ulamp, Elect. Ballast, Recessed Mnt., Prismatic Lens	92	0.09	191.4	\$31.57	1	0	No Change	92	0.09	191.36	\$31.57	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	File Storage/ Break Room	2080	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	811.2	\$133.85	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	611.52	\$100.90	\$30.00	\$0.00	\$180.00	0.10	199.68	\$32.95	5.46
227.21	Rear Exit	2600	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	338.0	\$55.77	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	254.8	\$42.04	\$30.00	\$0.00	\$60.00	0.03	83.2	\$13.73	4.37
227.21	Lobby	4400	8	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.52	2,288.0	\$377.52	8	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.39	1724.8	\$284.59	\$30.00	\$0.00	\$240.00	0.13	563.2	\$92.93	2.58
227.21	Men's Rest Room	4225	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	274.6	\$45.31	1	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.05	207.025	\$34.16	\$30.00	\$0.00	\$30.00	0.02	67.6	\$11.15	2.69

## Investment Grade Lighting Audit

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
221.41		4225	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Prismatic	62	0.25	1,047.8	\$172.89	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	845	\$139.43	\$14.00	\$40.00	\$56.00	0.05	202.8	\$33.46	1.67
221.14	Custodial Closet	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.12	148.8	\$24.55	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$19.80	\$14.00	\$20.00	\$28.00	0.02	28.8	\$4.75	5.89
227.21	Woman's Rest Room	4225	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	274.6	\$45.31	1	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.05	207.025	\$34.16	\$30.00	\$0.00	\$30.00	0.02	67.6	\$11.15	2.69
221.41		4225	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Prismatic	62	0.25	1,047.8	\$172.89	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	845	\$139.43	\$14.00	\$40.00	\$56.00	0.05	202.8	\$33.46	1.67
227.21	Corridor	4400	9	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.59	2,574.0	\$424.71	9	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.44	1940.4	\$320.17	\$30.00	\$0.00	\$270.00	0.14	633.6	\$104.54	2.58
227.21	Twp. Clerk	8736	15	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.98	8,517.6	\$1,405.40	15	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.74	6420.96	\$1,059.46	\$30.00	\$0.00	\$450.00	0.24	2096.64	\$345.95	1.30
227.21	Conference/ Lunch Room	2080	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	540.8	\$89.23	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	407.68	\$67.27	\$30.00	\$0.00	\$120.00	0.06	133.12	\$21.96	5.46
227.21	File Room	2080	8	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.52	1,081.6	\$178.46	8	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.39	815.36	\$134.53	\$30.00	\$0.00	\$240.00	0.13	266.24	\$43.93	5.46
227.21	Office	2080	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	811.2	\$133.85	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	611.52	\$100.90	\$30.00	\$0.00	\$180.00	0.10	199.68	\$32.95	5.46
227.21	Office	2080	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	811.2	\$133.85	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	611.52	\$100.90	\$30.00	\$0.00	\$180.00	0.10	199.68	\$32.95	5.46
221.41	Rear Stairwell	4400	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Prismatic	62	0.25	1,091.2	\$180.05	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	880	\$145.20	\$14.00	\$40.00	\$56.00	0.05	211.2	\$34.85	1.61
227.21	Mayor's Office	2080	10	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.65	1,352.0	\$223.08	10	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.49	1019.2	\$168.17	\$30.00	\$0.00	\$300.00	0.16	332.8	\$54.91	5.46
227.21	Mayor's Office	2080	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	811.2	\$133.85	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	611.52	\$100.90	\$30.00	\$0.00	\$180.00	0.10	199.68	\$32.95	5.46
227.21	Lunch Room Area	500	3	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.20	97.5	\$16.09	3	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.15	73.5	\$12.13	\$30.00	\$0.00	\$90.00	0.05	24	\$3.96	22.73
221.41	Rest Room	1200	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Prismatic	62	0.06	74.4	\$12.28	1	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.05	60	\$9.90	\$14.00	\$10.00	\$14.00	0.01	14.4	\$2.38	5.89
221.41	Rest Room	1200	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Prismatic	62	0.06	74.4	\$12.28	1	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.05	60	\$9.90	\$14.00	\$10.00	\$14.00	0.01	14.4	\$2.38	5.89

## Investment Grade Lighting Audit

EXISTING LIGHTING										PROPOSED LIGHTING								SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
227.21	Vital Statistics - Front Office	1900	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	494.0	\$81.51	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	372.4	\$61.45	\$30.00	\$0.00	\$120.00	0.06	121.6	\$20.06	5.98
227.21	Vital Statistics - Rear Office	1900	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	494.0	\$81.51	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	372.4	\$61.45	\$30.00	\$0.00	\$120.00	0.06	121.6	\$20.06	5.98
227.21	Personnel	2080	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	540.8	\$89.23	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	407.68	\$67.27	\$30.00	\$0.00	\$120.00	0.06	133.12	\$21.96	5.46
221.14	Personnel Storage	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.12	148.8	\$24.55	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$19.80	\$14.00	\$20.00	\$28.00	0.02	28.8	\$4.75	5.89
227.21		1200	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	156.0	\$25.74	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	117.6	\$19.40	\$30.00	\$0.00	\$60.00	0.03	38.4	\$6.34	9.47
227.21	A110 Storage	1200	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	156.0	\$25.74	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	117.6	\$19.40	\$30.00	\$0.00	\$60.00	0.03	38.4	\$6.34	9.47
227.21	Secure Storage	1200	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	312.0	\$51.48	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	235.2	\$38.81	\$30.00	\$0.00	\$120.00	0.06	76.8	\$12.67	9.47
221.14	A111 Electrical Room	504	6	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.37	187.5	\$30.94	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.30	151.2	\$24.95	\$14.00	\$60.00	\$84.00	0.07	36.288	\$5.99	14.03
227.21	A109 Council Room Entry	4400	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	572.0	\$94.38	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	431.2	\$71.15	\$30.00	\$0.00	\$60.00	0.03	140.8	\$23.23	2.58
227.21	A109 Council Room	1200	46	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	2.99	3,588.0	\$592.02	46	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	2.25	2704.8	\$446.29	\$30.00	\$0.00	\$1,380.00	0.74	883.2	\$145.73	9.47
221.22		4400	6	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.37	1,636.8	\$270.07	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.30	1320	\$217.80	\$14.00	\$0.00	\$84.00	0.07	316.8	\$52.27	1.61
227.21	A109-4 Conference Room	600	8	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.52	312.0	\$51.48	8	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.39	235.2	\$38.81	\$30.00	\$0.00	\$240.00	0.13	76.8	\$12.67	18.94
221.14	A109-3 Storage	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.12	148.8	\$24.55	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$19.80	\$14.00	\$20.00	\$28.00	0.02	28.8	\$4.75	5.89
227.21	A109-2 Lunch/ Kitchen	2600	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	338.0	\$55.77	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	254.8	\$42.04	\$30.00	\$0.00	\$60.00	0.03	83.2	\$13.73	4.37
227.21	A200 Professional Standard	2600	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	676.0	\$111.54	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	509.6	\$84.08	\$30.00	\$0.00	\$120.00	0.06	166.4	\$27.46	4.37
221.14	A201 Phone Room	2600	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.12	322.4	\$53.20	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	260	\$42.90	\$14.00	\$20.00	\$28.00	0.02	62.4	\$10.30	2.72

## Investment Grade Lighting Audit

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS				
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback	
227.21	Construction Office	1850	38	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	2.47	4,569.5	\$753.97	38	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	1.86	3444.7	\$568.38	\$30.00	\$0.00	\$1,140.00	0.61	1124.8	\$185.59	6.14	
227.21	Corner Office - Lechner	1850	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	481.0	\$79.37	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	362.6	\$59.83	\$30.00	\$0.00	\$120.00	0.06	118.4	\$19.54	6.14	
227.21	Zoning Office	1850	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	481.0	\$79.37	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	362.6	\$59.83	\$30.00	\$0.00	\$120.00	0.06	118.4	\$19.54	6.14	
227.21	Side Office	1850	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	481.0	\$79.37	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	362.6	\$59.83	\$30.00	\$0.00	\$120.00	0.06	118.4	\$19.54	6.14	
227.21	Kitchenette	1850	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	721.5	\$119.05	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	543.9	\$89.74	\$30.00	\$0.00	\$180.00	0.10	177.6	\$29.30	6.14	
227.21	File Storage	1100	5	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.33	357.5	\$58.99	5	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.25	269.5	\$44.47	\$30.00	\$0.00	\$150.00	0.08	88	\$14.52	10.33	
111.15		1100	6	1	6"x4, 1-Lamp, 34w T12, Mag. Ballast, Surface Mnt., White Diffuser	48	0.29	316.8	\$52.27	6	1	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	25	0.15	165	\$27.23	\$80.00	\$60.00	\$480.00	0.14	151.8	\$25.05	19.16	
221.14	A203 Roof Access	1200	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.12	148.8	\$24.55	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$19.80	\$14.00	\$20.00	\$28.00	0.02	28.8	\$4.75	5.89	
221.41	Men's Rest Room	4225	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Prismatic	62	0.12	523.9	\$86.44	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	422.5	\$69.71	\$14.00	\$20.00	\$28.00	0.02	101.4	\$16.73	1.67	
221.41	Woman's Rest Room	4225	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Prismatic	62	0.12	523.9	\$86.44	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	422.5	\$69.71	\$14.00	\$20.00	\$28.00	0.02	101.4	\$16.73	1.67	
227.21	2nd Floor Hall	4400	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	1,716.0	\$283.14	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	1293.6	\$213.44	\$30.00	\$0.00	\$180.00	0.10	422.4	\$69.70	2.58	
227.21	2nd Floor Connecting Corridor	4400	8	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.52	2,288.0	\$377.52	8	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.39	1724.8	\$284.59	\$30.00	\$0.00	\$240.00	0.13	563.2	\$92.93	2.58	
<b>Police Building</b>													0					\$0.00						
227.21	213 Police Operations Center	8760	8	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.52	4,555.2	\$751.61	8	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.39	3433.92	\$566.60	\$30.00	\$0.00	\$240.00	0.13	1121.28	\$185.01	1.30	
227.21	2nd Floor Corridor	8760	16	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	1.04	9,110.4	\$1,503.22	16	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.78	6867.84	\$1,133.19	\$30.00	\$0.00	\$480.00	0.26	2242.56	\$370.02	1.30	
227.21	Men's Rest Room	2600	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	169.0	\$27.89	1	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.05	127.4	\$21.02	\$30.00	\$0.00	\$30.00	0.02	41.6	\$6.86	4.37	
227.21	Woman's Rest Room	2600	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	169.0	\$27.89	1	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.05	127.4	\$21.02	\$30.00	\$0.00	\$30.00	0.02	41.6	\$6.86	4.37	

## Investment Grade Lighting Audit

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
227.21	217 Conference Room/Offices	1900	25	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	1.63	3,087.5	\$509.44	25	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	1.23	2327.5	\$384.04	\$30.00	\$0.00	\$750.00	0.40	760	\$125.40	5.98
227.21	218-219 Office	1600	12	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.78	1,248.0	\$205.92	12	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.59	940.8	\$155.23	\$30.00	\$0.00	\$360.00	0.19	307.2	\$50.69	7.10
227.21	210 Police Records	1600	11	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.72	1,144.0	\$188.76	11	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.54	862.4	\$142.30	\$30.00	\$0.00	\$330.00	0.18	281.6	\$46.46	7.10
227.21	Lt Office	1200	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	312.0	\$51.48	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	235.2	\$38.81	\$30.00	\$0.00	\$120.00	0.06	76.8	\$12.67	9.47
227.21	Office/ Files	2600	10	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.65	1,690.0	\$278.85	10	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.49	1274	\$210.21	\$30.00	\$0.00	\$300.00	0.16	416	\$68.64	4.37
227.21	206 Tech. Services	8760	10	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.65	5,694.0	\$939.51	10	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.49	4292.4	\$708.25	\$30.00	\$0.00	\$300.00	0.16	1401.6	\$231.26	1.30
227.21	Law Library	2600	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	1,014.0	\$167.31	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	764.4	\$126.13	\$30.00	\$0.00	\$180.00	0.10	249.6	\$41.18	4.37
142.21	Storage Closet	1200	1	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	156	0.16	187.2	\$30.89	1	3	3 Lamp , 32w T8, Elect. Ballast, Specular Reflector; retrofit	86	0.09	103.2	\$17.03	\$100.00	\$15.00	\$100.00	0.07	84	\$13.86	7.22
227.21	Kitchenette	2600	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	169.0	\$27.89	1	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.05	127.4	\$21.02	\$30.00	\$0.00	\$30.00	0.02	41.6	\$6.86	4.37
563	Dispatch	8760	8	1	Recessed Down Light, 26w PL Lamp	26	0.21	1,822.1	\$300.64	8	0	No Change	26	0.21	1822.08	\$300.64	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
564		8760	12	1	Recessed Down Light, 50w MR16 Lamp	50	0.60	5,256.0	\$867.24	12	1	LED MR16 4w Dimmable Lamp	4	0.05	420.48	\$69.38	\$35.00	\$0.00	\$420.00	0.55	4835.52	\$797.86	0.53
142.22	Storage/ Server Room	1200	1	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Parabolic Lens	156	0.16	187.2	\$30.89	1	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp F028/841/SS/ECO	72	0.07	86.4	\$14.26	\$100.00	\$15.00	\$100.00	0.08	100.8	\$16.63	6.01
227.21	Kitchenette	2100	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	273.0	\$45.05	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	205.8	\$33.96	\$30.00	\$0.00	\$60.00	0.03	67.2	\$11.09	5.41
227.21	Stairway	8760	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	1,138.8	\$187.90	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	858.48	\$141.65	\$30.00	\$0.00	\$60.00	0.03	280.32	\$46.25	1.30
227.21	Police Chief - Front	2600	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	1,014.0	\$167.31	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	764.4	\$126.13	\$30.00	\$0.00	\$180.00	0.10	249.6	\$41.18	4.37
227.21	Police Chief Office	1615	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	629.9	\$103.93	6	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.29	474.81	\$78.34	\$30.00	\$0.00	\$180.00	0.10	155.04	\$25.58	7.04
3520	Police Chief Storage	1200	2	2	White Globe Fixture, (2) 100w A Lamps	200	0.40	480.0	\$79.20	2	2	26w CFL Lamp	52	0.10	124.8	\$20.59	\$40.00	\$14.00	\$80.00	0.30	355.2	\$58.61	1.37

## Investment Grade Lighting Audit

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
227.21	Deputy Chief	1615	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	419.9	\$69.28	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	316.54	\$52.23	\$30.00	\$0.00	\$120.00	0.06	103.36	\$17.05	7.04
227.21	205 Grants	2080	10	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.65	1,352.0	\$223.08	10	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.49	1019.2	\$168.17	\$30.00	\$0.00	\$300.00	0.16	332.8	\$54.91	5.46
227.21	204 Court Clerks	2080	24	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	1.56	3,244.8	\$535.39	24	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	1.18	2446.08	\$403.60	\$30.00	\$0.00	\$720.00	0.38	798.72	\$131.79	5.46
227.21	204 Files Area	2080	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	270.4	\$44.62	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	203.84	\$33.63	\$30.00	\$0.00	\$60.00	0.03	66.56	\$10.98	5.46
227.21	204 Corner Office	2080	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	270.4	\$44.62	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	203.84	\$33.63	\$30.00	\$0.00	\$60.00	0.03	66.56	\$10.98	5.46
227.21	204 Storage	1200	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	156.0	\$25.74	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	117.6	\$19.40	\$30.00	\$0.00	\$60.00	0.03	38.4	\$6.34	9.47
227.21	CSI Room	2080	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	540.8	\$89.23	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	407.68	\$67.27	\$30.00	\$0.00	\$120.00	0.06	133.12	\$21.96	5.46
227.21	Grants Office #1	2080	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	540.8	\$89.23	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	407.68	\$67.27	\$30.00	\$0.00	\$120.00	0.06	133.12	\$21.96	5.46
227.21	Grants Office #2	2080	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	540.8	\$89.23	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	407.68	\$67.27	\$30.00	\$0.00	\$120.00	0.06	133.12	\$21.96	5.46
227.21	Clerks Office #1	2080	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	270.4	\$44.62	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	203.84	\$33.63	\$30.00	\$0.00	\$60.00	0.03	66.56	\$10.98	5.46
227.21	Clerks Office #2	2080	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	270.4	\$44.62	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	203.84	\$33.63	\$30.00	\$0.00	\$60.00	0.03	66.56	\$10.98	5.46
211.25	Supplies #207	1200	1	2	1x4, 1 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Acrylic Lens	30	0.03	36.0	\$5.94	1	0	No Change	30	0.03	36	\$5.94	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Woman's Rest Room	3295	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	428.4	\$70.68	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	322.91	\$53.28	\$30.00	\$0.00	\$60.00	0.03	105.44	\$17.40	3.45
227.21	Men's Rest Room	3295	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	428.4	\$70.68	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	322.91	\$53.28	\$30.00	\$0.00	\$60.00	0.03	105.44	\$17.40	3.45
242.21	Park Patrol #202	2080	1	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	107	0.11	222.6	\$36.72	1	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.10	203.84	\$33.63	\$28.00	\$10.00	\$28.00	0.01	18.72	\$3.09	9.07



## Investment Grade Lighting Audit

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
227.21	Holding Cell Hallway	8760	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	1,138.8	\$187.90	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	858.48	\$141.65	\$30.00	\$0.00	\$60.00	0.03	280.32	\$46.25	1.30
3015	Holding Cell #1	8760	1	1	Wall Mnt., Glass Cover, 100w A Lamp	100	0.10	876.0	\$144.54	1	1	26w CFL Lamp	26	0.03	227.76	\$37.58	\$20.00	\$7.00	\$20.00	0.07	648.24	\$106.96	0.19
3015	Holding Cell #2	8760	1	1	Wall Mnt., Glass Cover, 100w A Lamp	100	0.10	876.0	\$144.54	1	1	26w CFL Lamp	26	0.03	227.76	\$37.58	\$20.00	\$7.00	\$20.00	0.07	648.24	\$106.96	0.19
242.21	Radio Room	8760	1	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	107	0.11	937.3	\$154.66	1	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.10	858.48	\$141.65	\$28.00	\$10.00	\$28.00	0.01	78.84	\$13.01	2.15
227.21	Police Entrance	8760	3	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.20	1,708.2	\$281.85	3	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.15	1287.72	\$212.47	\$30.00	\$0.00	\$90.00	0.05	420.48	\$69.38	1.30
142.25	Watch Desk/ Command	8760	4	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Parabolic Lens	156	0.62	5,466.2	\$901.93	4	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.29	2522.88	\$416.28	\$100.00	\$60.00	\$400.00	0.34	2943.36	\$485.65	0.82
227.21		8760	12	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.78	6,832.8	\$1,127.41	12	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.59	5150.88	\$849.90	\$30.00	\$0.00	\$360.00	0.19	1681.92	\$277.52	1.30
242.21		8760	2	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	107	0.21	1,874.6	\$309.32	2	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	1716.96	\$283.30	\$28.00	\$20.00	\$56.00	0.02	157.68	\$26.02	2.15
227.21	106 Hall	8760	5	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.33	2,847.0	\$469.76	5	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.25	2146.2	\$354.12	\$30.00	\$0.00	\$150.00	0.08	700.8	\$115.63	1.30
227.212	Squad Room	8760	16	2	2x2, 2 Lamp, 31w T8 Ulamp, Elect. Ballast, Recessed Mnt., Prismatic Lens	60	0.96	8,409.6	\$1,387.58	16	0	No Change	60	0.96	8409.6	\$1,387.58	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	122 Booking Fingerprinting	8760	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	1,138.8	\$187.90	2	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.10	858.48	\$141.65	\$30.00	\$0.00	\$60.00	0.03	280.32	\$46.25	1.30
227.212	Interview Room	2600	2	2	2x2, 2 Lamp, 31w T8 Ulamp, Elect. Ballast, Recessed Mnt., Prismatic Lens	60	0.12	312.0	\$51.48	2	0	No Change	60	0.12	312	\$51.48	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.212	Office	2600	4	2	2x2, 2 Lamp, 31w T8 Ulamp, Elect. Ballast, Recessed Mnt., Prismatic Lens	60	0.24	624.0	\$102.96	4	0	No Change	60	0.24	624	\$102.96	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Briefing Room	4400	12	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.78	3,432.0	\$566.28	12	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.59	2587.2	\$426.89	\$30.00	\$0.00	\$360.00	0.19	844.8	\$139.39	2.58
613.1	Boiler Room	2600	4	1	Industrial Fixture, 170w A19 Lamp	170	0.68	1,768.0	\$291.72	4	1	(1) 42w CFL Lamp	42	0.17	436.8	\$72.07	\$20.00	\$28.00	\$80.00	0.51	1331.2	\$219.65	0.36
284.21	Court Room	11248	12	8	4x4, 8 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	214	2.57	28,884.9	\$4,766.00	12	8	Relamp - Sylvania Lamp FO28/841/SS/ECO	192	2.30	25915.39	\$4,276.04	\$56.00	\$120.00	\$672.00	0.26	2969.472	\$489.96	1.37
142.21		1248	6	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	156	0.94	1,168.1	\$192.74	6	3	3 Lamp, 32w T8, Elect. Ballast, Specular Reflector; retrofit	86	0.52	643.968	\$106.25	\$100.00	\$90.00	\$600.00	0.42	524.16	\$86.49	6.94

## Investment Grade Lighting Audit

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback		
242.21		1248	2	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	107	0.21	267.1	\$44.07	2	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	244.608	\$40.36	\$28.00	\$20.00	\$56.00	0.02	22.464	\$3.71	15.11		
227.212	Kitchenette	1200	4	2	2x2, 2 Lamp, 31w T8 Ulamp, Elect. Ballast, Recessed Mnt., Prismatic Lens	60	0.24	288.0	\$47.52	4	0	No Change	60	0.24	288	\$47.52	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
227.21	Detective Offices	4400	16	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	1.04	4,576.0	\$755.04	16	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.78	3449.6	\$569.18	\$30.00	\$0.00	\$480.00	0.26	1126.4	\$185.86	2.58		
<b>Township Courts</b>													0								\$0.00				
221.11	Evidence Storage	1200	9	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.56	669.6	\$110.48	9	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.45	540	\$89.10	\$14.00	\$90.00	\$126.00	0.11	129.6	\$21.38	5.89		
142.11	Gun Cleaning Room	2600	1	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.16	405.6	\$66.92	1	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.07	187.2	\$30.89	\$100.00	\$0.00	\$100.00	0.08	218.4	\$36.04	2.78		
221.14	Locker Room	2600	9	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.56	1,450.8	\$239.38	9	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.45	1170	\$193.05	\$14.00	\$90.00	\$126.00	0.11	280.8	\$46.33	2.72		
3015	Female Changing Room	2600	2	1	Wall Mnt., Glass Cover, 100w A Lamp	100	0.20	520.0	\$85.80	2	1	26w CFL Lamp	26	0.05	135.2	\$22.31	\$20.00	\$14.00	\$40.00	0.15	384.8	\$63.49	0.63		
221.11	Lavatory	2600	1	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	62	0.06	161.2	\$26.60	1	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.05	130	\$21.45	\$14.00	\$10.00	\$14.00	0.01	31.2	\$5.15	2.72		
227.21	Court Entrance	1248	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	81.1	\$13.38	1	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.05	61.152	\$10.09	\$30.00	\$0.00	\$30.00	0.02	19.968	\$3.29	9.11		
227.21	Court Entrance	1248	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	81.1	\$13.38	1	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.05	61.152	\$10.09	\$30.00	\$0.00	\$30.00	0.02	19.968	\$3.29	9.11		
227.21	Deal Room	1248	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	324.5	\$53.54	4	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.20	244.608	\$40.36	\$30.00	\$0.00	\$120.00	0.06	79.872	\$13.18	9.11		
3015	Court Room IT Closet	1200	2	1	Wall Mnt., Glass Cover, 100w A Lamp	100	0.20	240.0	\$39.60	2	1	26w CFL Lamp	26	0.05	62.4	\$10.30	\$20.00	\$14.00	\$40.00	0.15	177.6	\$29.30	1.37		
242.11	Court Room Hall	1248	1	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	107	0.11	133.5	\$22.03	1	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.10	122.304	\$20.18	\$28.00	\$10.00	\$28.00	0.01	11.232	\$1.85	15.11		
227.21	First Floor Corridor	8760	7	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.46	3,985.8	\$657.66	7	2	Sylvania Lamp FBO30/841XP/6//SS/ECO	49	0.34	3004.68	\$495.77	\$30.00	\$0.00	\$210.00	0.11	981.12	\$161.88	1.30		
211.44	Stairway	8760	3	2	1x4, 1 Lamp, 32w T8, Elect. Ballast, Wall Mnt., No Lens	32	0.10	841.0	\$138.76	3	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	25	0.08	657	\$108.41	\$7.00	\$30.00	\$21.00	0.02	183.96	\$30.35	0.69		
247.211	Garage Hall		3	4	2x2, 4 Lamp, 17w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	68	0.20	0.0	\$0.00	3	0	No Change	68	0.20	0	\$0.00	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00		
211.44	Garage	2600	4	2	1x4, 1 Lamp, 32w T8, Elect. Ballast, Wall Mnt., No Lens	32	0.13	332.8	\$54.91	4	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	25	0.10	260	\$42.90	\$7.00	\$40.00	\$28.00	0.03	72.8	\$12.01	2.33		

## Investment Grade Lighting Audit

EXISTING LIGHTING				PROPOSED LIGHTING										SAVINGS									
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
221.41	Garage	2600	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Wall Mnt., Prismatic	62	0.25	644.8	\$106.39	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	520	\$85.80	\$14.00	\$40.00	\$56.00	0.05	124.8	\$20.59	2.72
725	Exterior	4400	16	1	150w HPS Wallpack	188	3.01	13,235.2	\$2,183.81	16	0	No Change	188	3.01	13235.2	\$2,183.81	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
713		4400	12	1	100w HPS 1x1 w/Prismatic Lens	125	1.50	6,600.0	\$1,089.00	12	0	No Change	125	1.50	6600	\$1,089.00	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
<b>Totals</b>			765	279			55.44	208,431	\$34,391	765	252			42.3	162,107	\$26,748		\$1,154	\$21,259	13.1	46,324	\$7,644	2.78

**ECM: Lighting Controls**

EXISTING LIGHTING				PROPOSED LIGHTING CONTROLS													SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
227.21	Open Office - 1st Floor	2080	35	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	1.72	3567.2	\$588.59	35	0	No Change	49	1.72	0%	3567.2	\$588.59	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Counter Area	2080	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	203.84	\$33.63	2	0	No Change	49	0.10	0%	203.84	\$33.63	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Tax Collector	2080	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	407.68	\$67.27	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.13	33%	274.36864	\$45.27	\$75.00	\$75.00	0.06	133.31136	\$22.00	3.41
227.21	Muni. Assessors Office	2080	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	407.68	\$67.27	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.13	33%	273.1456	\$45.07	\$75.00	\$75.00	0.06	134.5344	\$22.20	3.38
227.21	Side Office	2080	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	611.52	\$100.90	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.20	33%	409.7184	\$67.60	\$75.00	\$75.00	0.10	201.8016	\$33.30	2.25
227.21	Side Office	2080	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	611.52	\$100.90	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.20	33%	409.7184	\$67.60	\$75.00	\$75.00	0.10	201.8016	\$33.30	2.25
227.21	Corner Office	2080	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	611.52	\$100.90	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.20	33%	409.7184	\$67.60	\$75.00	\$75.00	0.10	201.8016	\$33.30	2.25
227.21	Printer/ Copy Room	2080	11	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.54	1121.12	\$184.98	11	1	Dual Technology Occupancy Sensor - Remote Mnt.	49	0.27	49%	571.7712	\$94.34	\$160.00	\$160.00	0.26	549.3488	\$90.64	1.77
237.22	0	2080	1	No Change	92	0.09	191.36	\$31.57	1	0	No Change	92	0.09	0%	191.36	\$31.57	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	File Storage/ Break Room	2080	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	611.52	\$100.90	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.15	49%	311.8752	\$51.46	\$75.00	\$75.00	0.14	299.6448	\$49.44	1.52
227.21	Rear Exit	2600	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	254.8	\$42.04	2	0	No Change	49	0.10	0%	254.8	\$42.04	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Lobby	4400	8	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.39	1724.8	\$284.59	8	0	No Change	49	0.39	0%	1724.8	\$284.59	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Men's Rest Room	4225	1	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	207.025	\$34.16	1	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.01	82%	37.2645	\$6.15	\$75.00	\$75.00	0.04	169.7605	\$28.01	0.53
221.41	0	4225	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	845	\$139.43	4			50	0.04	82%	152.1	\$25.10		\$0.00	0.16	692.9	\$114.33	
221.14	Custodial Closet	1200	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$19.80	2	0	No Change	50	0.10	0%	120	\$19.80	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Woman's Rest Room	4225	1	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	207.025	\$34.16	1	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.01	82%	37.2645	\$6.15	\$75.00	\$75.00	0.04	169.7605	\$28.01	0.53
221.41	0	4225	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	845	\$139.43	4			50	0.04	82%	152.1	\$25.10		\$0.00	0.16	692.9	\$114.33	
227.21	Corridor	4400	9	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.44	1940.4	\$320.17	9	0	No Change	49	0.44	0%	1940.4	\$320.17	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Twp. Clerk	8736	15	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.74	6420.96	\$1,059.46	15	1	Dual Technology Occupancy Sensor - Remote Mnt.	49	0.17	77%	1476.8208	\$243.68	\$160.00	\$160.00	0.57	4944.1392	\$815.78	0.20
227.21	Conference/ Lunch Room	2080	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	407.68	\$67.27	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.16	18%	334.2976	\$55.16	\$75.00	\$75.00	0.04	73.3824	\$12.11	6.19
227.21	File Room	2080	8	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.39	815.36	\$134.53	8	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.32	18%	668.5952	\$110.32	\$75.00	\$75.00	0.07	146.7648	\$24.22	3.10

EXISTING LIGHTING				PROPOSED LIGHTING CONTROLS														SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback	
227.21	Office	2080	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	611.52	\$100.90	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.24	18%	501.4464	\$82.74	\$75.00	\$75.00	0.05	110.0736	\$18.16	4.13	
227.21	Office	2080	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	611.52	\$100.90	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.24	18%	501.4464	\$82.74	\$75.00	\$75.00	0.05	110.0736	\$18.16	4.13	
221.41	Rear Stairwell	4400	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	880	\$145.20	4	0	No Change	50	0.20	0%	880	\$145.20	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Mayor's Office	2080	10	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.49	1019.2	\$168.17	10	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.25	50%	509.6	\$84.08	\$75.00	\$75.00	0.25	509.6	\$84.08	0.89	
227.21	Mayor's Office	2080	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	611.52	\$100.90	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.15	50%	305.76	\$50.45	\$75.00	\$75.00	0.15	305.76	\$50.45	1.49	
227.21	Lunch Room Area	500	3	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	73.5	\$12.13	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.08	48%	38.22	\$6.31	\$75.00	\$75.00	0.07	35.28	\$5.82	12.88	
221.41	Rest Room	1200	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.05	60	\$9.90	1	0	No Change	50	0.05	0%	60	\$9.90	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
221.41	Rest Room	1200	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.05	60	\$9.90	1	0	No Change	50	0.05	0%	60	\$9.90	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Vital Statistics - Front Office	1900	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	372.4	\$61.45	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.19	5%	353.78	\$58.37	\$75.00	\$75.00	0.01	18.62	\$3.07	24.41	
227.21	Vital Statistics - Rear Office	1900	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	372.4	\$61.45	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.19	5%	353.78	\$58.37	\$75.00	\$75.00	0.01	18.62	\$3.07	24.41	
227.21	Personnel	2080	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	407.68	\$67.27	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.16	20%	326.144	\$53.81	\$75.00	\$75.00	0.04	81.536	\$13.45	5.57	
221.14	Personnel Storage	1200	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$19.80	2	0	No Change	50	0.10	0%	120	\$19.80	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	0	1200	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	117.6	\$19.40	2	0	No Change	49	0.10	0%	117.6	\$19.40	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	A110 Storage	1200	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	117.6	\$19.40	2	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.08	20%	94.08	\$15.52	\$75.00	\$75.00	0.02	23.52	\$3.88	19.33	
227.21	Secure Storage	1200	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	235.2	\$38.81	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.16	20%	188.16	\$31.05	\$75.00	\$75.00	0.04	47.04	\$7.76	9.66	
221.14	A111 Electrical Room	504	6	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.30	151.2	\$24.95	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	50	0.04	87%	19.656	\$3.24	\$75.00	\$75.00	0.26	131.544	\$21.70	3.46	
227.21	A109 Council Room Entry	4400	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	431.2	\$71.15	2	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.08	20%	344.96	\$56.92	\$75.00	\$75.00	0.02	86.24	\$14.23	5.27	
227.21	A109 Council Room	1200	46	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	2.25	2704.8	\$446.29	46	0	No Change	49	2.25	0%	2704.8	\$446.29	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
221.22	0	4400	6	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.30	1320	\$217.80	6	1	Dual Technology Occupancy Sensor - Remote Mnt.	50	0.24	20%	1056	\$174.24	\$160.00	\$160.00	0.06	264	\$43.56	3.67	
227.21	A109-4 Conference Room	600	8	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.39	235.2	\$38.81	8	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.35	11%	209.328	\$34.54	\$75.00	\$75.00	0.04	25.872	\$4.27	17.57	
221.14	A109-3 Storage	1200	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$19.80	2	0	No Change	50	0.10	0%	120	\$19.80	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	A109-2 Lunch/ Kitchen	2600	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	254.8	\$42.04	2	0	No Change	49	0.10	0%	254.8	\$42.04	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	A200 Professional Standard	2600	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	509.6	\$84.08	4	0	No Change	49	0.20	0%	509.6	\$84.08	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
221.14	A201 Phone Room	2600	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	260	\$42.90	2	3	Dual Technology Occupancy Sensor - Remote Mnt.	50	0.08	20%	208	\$34.32	\$160.00	\$480.00	0.02	52	\$8.58	55.94	

EXISTING LIGHTING				PROPOSED LIGHTING CONTROLS														SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback	
227.21	Construction Office	1850	38	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	1.86	3444.7	\$568.38	38	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	1.49	20%	2755.76	\$454.70	\$75.00	\$75.00	0.37	688.94	\$113.68	0.66	
227.21	Corner Office - Lechner	1850	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	362.6	\$59.83	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.16	20%	290.08	\$47.86	\$75.00	\$75.00	0.04	72.52	\$11.97	6.27	
227.21	Zoning Office	1850	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	362.6	\$59.83	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.16	20%	290.08	\$47.86	\$75.00	\$75.00	0.04	72.52	\$11.97	6.27	
227.21	Side Office	1850	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	362.6	\$59.83	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.16	20%	290.08	\$47.86	\$75.00	\$75.00	0.04	72.52	\$11.97	6.27	
227.21	Kitchenette	1850	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	543.9	\$89.74	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.24	20%	435.12	\$71.79	\$75.00	\$75.00	0.06	108.78	\$17.95	2.79	
227.21	File Storage	1100	5	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.25	269.5	\$44.47	5			49	0.20	20%	215.6	\$35.57			0.05	53.9	\$8.89		
111.15	0	1100	6	Reballast & Relamp; Sylvania Lamp FO28/841/SS/ECO	25	0.15	165	\$27.23	6	0	No Change	25	0.15	0%	165	\$27.23	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
221.14	A203 Roof Access	1200	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	120	\$19.80	2	0	No Change	50	0.10	0%	120	\$19.80	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
221.41	Men's Rest Room	4225	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	422.5	\$69.71	2	0	No Change	50	0.10	0%	422.5	\$69.71	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
221.41	Woman's Rest Room	4225	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	422.5	\$69.71	2	0	No Change	50	0.10	0%	422.5	\$69.71	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	2nd Floor Hall	4400	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	1293.6	\$213.44	6	0	No Change	49	0.29	0%	1293.6	\$213.44	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	2nd Floor Connecting Corridor	4400	8	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.39	1724.8	\$284.59	8	0	No Change	49	0.39	0%	1724.8	\$284.59	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
Police Building	0	0	0	0	0	0.00	0	\$0.00	0	0	No Change	0	0.00	0%	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	213 Police Operations Center	8760	8	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.39	3433.92	\$566.60	8	0	No Change	49	0.39	0%	3433.92	\$566.60	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	2nd Floor Corridor	8760	16	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.78	6867.84	\$1,133.19	16	0	No Change	49	0.78	0%	6867.84	\$1,133.19	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Men's Rest Room	2600	1	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	127.4	\$21.02	1	0	Dual Technology Occupancy Sensor - Remote Mnt.	49	0.04	20%	101.92	\$16.82	\$0.00	\$0.00	0.01	25.48	\$4.20	0.00	
227.21	Woman's Rest Room	2600	1	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	127.4	\$21.02	1	1	Dual Technology Occupancy Sensor - Remote Mnt.	49	0.04	20%	101.92	\$16.82	\$160.00	\$160.00	0.01	25.48	\$4.20	38.06	
227.21	217 Conference Room/Offices	1900	25	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	1.23	2327.5	\$384.04	25	2	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.44	64%	837.9	\$138.25	\$75.00	\$150.00	0.78	1489.6	\$245.78	0.61	
227.21	218-219 Office	1600	12	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.59	940.8	\$155.23	12	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.40	32%	639.744	\$105.56	\$75.00	\$75.00	0.19	301.056	\$49.67	1.51	
227.21	210 Police Records	1600	11	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.54	862.4	\$142.30	11	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.37	32%	586.432	\$96.76	\$75.00	\$75.00	0.17	275.968	\$45.53	1.65	
227.21	Lt Office	1200	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	235.2	\$38.81	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.15	24%	179.928	\$29.69	\$75.00	\$75.00	0.05	55.272	\$9.12	8.22	
227.21	Office/ Files	2600	10	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.49	1274	\$210.21	10	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.39	20%	1019.2	\$168.17	\$75.00	\$75.00	0.10	254.8	\$42.04	1.78	
227.21	206 Tech. Services	8760	10	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.49	4292.4	\$708.25	10	0	No Change	49	0.49	0%	4292.4	\$708.25	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Law Library	2600	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	764.4	\$126.13	6	0	No Change	49	0.29	0%	764.4	\$126.13	\$0.00	\$0.00	0.00	0	\$0.00	0.00	

EXISTING LIGHTING				PROPOSED LIGHTING CONTROLS														SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback	
142.21	Storage Closet	1200	1	3 Lamp - 32w T8, Elect. Ballast, Specular Reflector; retrofit	86	0.09	103.2	\$17.03	1	0	No Change	86	0.09	0%	103.2	\$17.03	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Kitchenette	2600	1	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	127.4	\$21.02	1	0	No Change	49	0.05	0%	127.4	\$21.02	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
563	Dispatch	8760	8	No Change	26	0.21	1822.08	\$300.64	8	0	No Change	26	0.21	0%	1822.08	\$300.64	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
564	0	8760	12	LED MR16 4w Dimmable Lamp	4	0.05	420.48	\$69.38	12	1	Dual Technology Occupancy Sensor - Switch Mnt.	4	0.04	20%	336.384	\$55.50	\$75.00	\$75.00	0.01	84,096	\$13.88	5.41	
142.22	Storage/ Server Room	1200	1	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.07	86.4	\$14.26	1	0	No Change	72	0.07	0%	86.4	\$14.26	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Kitchenette	2100	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	205.8	\$33.96	2	0	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.04	60%	82.32	\$13.58	\$0.00	\$0.00	0.06	123.48	\$20.37	0.00	
227.21	Stairway	8760	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	858.48	\$141.65	2	0	No Change	49	0.10	0%	858.48	\$141.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Police Chief - Front	2600	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	764.4	\$126.13	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.24	20%	611.52	\$100.90	\$75.00	\$75.00	0.06	152.88	\$25.23	2.97	
227.21	Police Chief Office	1615	6	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	474.81	\$78.34	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.24	20%	379.848	\$62.67	\$75.00	\$75.00	0.06	94,962	\$15.67	4.79	
3520	Police Chief Storage	1200	2	26w CFL Lamp	52	0.10	124.8	\$20.59	2	0	No Change	52	0.10	0%	124.8	\$20.59	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Deputy Chief	1615	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	316.54	\$52.23	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.16	20%	253.232	\$41.78	\$75.00	\$75.00	0.04	63,308	\$10.45	7.18	
227.21	205 Grants	2080	10	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.49	1019.2	\$168.17	10	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.39	20%	815.36	\$134.53	\$75.00	\$75.00	0.10	203.84	\$33.63	2.23	
227.21	204 Court Clerks	2080	24	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	1.18	2446.08	\$403.60	24	2	Dual Technology Occupancy Sensor - Remote Mnt.	49	0.94	20%	1956.864	\$322.88	\$160.00	\$320.00	0.24	489,216	\$80.72	3.96	
227.21	204 Files Area	2080	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	203.84	\$33.63	2	0	No Change	49	0.10	0%	203.84	\$33.63	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	204 Corner Office	2080	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	203.84	\$33.63	2	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.08	20%	163.072	\$26.91	\$75.00	\$75.00	0.02	40,768	\$6.73	11.15	
227.21	204 Storage	1200	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	117.6	\$19.40	2	0	No Change	49	0.10	0%	117.6	\$19.40	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	CSI Room	2080	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	407.68	\$67.27	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.16	20%	326.144	\$53.81	\$75.00	\$75.00	0.04	81,536	\$13.45	5.57	
227.21	Grants Office #1	2080	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	407.68	\$67.27	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.16	20%	326.144	\$53.81	\$75.00	\$75.00	0.04	81,536	\$13.45	5.57	
227.21	Grants Office #2	2080	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	407.68	\$67.27	4	0	No Change	49	0.20	0%	407.68	\$67.27	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Clerks Office #1	2080	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	203.84	\$33.63	2	0	No Change	49	0.10	0%	203.84	\$33.63	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Clerks Office #2	2080	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	203.84	\$33.63	2	0	No Change	49	0.10	0%	203.84	\$33.63	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
211.25	Supplies #207	1200	1	No Change	30	0.03	36	\$5.94	1	0	No Change	30	0.03	0%	36	\$5.94	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
227.21	Woman's Rest Room	3295	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	322.91	\$53.28	2	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.02	84%	51.6656	\$8.52	\$75.00	\$75.00	0.08	271,2444	\$44.76	1.68	
227.21	Men's Rest Room	3295	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	322.91	\$53.28	2	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.02	84%	51.6656	\$8.52	\$75.00	\$75.00	0.08	271,2444	\$44.76	1.68	
242.21	Park Patrol #202	2080	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.10	203.84	\$33.63	1	0	No Change	98	0.10	0%	203.84	\$33.63	\$0.00	\$0.00	0.00	0	\$0.00	0.00	

EXISTING LIGHTING				PROPOSED LIGHTING CONTROLS													SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
227.21	Holding Cell Hallway	8760	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	858.48	\$141.65	2	0	No Change	49	0.10	0%	858.48	\$141.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00
3015	Holding Cell #1	8760	1	26w CFL Lamp	26	0.03	227.76	\$37.58	1	0	No Change	26	0.03	0%	227.76	\$37.58	\$0.00	\$0.00	0.00	0	\$0.00	0.00
3015	Holding Cell #2	8760	1	26w CFL Lamp	26	0.03	227.76	\$37.58	1	0	No Change	26	0.03	0%	227.76	\$37.58	\$0.00	\$0.00	0.00	0	\$0.00	0.00
242.21	Radio Room	8760	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.10	858.48	\$141.65	1	0	No Change	98	0.10	0%	858.48	\$141.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Police Entrance	8760	3	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	1287.72	\$212.47	3	0	No Change	49	0.15	0%	1287.72	\$212.47	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.25	Watch Desk/Command	8760	4	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.29	2522.88	\$416.28	4	0	No Change	72	0.29	0%	2522.88	\$416.28	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	0	8760	12	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.59	5150.88	\$849.90	12	0	No Change	49	0.59	0%	5150.88	\$849.90	\$0.00	\$0.00	0.00	0	\$0.00	0.00
242.21	0	8760	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	1716.96	\$283.30	2	0	No Change	98	0.20	0%	1716.96	\$283.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	106 Hall	8760	5	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.25	2146.2	\$354.12	5	0	No Change	49	0.25	0%	2146.2	\$354.12	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.212	Squad Room	8760	16	No Change	60	0.96	8409.6	\$1,387.58	16	9	Dual Technology Occupancy Sensor - Switch Mnt.	60	0.83	14%	7232.256	\$1,193.32	\$75.00	\$675.00	0.13	1177.344	\$194.26	3.47
227.21	122 Booking Fingerprinting	8760	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	858.48	\$141.65	2	0	No Change	49	0.10	0%	858.48	\$141.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.212	Interview Room	2600	2	No Change	60	0.12	312	\$51.48	2	0	No Change	60	0.12	0%	312	\$51.48	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.212	Office	2600	4	No Change	60	0.24	624	\$102.96	4	0	No Change	60	0.24	0%	624	\$102.96	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Briefing Room	4400	12	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.59	2587.2	\$426.89	12	0	No Change	49	0.59	0%	2587.2	\$426.89	\$0.00	\$0.00	0.00	0	\$0.00	0.00
613.1	Boiler Room	2600	4	(1) 42w CFL Lamp	42	0.17	436.8	\$72.07	4	0	No Change	42	0.17	0%	436.8	\$72.07	\$0.00	\$0.00	0.00	0	\$0.00	0.00
284.21	Court Room	11248	12	Relamp - Sylvania Lamp FO28/841/SS/ECO	192	2.30	25915.392	\$4,276.04	12	0	No Change	192	2.30	0%	25915.392	\$4,276.04	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.21	0	1248	6	3 Lamp, 32w T8, Elect. Ballast, Specular Reflector; retrofit	86	0.52	643.968	\$106.25	6	0	No Change	86	0.52	0%	643.968	\$106.25	\$0.00	\$0.00	0.00	0	\$0.00	0.00
242.21	0	1248	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	244.608	\$40.36	2	0	No Change	98	0.20	0%	244.608	\$40.36	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.212	Kitchenette	1200	4	No Change	60	0.24	288	\$47.52	4	0	No Change	60	0.24	0%	288	\$47.52	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Detective Offices	4400	16	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.78	3449.6	\$569.18	16	0	No Change	49	0.78	0%	3449.6	\$569.18	\$0.00	\$0.00	0.00	0	\$0.00	0.00
Township Courts	0	0	0	0	0	0.00	0	\$0.00	0	0	No Change	0	0.00	0%	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.11	Evidence Storage	1200	9	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.45	540	\$89.10	9	0	No Change	50	0.45	0%	540	\$89.10	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.11	Gun Cleaning Room	2600	1	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.07	187.2	\$30.89	1	0	No Change	72	0.07	0%	187.2	\$30.89	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.14	Locker Room	2600	9	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.45	1170	\$193.05	9	0	No Change	50	0.45	0%	1170	\$193.05	\$0.00	\$0.00	0.00	0	\$0.00	0.00
3015	Female Changing Room	2600	2	26w CFL Lamp	26	0.05	135.2	\$22.31	2	0	No Change	26	0.05	0%	135.2	\$22.31	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.11	Lavatory	2600	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.05	130	\$21.45	1	0	No Change	50	0.05	0%	130	\$21.45	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Court Entrance	1248	1	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	61.152	\$10.09	1	0	No Change	49	0.05	0%	61.152	\$10.09	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Court Entrance	1248	1	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	61.152	\$10.09	1	0	No Change	49	0.05	0%	61.152	\$10.09	\$0.00	\$0.00	0.00	0	\$0.00	0.00



EXISTING LIGHTING				PROPOSED LIGHTING CONTROLS													SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
227.21	Deal Room	1248	4	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	244.608	\$40.36	4	0	No Change	49	0.20	0%	244.608	\$40.36	\$0.00	\$0.00	0.00	0	\$0.00	0.00
3015	Court Room IT Closet	1200	2	26w CFL Lamp	26	0.05	62.4	\$10.30	2	0	No Change	26	0.05	0%	62.4	\$10.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
242.11	Court Room Hall	1248	1	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.10	122.304	\$20.18	1	0	No Change	98	0.10	0%	122.304	\$20.18	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	First Floor Corridor	8760	7	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.34	3004.68	\$495.77	7	0	No Change	49	0.34	0%	3004.68	\$495.77	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.44	Stairway	8760	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	25	0.08	657	\$108.41	3	0	No Change	25	0.08	0%	657	\$108.41	\$0.00	\$0.00	0.00	0	\$0.00	0.00
247.211	Garage Hall	0	3	No Change	68	0.20	0	\$0.00	3	0	No Change	68	0.20	0%	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
211.44	Garage	2600	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	25	0.10	260	\$42.90	4	0	No Change	25	0.10	0%	260	\$42.90	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.41	Garage	2600	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	520	\$85.80	4	0	No Change	50	0.20	0%	520	\$85.80	\$0.00	\$0.00	0.00	0	\$0.00	0.00
725	Exterior	4400	16	No Change	188	3.01	13235.2	\$2,183.81	16	0	No Change	188	3.01	0%	13235.2	\$2,183.81	\$0.00	\$0.00	0.00	0	\$0.00	0.00
713	0	4400	12	No Change	125	1.50	6600	\$1,089.00	12	0	No Change	125	1.50	0%	6600	\$1,089.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
	Totals		765			27.5	77,207.3	\$12,739	765	62			21.8		145,042.6	\$23,932.03		\$5,415	5.86	17,064	\$2,816	1.92

## Investment Grade Lighting Audit

CEG Job #: 1C11039

Project: Pool

Monroe Pool

KWH COST: \$0.179

### ECM #1: Lighting Upgrade - General

EXISTING LIGHTING					PROPOSED LIGHTING										SAVINGS								
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
142.11	Office	1100	1	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.16	171.6	\$30.72	1	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	85	0.09	93.5	\$16.74	\$100.00	\$20.00	\$100.00	0.07	78.1	\$13.98	7.15
142.11	Men's Rest Room	2200	2	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.31	686.4	\$122.87	2	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	85	0.17	374	\$66.95	\$100.00	\$40.00	\$200.00	0.14	312.4	\$55.92	3.58
242.11		2200	1	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	107	0.11	235.4	\$42.14	1	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.10	215.6	\$38.59	\$28.00	\$10.00	\$28.00	0.01	19.8	\$3.54	7.90
142.11	Women's Rest Room	2200	1	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.16	343.2	\$61.43	1	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	85	0.09	187	\$33.47	\$100.00	\$20.00	\$100.00	0.07	156.2	\$27.96	3.58
242.11		2200	3	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	107	0.32	706.2	\$126.41	3	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.29	646.8	\$115.78	\$28.00	\$30.00	\$84.00	0.03	59.4	\$10.63	7.90
242.11	Snack Stand	2200	2	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	107	0.21	470.8	\$84.27	2	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	431.2	\$77.18	\$28.00	\$20.00	\$56.00	0.02	39.6	\$7.09	7.90
613	Pump Room	2200	2	1	Socket , 100w A19 Lamp	100	0.20	440.0	\$78.76	2	1	(1) 26w CFL Lamp	26	0.05	114.4	\$20.48	\$20.00	\$14.00	\$40.00	0.15	325.6	\$58.28	0.69
619	Exterior	4400	1	1	Ceiling Mount Globe, (1) 100w A19 Lamp	100	0.10	440.0	\$78.76	1	1	(1) 26w CFL Lamp	26	0.03	114.4	\$20.48	\$20.00	\$7.00	\$20.00	0.07	325.6	\$58.28	0.34
710		4400	3	1	100w HPS Flood Light	125	0.38	1,650.0	\$295.35	3	0	No Change	125	0.38	1,650	\$295.35	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
<b>Totals</b>			16	27		1.94	5,144	\$921		16	23			1.4	3,827	\$685		\$161.00	\$628	0.6	1,317	\$236	2.66

## Investment Grade Lighting Audit

CEG Job #: 9C10076

Project: Public Works Building

1729 Erial Road

Gloucester Township, NJ

Bldg. Sq. Ft.

Public Works Building

KWH COST: \$0.180

### ECM: Lighting Upgrade - General

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Installed Cost	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
237.22	Front Office	2600	14	3	2x2, 3 Lamp, FT40DL/835/RS 40w CFL, Elect. Ballast, Recessed Mnt., Parabolic Lens	110	1.54	4,004.0	\$720.72	14	0	No Change	110	1.54	4004	\$720.72	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Hall	8736	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	2,271.4	\$408.84	4	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	1712.256	\$308.21	\$100.00	\$0.00	\$100.00	0.06	559.104	\$100.64	0.99
237.22	Lobby	2600	4	3	2x2, 3 Lamp, FT40DL/835/RS 40w CFL, Elect. Ballast, Recessed Mnt., Parabolic Lens	110	0.44	1,144.0	\$205.92	4	0	No Change	110	0.44	1144	\$205.92	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
563		2600	3	1	Recessed Down Light, 26w PL Lamp	26	0.08	202.8	\$36.50	3	0	No Change	26	0.08	202.8	\$36.50	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
237.22	Vestibule	2600	2	3	2x2, 3 Lamp, FT40DL/835/RS 40w CFL, Elect. Ballast, Recessed Mnt., Parabolic Lens	110	0.22	572.0	\$102.96	2	0	No Change	110	0.22	572	\$102.96	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.34	Mechanical Room	1200	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	62	0.25	297.6	\$53.57	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	240	\$43.20	\$56.00	\$40.00	\$16.00	0.05	57.6	\$10.37	1.54
227.21	Hall	8736	3	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.20	1,703.5	\$306.63	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	1284.192	\$231.15	\$75.00	\$0.00	\$75.00	0.05	419.328	\$75.48	0.99
237.21	Conference Room	350	6	3	2x2, 3 Lamp, FT40DL/835/RS 40w CFL, Elect. Ballast, Recessed Mnt., Parabolic Lens	110	0.66	231.0	\$41.58	6	0	No Change	110	0.66	231	\$41.58	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
237.21	105 Director's Office	2600	6	3	2x2, 3 Lamp, FT40DL/835/RS 40w CFL, Elect. Ballast, Recessed Mnt., Parabolic Lens	110	0.66	1,716.0	\$308.88	6	0	No Change	110	0.66	1716	\$308.88	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Electrical Room	8736	2	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.13	1,135.7	\$204.42	2	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	856.128	\$154.10	\$50.00	\$0.00	\$50.00	0.03	279.552	\$50.32	0.99
227.21	Hall	2348	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	610.5	\$109.89	4	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	460.208	\$82.84	\$100.00	\$0.00	\$100.00	0.06	150.272	\$27.05	3.70
237.22	Supervisor's Office	1200	8	3	2x2, 3 Lamp, FT40DL/835/RS 40w CFL, Elect. Ballast, Recessed Mnt., Parabolic Lens	110	0.88	1,056.0	\$190.08	8	0	No Change	110	0.88	1056	\$190.08	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	110 Lunch Room	8736	7	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.46	3,974.9	\$715.48	7	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.34	2996.448	\$539.36	\$175.00	\$0.00	\$175.00	0.11	978.432	\$176.12	0.99
227.21	Hall	3000	6	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.39	1,170.0	\$210.60	6	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	882	\$158.76	\$150.00	\$0.00	\$150.00	0.10	288	\$51.84	2.89
746	M109 Building Maintenance	2600	4	1	250w MH LoBay w/Prismatic Lens	295	1.18	3,068.0	\$552.24	4	3	2x4 54w T5HO 3 Lamp, Prismatic Lens	177	0.71	1840.8	\$331.34	\$880.00	\$200.00	\$680.00	0.47	1227.2	\$220.90	3.08

## Investment Grade Lighting Audit

EXISTING LIGHTING					PROPOSED LIGHTING													SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Installed Cost	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
221.34	Mezzanine	1200	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	62	0.25	297.6	\$53.57	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	240	\$43.20	\$56.00	\$40.00	\$16.00	0.05	57.6	\$10.37	1.54
221.34	Parts - Under Mezzanine	3640	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	62	0.25	902.7	\$162.49	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	728	\$131.04	\$56.00	\$40.00	\$16.00	0.05	174.72	\$31.45	0.51
227.21	Men's Locker Room	3640	5	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.33	1,183.0	\$212.94	5	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.25	891.8	\$160.52	\$125.00	\$0.00	\$125.00	0.08	291.2	\$52.42	2.38
227.21	Men's Showers	3640	3	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.20	709.8	\$127.76	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	535.08	\$96.31	\$75.00	\$0.00	\$75.00	0.05	174.72	\$31.45	2.38
227.21	Women's Locker Room & Showers	3640	4	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.26	946.4	\$170.35	4	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	713.44	\$128.42	\$100.00	\$0.00	\$100.00	0.06	232.96	\$41.93	2.38
746	Tool Storage	2600	6	1	250w MH LoBay w/Prismatic Lens	295	1.77	4,602.0	\$828.36	6	3	2x4 54w T5HO 3 Lamp, Prismatic Lens	177	1.06	2761.2	\$497.02	\$1,320.00	\$300.00	\$1,020.00	0.71	1840.8	\$331.34	3.08
221.34	Mezzanine	2600	6	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	62	0.37	967.2	\$174.10	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.30	780	\$140.40	\$84.00	\$60.00	\$24.00	0.07	187.2	\$33.70	0.71
221.34	Parts - Under Mezzanine	2600	4	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	62	0.25	644.8	\$116.06	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	520	\$93.60	\$56.00	\$40.00	\$16.00	0.05	124.8	\$22.46	0.71
232.21	Restroom	2600	22	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	1.89	4,919.2	\$885.46	22	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	74	1.63	4232.8	\$761.90	\$462.00	\$220.00	\$242.00	0.26	686.4	\$123.55	1.96
746	Vehicle Maintenance	3000	19	1	250w MH LoBay w/Prismatic Lens	295	5.61	16,815.0	\$3,026.70	19	3	2x4 54w T5HO 3 Lamp, Prismatic Lens	177	3.36	10089	\$1,816.02	\$4,180.00	\$950.00	\$3,230.00	2.24	6726	\$1,210.68	2.67
221.34		3000	6	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	62	0.37	1,116.0	\$200.88	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.30	900	\$162.00	\$84.00	\$60.00	\$24.00	0.07	216	\$38.88	0.62
232.21	M105 Supervisor's Office	3000	1	3	2x4, 3 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	86	0.09	258.0	\$46.44	1	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	74	0.07	222	\$39.96	\$21.00	\$10.00	\$11.00	0.01	36	\$6.48	1.70
227.21		3000	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	195.0	\$35.10	1	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	147	\$26.46	\$25.00	\$0.00	\$25.00	0.02	48	\$8.64	2.89
221.34	Compressor Room	3000	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	62	0.12	372.0	\$66.96	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	300	\$54.00	\$28.00	\$20.00	\$8.00	0.02	72	\$12.96	0.62
746	Parts Bay	3000	2	1	250w MH LoBay w/Prismatic Lens	295	0.59	1,770.0	\$318.60	2	3	2x4 54w T5HO 3 Lamp, Prismatic Lens	177	0.35	1062	\$191.16	\$440.00	\$100.00	\$340.00	0.24	708	\$127.44	2.67
221.34		3000	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Pendant Mnt., No Lens	62	0.06	186.0	\$33.48	1	0	Remove Fixture	50	0.05	150	\$27.00	\$14.00	\$10.00	\$4.00	0.01	36.0	\$6.48	0.62
221.45	M103 Janitor	800	1	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Wall Mnt., No Lens	62	0.06	49.6	\$8.93	1	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.05	40	\$7.20	\$14.00	\$10.00	\$4.00	0.01	9.6	\$1.73	2.31
227.21	Men's Restroom	2600	1	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.07	169.0	\$30.42	1	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	127.4	\$22.93	\$25.00	\$0.00	\$25.00	0.02	41.6	\$7.49	3.34
227.21	Women's Restroom	2600	5	2	2x2, 2 Lamp, 32w 700 series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	65	0.33	845.0	\$152.10	5	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.25	637	\$114.66	\$125.00	\$0.00	\$125.00	0.08	208	\$37.44	3.34
711	Exterior	4400	4	1	70w HPS Bollards	92	0.37	1,619.2	\$291.46	4	0	No Change	92	0.37	1619.2	\$291.46	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
750		4400	19	1	250w HPS Wallpack	295	5.61	24,662.0	\$4,439.16	19	0	No Change	295	5.61	24662	\$4,439.16	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
767		4400	30	1	400w Probe Start MH "Shoobox" Parking Lot Light	460	13.80	60,720.0	\$10,929.60	30	1	Venture Lighting Optiwave Ballast V90U7421K and 320w MH Lamp	349	10.47	46068	\$8,292.24	\$7,500.00	\$750.00	\$6,750.00	3.33	14652	\$2,637.36	2.56

## Investment Grade Lighting Audit

EXISTING LIGHTING					PROPOSED LIGHTING										SAVINGS								
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Installed Cost	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
601	Exit Signage	8760	14	2	(2) 7w CFL Exit Sign	16	0.22	1,962.2	\$353.20	14	1	LED Exit Sign	2	0.03	245.28	\$44.15	\$910.00	\$0.00	\$910.00	0.20	1716.96	\$309.05	2.94
<b>Old Public Works Building</b>																							
242.11	Lobby	800	2	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	107	0.21	171.2	\$30.82	2	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	156.8	\$28.22	\$56.00	\$20.00	\$36.00	0.02	14.4	\$2.59	13.89
242.11	Hall	800	2	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	107	0.21	171.2	\$30.82	2	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	156.8	\$28.22	\$56.00	\$20.00	\$36.00	0.02	14.4	\$2.59	13.89
3015	Restroom	200	1	1	Wall Mnt., Glass Cover, 100w A Lamp	100	0.10	20.0	\$3.60	1	1	26w CFL Lamp	26	0.03	5.2	\$0.94	\$20.00	\$0.00	\$20.00	0.07	14.8	\$2.66	7.51
242.11	Reception	800	2	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	107	0.21	171.2	\$30.82	2	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	156.8	\$28.22	\$56.00	\$20.00	\$36.00	0.02	14.4	\$2.59	13.89
625	Restroom	200	1	2	Fan/Light Combo (2) 100w A Lamp	200	0.20	40.0	\$7.20	1	2	(1) 18w CFL Lamp	36	0.04	7.2	\$1.30	\$20.00	\$0.00	\$20.00	0.16	32.8	\$5.90	3.39
142.11	Front Office	800	2	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.31	249.6	\$44.93	2	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.14	115.2	\$20.74	\$200.00	\$20.00	\$180.00	0.17	134.4	\$24.19	7.44
551	Utility Room	200	1	1	Recessed Down Light, 100w A Lamp	100	0.10	20.0	\$3.60	1	1	26w CFL Lamp	26	0.03	5.2	\$0.94	\$20.00	\$0.00	\$20.00	0.07	14.8	\$2.66	7.51
242.11	Locker/ Lunch Room	800	6	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Surface Mnt., Prismatic Lens	107	0.64	513.6	\$92.45	6	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.59	470.4	\$84.67	\$168.00	\$60.00	\$108.00	0.05	43.2	\$7.78	13.89
142.11		800	5	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	0.78	624.0	\$112.32	5	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.36	288	\$51.84	\$500.00	\$50.00	\$450.00	0.42	336	\$60.48	7.44
625	Restroom	200	1	2	Fan/Light Combo (2) 100w A Lamp	200	0.20	40.0	\$7.20	1	2	(1) 18w CFL Lamp	36	0.04	7.2	\$1.30	\$20.00	\$0.00	\$20.00	0.16	32.8	\$5.90	3.39
142.11	Files	800	8	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	1.25	998.4	\$179.71	8	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.58	460.8	\$82.94	\$800.00	\$80.00	\$720.00	0.67	537.6	\$96.77	7.44
3015	Restroom	200	1	1	Wall Mnt., Glass Cover, 100w A Lamp	100	0.10	20.0	\$3.60	1	1	26w CFL Lamp	26	0.03	5.2	\$0.94	\$20.00	\$0.00	\$20.00	0.07	14.8	\$2.66	7.51
142.11	Garage Bay	1200	8	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Surface Mnt., Prismatic Lens	156	1.25	1,497.6	\$269.57	8	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.58	691.2	\$124.42	\$800.00	\$80.00	\$720.00	0.67	806.4	\$145.15	4.96
121.14	Large Garage Bays	1200	1	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., No Lens	78	0.08	93.6	\$16.85	1	2	2 Lamp, 32w T8, Elect. Ballast; retrofit	58	0.06	69.6	\$12.53	\$100.00	\$0.00	\$100.00	0.02	24	\$4.32	23.15
128.14		1200	12	2	8' Channel, 2 Lamp, 75w T12, Mag. Ballast, Surface Mnt., No Lens	142	1.70	2,044.8	\$368.06	12	4	(2) 8' Lamps to (4) 4' Lamps - 28w T8, Elect Ballast; retrofit	96	1.15	1382.4	\$248.83	\$1,200.00	\$0.00	\$1,200.00	0.55	662.4	\$119.23	10.06
<b>Totals</b>			227	74			40.28	155,744	\$26,479	227	59			31.9	120,847	\$20,992	\$16,376	\$2,850	\$13,526	8.4	30,483	\$5,487	2.47

CEG Job #: 9C10076

Project: Public Works Building  
 Address: 1729 Erial Road  
 Gloucester Township, NJ  
 Building SF: -

Public Works Building

KWH COST: \$0.180

**ECM: Lighting Controls**

EXISTING LIGHTING					PROPOSED LIGHTING CONTROLS												SAVINGS						
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
237.22	Front Office	2600	14	0	No Change	110	1.54	4004	\$720.72	14	1	Dual Technology Occupancy Sensor - Remote Mnt.	110	1.31	15%	3403.4	\$612.61	\$160.00	\$160.00	0.23	600.6	\$108.11	1.48
227.21	Hall	8736	4	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	1712.256	\$308.21	4	1	Dual Technology Occupancy Sensor - Remote Mnt.	49	0.04	82%	308.20608	\$55.48	\$160.00	\$160.00	0.16	1404.04992	\$252.73	0.63
237.22	Lobby	2600	4	0	No Change	110	0.44	1144	\$205.92	4	0	No Change	110	0.44	0%	1144	\$205.92	\$0.00	\$0.00	0.00	0	\$0.00	0.00
563	0	2600	3	0	No Change	26	0.08	202.8	\$36.50	3	0	No Change	26	0.08	0%	202.8	\$36.50	\$0.00	\$0.00	0.00	0	\$0.00	0.00
237.22	Vestibule	2600	2	0	No Change	110	0.22	572	\$102.96	2	0	No Change	110	0.22	0%	572	\$102.96	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.34	Mechanical Room	1200	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	240	\$43.20	4	0	No Change	50	0.20	0%	240	\$43.20	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Hall	8736	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	1284.192	\$231.15	3	1	Dual Technology Occupancy Sensor - Remote Mnt.	49	0.03	82%	231.15456	\$41.61	\$160.00	\$160.00	0.12	1053.03744	\$189.55	0.84
237.21	Conference Room	350	6	0	No Change	110	0.66	231	\$41.58	6	1	Dual Technology Occupancy Sensor - Switch Mnt.	110	0.30	54%	106.26	\$19.13	\$75.00	\$75.00	0.36	124.74	\$22.45	3.34
237.21	105 Director's Office	2600	6	0	No Change	110	0.66	1716	\$308.88	6	0	No Change	110	0.66	0%	1716	\$308.88	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Electrical Room	8736	2	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.10	856.128	\$154.10	2	1	Dual Technology Occupancy Sensor - Remote Mnt.	49	0.02	82%	154.10304	\$27.74	\$160.00	\$160.00	0.08	702.02496	\$126.36	1.27
227.21	Hall	2348	4	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	460.208	\$82.84	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.17	13%	400.38096	\$72.07	\$75.00	\$75.00	0.03	59.82704	\$10.77	6.96
237.22	Supervisor's Office	1200	8	0	No Change	110	0.88	1056	\$190.08	8	1	Dual Technology Occupancy Sensor - Remote Mnt.	110	0.69	22%	823.68	\$148.26	\$160.00	\$160.00	0.19	232.32	\$41.82	3.83
227.21	110 Lunch Room	8736	7	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.34	2996.448	\$539.36	7	1	Dual Technology Occupancy Sensor - Remote Mnt.	49	0.06	82%	539.36064	\$97.08	\$160.00	\$160.00	0.28	2457.08736	\$442.28	0.36
227.21	Hall	3000	6	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.29	882	\$158.76	6	0	No Change	49	0.29	0%	882	\$158.76	\$0.00	\$0.00	0.00	0	\$0.00	0.00
746	M109 Building Maintenance	2600	4	3	2x4 54w TSHO 3 Lamp, Prismatic Lens	177	0.71	1840.8	\$331.34	4	0	No Change	177	0.71	0%	1840.8	\$331.34	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.34	Mezzanine	1200	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	240	\$43.20	4	1	Dual Technology Occupancy Sensor - Remote Mnt.	50	0.16	20%	192	\$34.56	\$160.00	\$160.00	0.04	48	\$8.64	18.52
221.34	Parts - Under Mezzanine	3640	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	728	\$131.04	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	50	0.16	20%	582.4	\$104.83	\$75.00	\$75.00	0.04	145.6	\$26.21	2.86
227.21	Men's Locker Room	3640	5	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.25	891.8	\$160.52	5	0	No Change	49	0.25	0%	891.8	\$160.52	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Men's Showers	3640	3	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.15	535.08	\$96.31	3	1	Dual Technology Occupancy Sensor - Switch Mnt.	49	0.12	20%	428.064	\$77.05	\$75.00	\$75.00	0.03	107.016	\$19.26	3.89
227.21	Women's Locker Room & Showers	3640	4	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.20	713.44	\$128.42	4	0	No Change	49	0.20	0%	713.44	\$128.42	\$0.00	\$0.00	0.00	0	\$0.00	0.00
746	Tool Storage	2600	6	3	2x4 54w TSHO 3 Lamp, Prismatic Lens	177	1.06	2761.2	\$497.02	6	1	Dual Technology Occupancy Sensor - Remote Mnt.	177	0.85	20%	2208.96	\$397.61	\$160.00	\$160.00	0.21	552.24	\$99.40	1.61
221.34	Mezzanine	2600	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.30	780	\$140.40	6	1	Dual Technology Occupancy Sensor - Remote Mnt.	50	0.24	20%	624	\$112.32	\$160.00	\$160.00	0.06	156	\$28.08	5.70
221.34	Parts - Under Mezzanine	2600	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	520	\$93.60	4	0	No Change	50	0.20	0%	520	\$93.60	\$0.00	\$0.00	0.00	0	\$0.00	0.00
232.21	Restroom	2600	22	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	74	1.63	4232.8	\$761.90	22	0	No Change	74	1.63	0%	4232.8	\$761.90	\$0.00	\$0.00	0.00	0	\$0.00	0.00
746	Vehicle Maintenance	3000	19	3	2x4 54w TSHO 3 Lamp, Prismatic Lens	177	3.36	10089	\$1,816.02	19	0	No Change	177	3.36	0%	10089	\$1,816.02	\$0.00	\$0.00	0.00	0	\$0.00	0.00

EXISTING LIGHTING					PROPOSED LIGHTING CONTROLS													SAVINGS					
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
221.34	0	3000	6	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.30	900	\$162.00	6	0	No Change	50	0.30	0%	900	\$162.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
232.21	M105 Supervisor's Office	3000	1	3	Relamp - Sylvania Lamp FO28/841/SS/ECO	74	0.07	222	\$39.96	1	0	No Change	74	0.07	0%	222	\$39.96	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	0	3000	1	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	147	\$26.46	1	0	No Change	49	0.05	0%	147	\$26.46	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.34	Compressor Room	3000	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	300	\$54.00	2	0	No Change	50	0.10	0%	300	\$54.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
746	Parts Bay	3000	2	3	2x4 54w TSHO 3 Lamp, Prismatic Lens	177	0.35	1062	\$191.16	2	0	No Change	177	0.35	0%	1062	\$191.16	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.34	0	3000	1	0	Remove Fixture	50	0.05	150	\$27.00	1	0	No Change	50	0.05	0%	150	\$27.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
221.45	M103 Janitor	800	1	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.05	40	\$7.20	1	0	No Change	50	0.05	0%	40	\$7.20	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Men's Restroom	2600	1	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.05	127.4	\$22.93	1	0	No Change	49	0.05	0%	127.4	\$22.93	\$0.00	\$0.00	0.00	0	\$0.00	0.00
227.21	Women's Restroom	2600	5	2	Sylvania Lamp FBO30/841XP/6/SS/ECO	49	0.25	637	\$114.66	5	0	No Change	49	0.25	0%	637	\$114.66	\$0.00	\$0.00	0.00	0	\$0.00	0.00
711	Exterior	4400	4	0	No Change	92	0.37	1619.2	\$291.46	4	0	No Change	92	0.37	0%	1619.2	\$291.46	\$0.00	\$0.00	0.00	0	\$0.00	0.00
750	0	4400	19	0	No Change	295	5.61	24662	\$4,439.16	19	0	No Change	295	5.61	0%	24662	\$4,439.16	\$0.00	\$0.00	0.00	0	\$0.00	0.00
767	0	4400	30	1	Venture Lighting Optiwave Ballast V90U7421K and 320w MH Lamp	349	10.47	46068	\$8,292.24	30	0	No Change	349	10.47	0%	46068	\$8,292.24	\$0.00	\$0.00	0.00	0	\$0.00	0.00
601	Exit Signage	8760	14	1	LED Exit Sign	2	0.03	245.28	\$44.15	14	0	No Change	2	0.03	0%	245.28	\$44.15	\$0.00	\$0.00	0.00	0	\$0.00	0.00
Old Public Works Building	0	0	0	0	0	0	0.00	0	\$0.00	0	0	No Change	0	0.00	0%	0	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
242.11	Lobby	800	2	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	156.8	\$28.22	2	0	No Change	98	0.20	0%	156.8	\$28.22	\$0.00	\$0.00	0.00	0	\$0.00	0.00
242.11	Hall	800	2	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	156.8	\$28.22	2	0	No Change	98	0.20	0%	156.8	\$28.22	\$0.00	\$0.00	0.00	0	\$0.00	0.00
3015	Restroom	200	1	1	26w CFL Lamp	26	0.03	5.2	\$0.94	1	0	No Change	26	0.03	0%	5.2	\$0.94	\$0.00	\$0.00	0.00	0	\$0.00	0.00
242.11	Reception	800	2	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.20	156.8	\$28.22	2	0	No Change	98	0.20	0%	156.8	\$28.22	\$0.00	\$0.00	0.00	0	\$0.00	0.00
625	Restroom	200	1	2	(1) 18w CFL Lamp	36	0.04	7.2	\$1.30	1	0	No Change	36	0.04	0%	7.2	\$1.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.11	Front Office	800	2	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.14	115.2	\$20.74	2	0	No Change	72	0.14	0%	115.2	\$20.74	\$0.00	\$0.00	0.00	0	\$0.00	0.00
551	Utility Room	200	1	1	26w CFL Lamp	26	0.03	5.2	\$0.94	1	0	No Change	26	0.03	0%	5.2	\$0.94	\$0.00	\$0.00	0.00	0	\$0.00	0.00
242.11	Locker/ Lunch Room	800	6	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	0.59	470.4	\$84.67	6	0	No Change	98	0.59	0%	470.4	\$84.67	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.11	0	800	5	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.36	288	\$51.84	5	0	No Change	72	0.36	0%	288	\$51.84	\$0.00	\$0.00	0.00	0	\$0.00	0.00
625	Restroom	200	1	2	(1) 18w CFL Lamp	36	0.04	7.2	\$1.30	1	0	No Change	36	0.04	0%	7.2	\$1.30	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.11	Files	800	8	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.58	460.8	\$82.94	8	0	No Change	72	0.58	0%	460.8	\$82.94	\$0.00	\$0.00	0.00	0	\$0.00	0.00
3015	Restroom	200	1	1	26w CFL Lamp	26	0.03	5.2	\$0.94	1	0	No Change	26	0.03	0%	5.2	\$0.94	\$0.00	\$0.00	0.00	0	\$0.00	0.00
142.11	Garage Bay	1200	8	3	Delamp 1, Reballast & Relamp; (3) Sylvania Lamp FO28/841/SS/ECO	72	0.58	691.2	\$124.42	8	0	No Change	72	0.58	0%	691.2	\$124.42	\$0.00	\$0.00	0.00	0	\$0.00	0.00
121.14	Large Garage Bays	1200	1	2	2 Lamp, 32w T8, Elect. Ballast; retrofit	58	0.06	69.6	\$12.53	1	1	No Change	58	0.06	0%	69.6	\$12.53	\$0.00	\$0.00	0.00	0	\$0.00	0.00
128.14	0	1200	12	4	(2) 8' Lamps to (4) 4' Lamps - 28w T8, Elect Ballast; retrofit	96	1.15	1382.4	\$248.83	12	2	No Change	96	1.15	0%	1382.4	\$248.83	\$0.00	\$0.00	0.00	0	\$0.00	0.00
	Totals		227	74			34.9	120,847.0	\$21,491	281	13			33.1		113,204.5	\$20,115.45		\$1,740	1.83	7,643	\$1,376	1.26

## Investment Grade Lighting Audit

CEG Job #: 1C11039

Project: Recreation Center

Recreation Center

KWH COST: \$0.181

### ECM: Lighting Upgrade - General

EXISTING LIGHTING					PROPOSED LIGHTING										SAVINGS						In Scope (D)			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Incentive	Total Cost	kW Savings		kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
1142.21	Hockey Rink	2340	4	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.31	730.1	\$132.14	4	2	T8 2 Lamp w/Electronic Ballast & Reflector	55	0.22	514.8	\$93.18	\$68.71	\$80.00	\$274.84	0.09	215.28	\$38.97	7.05	D
121.14		2340	10	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Surface Mnt., No Lens	78	0.78	1,825.2	\$330.36	10	2	2 Lamp, 32w T8, Elect. Ballast; retrofit	58	0.58	1357.2	\$245.65	\$100.00	\$0.00	\$1,000.00	0.20	468	\$84.71	11.81	
771		2340	43	2	400w MH & 250 HPS Indirect Lighting	760	32.68	76,471.2	\$13,841.29	43	6	2x4, 6 Lamp, 32w T8, Elect. Ballast, Lo Bay w/Wire Guard	220	9.46	22136.4	\$4,006.69	\$260.00	\$0.00	\$11,180.00	23.22	54334.8	\$9,834.60	1.14	
1601		8760	6	2	(2) 7w CFL Exit Sign	16	0.10	841.0	\$152.21	6	1	LED Exit Sign	2	0.01	105.12	\$19.03	\$132.46	\$60.00	\$794.76	0.08	735.84	\$133.19	5.97	D
1121.14	Games Storage	3796	8	1	Square, Wall Mntd. Down Light, 75w R30	75	0.60	2,277.6	\$412.25	8	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.21	789.568	\$142.91	\$20.00	\$0.00	\$160.00	0.39	1488.032	\$269.33	0.59	D
1121.14	Electrical Room	2200	8	1	Square, Wall Mntd. Down Light, 75w R30	75	0.60	1,320.0	\$238.92	8	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.21	457.6	\$82.83	\$20.00	\$0.00	\$160.00	0.39	862.4	\$156.09	1.03	D
1132.21	Lobby	2340	6	3	2x4, 3-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	127	0.76	1,783.1	\$322.74	6	3	T8 3 Lamp w/Electronic Ballast & Reflector	84	0.50	1179.36	\$213.46	\$277.42	\$120.00	\$1,664.52	0.26	603.72	\$109.27	15.23	D
1601		8760	2	2	(2) 7w CFL Exit Sign	16	0.03	280.3	\$50.74	2	1	LED Exit Sign	2	0.00	35.04	\$6.34	\$132.46	\$20.00	\$264.92	0.03	245.28	\$44.40	5.97	D
D142.21	Vestibule	2340	2	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	156	0.31	730.1	\$132.14	2	3	T8 3 Lamp w/Electronic Ballast & Reflector	84	0.17	393.12	\$71.15	\$277.42	\$40.00	\$554.84	0.14	336.96	\$60.99	9.10	D
1601		8760	2	2	(2) 7w CFL Exit Sign	16	0.03	280.3	\$50.74	2	1	LED Exit Sign	2	0.00	35.04	\$6.34	\$132.46	\$20.00	\$264.92	0.03	245.28	\$44.40	5.97	D
1132.21	Business Office/ Reception Area	2080	4	3	2x4, 3-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	127	0.51	1,056.6	\$191.25	4	3	T8 3 Lamp w/Electronic Ballast & Reflector	84	0.34	698.88	\$126.50	\$277.42	\$80.00	\$1,109.68	0.17	357.76	\$64.75	17.14	D
1142.21	Break Room	2080	2	2	1x4, 2-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	78	0.16	324.5	\$58.73	2	2	T8 2 Lamp w/Electronic Ballast & Reflector	55	0.11	228.8	\$41.41	\$68.71	\$40.00	\$137.42	0.05	95.68	\$17.32	7.94	D
1132.21	Business Office	2080	4	3	2x4, 3-Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	127	0.51	1,056.6	\$191.25	4	3	T8 3 Lamp w/Electronic Ballast & Reflector	84	0.34	698.88	\$126.50	\$277.42	\$80.00	\$1,109.68	0.17	357.76	\$64.75	17.14	D
550		2080	1	1	Recessed Down Light, 50w MH Lamp	70	0.07	145.6	\$26.35	1	1	Bypass ballast. Install socket adapter and 26w CFL Flood Lamp	26	0.03	54.08	\$9.79	\$30.00	\$0.00	\$30.00	0.04	91.52	\$16.57	1.81	
D142.21	Ticket Office	3400	1	4	2x4, 4 Lamp, 34w T12, Mag. Ballast, Recessed Mnt., Prismatic Lens	156	0.16	530.4	\$96.00	1	3	T8 3 Lamp w/Electronic Ballast & Reflector	84	0.08	285.6	\$51.69	\$277.42	\$20.00	\$277.42	0.07	244.8	\$44.31	6.26	D
1122.21	Men's Rest Room	2340	3	1	Square, Wall Mntd. Down Light, 75w R30	75	0.23	526.5	\$95.30	3	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.08	182.52	\$33.04	\$20.00	\$0.00	\$60.00	0.15	343.98	\$62.26	0.96	D
1121.21		2340	6	1	Square, Wall Mntd. Down Light, 75w R30	75	0.45	1,053.0	\$190.59	6	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.16	365.04	\$66.07	\$20.00	\$0.00	\$120.00	0.29	687.96	\$124.52	0.96	D
1122.21	Women's Rest Room	2340	3	1	Square, Wall Mntd. Down Light, 75w R30	75	0.23	526.5	\$95.30	3	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.08	182.52	\$33.04	\$20.00	\$0.00	\$60.00	0.15	343.98	\$62.26	0.96	D
1121.21		2340	6	1	Square, Wall Mntd. Down Light, 75w R30	75	0.45	1,053.0	\$190.59	6	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.16	365.04	\$66.07	\$20.00	\$0.00	\$120.00	0.29	687.96	\$124.52	0.96	D
750	Exterior	4400	6	1	250w HPS Wallpack	295	1.77	7,788.0	\$1,409.63	6	0	No Change	295	1.77	7788	\$1,409.63	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
767		4400	6	1	400w Probe Start MH "Shoebbox" Parking Lot Light	460	2.76	12,144.0	\$2,198.06	6	1	Venture Lighting Optiwave Ballast V90U7421K and 320w MH Lamp	349	2.09	9213.6	\$1,667.66	\$160.00	\$0.00	\$960.00	0.67	2930.4	\$530.40	1.81	
705		4400	2	1	70w MH, Architectural Wall Mnt.	92	0.18	809.6	\$146.54	2	0	No Change	92	0.18	809.6	\$146.54	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
705		4400	11	1	70w MH, Architectural Wall Mnt.	92	1.01	4,452.8	\$805.96	11	0	No Change	92	1.01	4452.8	\$805.96	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00	
<b>Totals</b>			146	40			44.68	118,006	\$21,359	146	38			17.8	52,329	\$9,471			\$20,303	26.9	65,677	\$11,888	1.71	



ECM: Lighting Controls

EXISTING LIGHTING					PROPOSED LIGHTING CONTROLS										SAVINGS								
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
1142.21	Hockey Rink	2340	4	2	T8 2 Lamp w/Electronic Ballast & Reflector	55	0.22	514.8	\$93.18	4	0	No Change	55	0.22	0%	514.8	\$93.18	\$0.00	\$0.00	0.00	0	\$0.00	0.00
121.14		2340	10	2	2 Lamp, 32w T8, Elect. Ballast, retrofit	58	0.58	1357.2	\$245.65	10	0	No Change	58	0.58	0%	1357.2	\$245.65	\$0.00	\$0.00	0.00	0	\$0.00	0.00
771		2340	43	6	2x4, 6 Lamp, 32w T8, Elect. Ballast, Lo Bay w/Wire Guard	220	9.46	22136.4	\$4,006.69	43	0	Packaged Occupancy Sensor Option w/ New Fixture in ECM #1	220	7.57	20%	17709.12	\$3,205.35	\$50.00	\$2,150.00	1.89	4427.28	\$801.34	2.68
1601		8760	6	2	LED Exit Sign	2	0.01	105.12	\$19.03	6	0	No Change	2	0.01	0%	105.12	\$19.03	\$0.00	\$0.00	0.00	0	\$0.00	0.00
1121.14	Games Storage	3796	8	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.21	789.568	\$142.91	8	1	Dual Technology Occupancy Sensor - Switch Mnt.	26	0.03	86%	110.53952	\$20.01	\$75.00	\$75.00	0.18	679.02848	\$122.90	0.61
1121.14	Electrical Room	2200	8	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.21	457.6	\$82.83	8	1	Dual Technology Occupancy Sensor - Switch Mnt.	26	0.10	54%	210.496	\$38.10	\$75.00	\$75.00	0.11	247.104	\$44.73	1.68
1132.21	Lobby	2340	6	3	T8 3 Lamp w/Electronic Ballast & Reflector	84	0.50	1179.36	\$213.46	6	0	No Change	84	0.50	0%	1179.36	\$213.46	\$0.00	\$0.00	0.00	0	\$0.00	0.00
1601		8760	2	2	LED Exit Sign	2	0.00	35.04	\$6.34	2	0	No Change	2	0.00	0%	35.04	\$6.34	\$75.00	\$0.00	0.00	0	\$0.00	0.00
D142.21	Vestibule	2340	2	4	T8 3 Lamp w/Electronic Ballast & Reflector	84	0.17	393.12	\$71.15	2	0	No Change	84	0.17	0%	393.12	\$71.15	\$0.00	\$0.00	0.00	0	\$0.00	0.00
1601		8760	2	2	LED Exit Sign	2	0.00	35.04	\$6.34	2	0	No Change	2	0.00	0%	35.04	\$6.34	\$0.00	\$0.00	0.00	0	\$0.00	0.00
1132.21	Business Office/ Reception Area	2080	4	3	T8 3 Lamp w/Electronic Ballast & Reflector	84	0.34	698.88	\$126.50	4	1	Dual Technology Occupancy Sensor - Switch Mnt.	84	0.33	3%	677.9136	\$122.70	\$75.00	\$75.00	0.01	20.9664	\$3.79	19.76
1142.21	Break Room	2080	2	2	T8 2 Lamp w/Electronic Ballast & Reflector	55	0.11	228.8	\$41.41	2	1	Dual Technology Occupancy Sensor - Switch Mnt.	55	0.11	3%	221.936	\$40.17	\$75.00	\$75.00	0.00	6.864	\$1.24	60.37
1132.21	Business Office	2080	4	3	T8 3 Lamp w/Electronic Ballast & Reflector	84	0.34	698.88	\$126.50	4	1	Install	84	0.33	3%	677.9136	\$122.70	\$75.00	\$75.00	0.01	20.9664	\$3.79	19.76
550		2080	1	1	Bypass ballast. Install socket adapter and 26w CFL Flood Lamp	26	0.03	54.08	\$9.79	1	0	No Change	26	0.03	0%	54.08	\$9.79	\$0.00	\$0.00	0.00	0	\$0.00	0.00
D142.21	Ticket Office	3400	1	4	T8 3 Lamp w/Electronic Ballast & Reflector	84	0.08	285.6	\$51.69	1	1	Dual Technology Occupancy Sensor - Remote Mnt.	84	0.07	20%	228.48	\$41.35	\$160.00	\$160.00	0.02	57.12	\$10.34	15.48
1122.21	Men's Rest Room	2340	3	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.08	182.52	\$33.04	3	1	Dual Technology Occupancy Sensor - Remote Mnt.	26	0.02	70%	54.756	\$9.91	\$160.00	\$160.00	0.05	127.764	\$23.13	2.31
1121.21		2340	6	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.16	365.04	\$66.07	6			26	0.05	70%	109.512	\$19.82		\$0.00	0.11	255.528	\$46.25	
1122.21	Women's Rest Room	2340	3	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.08	182.52	\$33.04	3	1	Dual Technology Occupancy Sensor - Remote Mnt.	26	0.02	70%	54.756	\$9.91	\$160.00	\$160.00	0.05	127.764	\$23.13	2.31
1121.21		2340	6	1	Energy Star Rated, Dimmable 26w CFL Lamp	26	0.16	365.04	\$66.07	6			26	0.05	70%	109.512	\$19.82		\$0.00	0.11	255.528	\$46.25	
750	Exterior	4400	6	1	No Change	295	1.77	7788	\$1,409.63	6	0	No Change	295	1.77	0%	7788	\$1,409.63	\$0.00	\$0.00	0.00	0	\$0.00	0.00
767		4400	6	1	Venture Lighting Optiwave Ballast V90U7421K and 320w MH Lamp	349	2.09	9213.6	\$1,667.66	6	0	No Change	349	2.09	0%	9213.6	\$1,667.66	\$0.00	\$0.00	0.00	0	\$0.00	0.00
705		4400	2	1	No Change	92	0.18	809.6	\$146.54	2	0	No Change	92	0.18	0%	809.6	\$146.54	\$0.00	\$0.00	0.00	0	\$0.00	0.00
705		4400	11	1	No Change	92	1.01	4452.8	\$805.96	11	0	No Change	92	1.01	0%	4452.8	\$805.96	\$0.00	\$0.00	0.00	0	\$0.00	0.00
Totals			146	40			16.6	52,328.6	\$8,519	133	8			14.0		46,102.7	\$7,392.09		\$3,005	2.55	6,226	\$1,127	2.67

## Investment Grade Lighting Audit

CEG Job #: 1C11039

Project: Senior Center

Senior Center

KWH COST: \$0.237

### ECM: Lighting Upgrade - General

EXISTING LIGHTING										PROPOSED LIGHTING										SAVINGS			
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Lamps	Retro-Unit Description	Watts Used	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Incentive	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings	Yearly Simple Payback
242.21	Assembly Room	1040	24	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	107	2.57	2,670.7	\$632.96	24	4	Relamp - Sylvania Lamp FO28/841/SS/ECO	98	2.35	2446.08	\$579.72	\$28.00	\$240.00	\$672.00	0.22	224.64	\$53.24	12.62
222.21	Kitchen	520	4	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.25	129.0	\$30.56	4	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.20	104	\$24.65	\$14.00	\$40.00	\$56.00	0.05	24.96	\$5.92	9.47
617		120	1	1	Hood Light w/Globe & Cage, 100w A19 Lamp	100	0.10	12.0	\$2.84	1	1	(1) 26w CFL Lamp	26	0.03	3.12	\$0.74	\$20.00	\$7.00	\$20.00	0.07	8.88	\$2.10	9.50
221.44	Utility Room	520	2	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Wall Mnt., No Lens	62	0.12	64.5	\$15.28	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	52	\$12.32	\$14.00	\$20.00	\$28.00	0.02	12.48	\$2.96	9.47
221.21	Men's Rest Room	1040	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.12	129.0	\$30.56	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	104	\$24.65	\$14.00	\$20.00	\$28.00	0.02	24.96	\$5.92	4.73
221.14	Custodial Closet	520	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.06	32.2	\$7.64	1	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.05	26	\$6.16	\$14.00	\$10.00	\$14.00	0.01	6.24	\$1.48	9.47
221.21	Women's Rest Room	1040	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.12	129.0	\$30.56	2	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.10	104	\$24.65	\$14.00	\$20.00	\$28.00	0.02	24.96	\$5.92	4.73
221.14	Closet	520	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.06	32.2	\$7.64	1	2	Relamp - Sylvania Lamp FO28/841/SS/ECO	50	0.05	26	\$6.16	\$14.00	\$10.00	\$14.00	0.01	6.24	\$1.48	9.47
725	Exterior	4400	7	1	150w HPS Wallpack	188	1.32	5,790.4	\$1,372.32	7	0	No Change	188	1.32	5790.4	\$1,372.32	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
711		4400	5	1	70w HPS Bollards	92	0.46	2,024.0	\$479.69	5	0	No Change	92	0.46	2024	\$479.69	\$0.00	\$0.00	\$0.00	0.00	0	\$0.00	0.00
<b>Totals</b>			49	19			5.19	11,013	\$2,610	49	17			4.8	10,680	\$2,531		\$367	\$860	0.4	333	\$79	10.89


**ECM: Lighting Controls**

EXISTING LIGHTING					PROPOSED LIGHTING CONTROLS										SAVINGS							
CEG Type	Fixture Location	Yearly Usage	No. Fixts	No. Lamps	Fixture Type	Fixt Watts	Total kW	kWh/Yr Fixtures	Yearly \$ Cost	No. Fixts	No. Cont.	Controls Description	Watts Used	Total kW	Reduction (%)	kWh/Yr Fixtures	Yearly \$ Cost	Unit Cost (INSTALLED)	Total Cost	kW Savings	kWh/Yr Savings	Yearly \$ Savings
242.21	Assembly Room	1040	24	4	2x4, 4 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	107	2.568	2670.72	\$632.96	24	1	No Change	107	2.57	0%	2670.72	\$632.96	\$225.00	\$225.00	0.00	0	\$0.00
222.21	Kitchen	520	4	2	2x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.248	128.96	\$30.56	4	1	No Change	62	0.25	0%	128.96	\$30.56	\$75.00	\$75.00	0.00	0	\$0.00
617		120	1	1	Hood Light w/Globe & Cage, 100w A19 Lamp	100	0.1	12	\$2.84	1	0	No Change	100	0.10	0%	12	\$2.84	\$0.00	\$0.00	0.00	0	\$0.00
221.44	Utility Room	520	2	2	1x4, 2 Lamp, 32w 700 Series T8, Elect. Ballast, Wall Mnt., No Lens	62	0.124	64.48	\$15.28	2	0	No Change	62	0.12	0%	64.48	\$15.28	\$0.00	\$0.00	0.00	0	\$0.00
221.21	Men's Rest Room	1040	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed Mnt., Prismatic Lens	62	0.124	128.96	\$30.56	2	0	No Change	62	0.12	0%	128.96	\$30.56	\$75.00	\$0.00	0.00	0	\$0.00
221.14	Custodial Closet	520	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.062	32.24	\$7.64	1	0	No Change	62	0.06	0%	32.24	\$7.64	\$75.00	\$0.00	0.00	0	\$0.00
221.21	Women's Rest Room	1040	2	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Recessed	62	0.124	128.96	\$30.56	2	0	No Change	62	0.12	0%	128.96	\$30.56	\$0.00	\$0.00	0.00	0	\$0.00
221.14	Closet	520	1	2	1x4, 2 Lamp, 32w T8, Elect. Ballast, Surface Mnt., No Lens	62	0.062	32.24	\$7.64	1	0	No Change	62	0.06	0%	32.24	\$7.64	\$160.00	\$0.00	0.00	0	\$0.00
725	Exterior	4400	7	1	150w HPS Wallpack	188	1.316	5790.4	\$1,372.32	7	0	No Change	188	1.32	0%	5790.4	\$1,372.32	\$0.00	\$0.00	0.00	0	\$0.00
711		4400	5	1	70w HPS Bollards	92	0.46	2024	\$479.69	5	0	No Change	92	0.46	0%	2024	\$479.69	\$0.00	\$0.00	0.00	0	\$0.00
Totals			49	19			5.2	11,013.0	\$2,610	49	2			5.2		11,013.0	\$2,610.07	\$300	\$0.00	0	\$0	

# Area Type Averages

## Concord Engineering, Gloucester Township ESIP

Area Type Averages			Normalized Weekly Lights On					Normalized Weekly Occupied						
Area Type	Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav	
Private Office	PO	1	40	27.64	17.51	0.00	0.00	45.15	25.02	14.26	0.00	0.00	39.29	12.98%
Meeting Rooms	M	1	32	8.94	4.15	0.00	0.00	13.10	8.94	4.15	0.00	0.00	13.10	0.00%
Restroom	R	4	30	42.42	21.50	0.00	0.00	63.91	13.58	2.26	0.00	0.00	15.84	75.22%
Storage	S	4	33	23.37	11.35	0.00	0.00	34.71	12.57	0.20	0.00	0.00	12.77	63.21%
Hallway	H	1	40	70.00	98.00	0.00	0.00	168.00	22.10	6.82	0.00	0.00	28.92	82.79%
Mechanical	MR	2	33	24.28	5.50	0.00	0.00	29.77	11.50	0.37	0.00	0.00	11.86	60.16%
Kitchen	K	6	32	26.08	6.35	0.00	0.00	32.43	16.40	2.74	0.00	0.00	19.14	40.98%
Cafeteria	CF	1	32	10.97	11.97	0.00	0.00	22.94	7.49	10.31	0.00	0.00	17.80	22.41%
Office	O	10	33	23.89	2.36	0.00	0.00	26.25	17.68	0.97	0.00	0.00	18.65	28.95%
Open Office	OO	4	34	51.04	49.75	0.00	0.00	100.79	40.24	20.97	0.00	0.00	61.20	39.28%
Conference	CN	4	34	22.00	0.41	0.00	0.00	22.41	9.62	0.15	0.00	0.00	9.77	56.40%
General Office	GO	2	33	43.55	6.25	0.00	0.00	49.79	42.24	6.02	0.00	0.00	48.25	3.09%
Building Average for 40 rooms			1322	30.27	14.23		0.00	44.50	18.92	4.34		0.00	23.26	47.73%





Normalized Data Logger Detail for Concord Engineering, Gloucester Township ESIP Page 1 of 1

All Loggers Listed			Load	Normalized Weekly Hours of Use					Normalized Weekly Hours of Occupancy					
Logger	Room Location	Ty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total	% sav
EDFC	Academy Hall 2nd Flr Break	K	34	46.67	0.00	0.00	0.00	46.67	46.67	0.00	0.00	0.00	46.67	0.00%
EE5A	Academy Hall 2nd Flr Office	O	34	7.41	4.76	0.00	0.00	12.17	4.26	0.00	0.00	0.00	4.26	65.00%
EE1C	Academy Hall 3rd Flr Left Office	O	34	13.02	0.00	0.00	0.00	13.02	8.23	0.00	0.00	0.00	8.23	36.79%
EEB0	Academy Hall Det. Sgt Office	O	34	1.36	0.00	0.00	0.00	1.36	0.91	0.00	0.00	0.00	0.91	33.09%
EEDB	Academy Hall Storage	S	34	2.64	0.00	0.00	0.00	2.64	0.77	0.00	0.00	0.00	0.77	70.83%
F015	Library Circulation Office	GO	32	49.03	10.51	0.00	0.00	59.53	47.49	10.13	0.00	0.00	57.62	3.21%
ED71	Library Lounge	K	32	46.20	9.04	0.00	0.00	55.24	20.29	4.22	0.00	0.00	24.51	55.63%
EDBA	Library Mens Room	R	20	52.49	13.00	0.00	0.00	65.49	22.29	4.85	0.00	0.00	27.15	58.54%
EFF3	Municipal Clerk Licensing Office	O	32	37.95	0.70	0.00	0.00	38.64	31.07	0.70	0.00	0.00	31.77	17.78%
EFE5	Municipal Clerk Office	OO	32	70.00	98.00	0.00	0.00	168.00	36.36	1.86	0.00	0.00	38.21	77.26%
EE5C	Municipal Clerk Office	CN	32	37.42	0.19	0.00	0.00	37.61	14.21	0.19	0.00	0.00	14.40	61.71%
EDA3	Municipal Construction File	S	32	20.30	0.05	0.00	0.00	20.35	18.88	0.05	0.00	0.00	18.93	6.98%
EDE8	Municipal Construction Office	O	32	34.94	0.70	0.00	0.00	35.64	27.67	0.70	0.00	0.00	28.36	20.43%
EFEF	Municipal Constuction Offices	K	32	33.87	2.08	0.00	0.00	35.95	16.94	1.35	0.00	0.00	18.29	49.12%
EEE4	Municipal Electrical Room	MR	32	4.95	4.76	0.00	0.00	9.70	1.19	0.00	0.00	0.00	1.19	87.73%
ED69	Municipal Mayor Conference	CN	32	9.90	0.00	0.00	0.00	9.90	8.82	0.00	0.00	0.00	8.82	10.91%
EE56	Municipal Mayors Office	O	32	38.58	3.46	0.00	0.00	42.04	18.47	1.09	0.00	0.00	19.56	53.47%
ED77	Municipal Mayors Office	K	32	7.67	0.19	0.00	0.00	7.86	3.91	0.11	0.00	0.00	4.02	48.85%
EDC3	Municipal Mens Room	R	32	42.67	38.59	0.00	0.00	81.26	13.63	0.71	0.00	0.00	14.33	82.37%
EDB3	Municipal Tax Office Corner	O	32	29.88	0.27	0.00	0.00	30.15	20.01	0.27	0.00	0.00	20.28	32.74%
EFFB	Municipal Tax Office Storage	S	32	37.60	4.28	0.00	0.00	41.88	20.69	0.76	0.00	0.00	21.45	48.78%
EFF4	Municipal Vital Statistics Office	O	32	35.27	0.83	0.00	0.00	36.11	34.08	0.83	0.00	0.00	34.92	3.30%
F008	Police Admin Area Conference	CN	32	34.70	1.19	0.00	0.00	35.89	12.85	0.14	0.00	0.00	12.99	63.81%
EE58	Police Building Chief Office	O	32	24.82	6.25	0.00	0.00	31.07	18.38	2.76	0.00	0.00	21.13	31.99%
EE4C	Police Building Dispatch	K	32	19.41	20.92	0.00	0.00	40.33	7.97	7.79	0.00	0.00	15.76	60.92%
EFEC	Police Building Lt. Office	O	32	15.66	6.62	0.00	0.00	22.28	13.70	3.34	0.00	0.00	17.03	23.56%
EFFA	Police Court Clerks Office	OO	32	35.34	3.19	0.00	0.00	38.53	35.00	3.04	0.00	0.00	38.05	1.25%
F010	Police Mens Room	R	32	30.36	33.02	0.00	0.00	63.38	7.03	3.12	0.00	0.00	10.15	83.99%
EF77	Police Squad Room	OO	31	60.48	86.55	0.00	0.00	147.03	54.26	72.25	0.00	0.00	126.52	13.95%
F00E	Public Works Conference Room	CN	40	5.97	0.25	0.00	0.00	6.22	2.62	0.25	0.00	0.00	2.86	54.02%
EF5D	Public Works Front Office	OO	40	38.34	11.25	0.00	0.00	49.59	35.32	6.71	0.00	0.00	42.03	15.25%
EF58	Public Works Hallway	H	40	70.00	98.00	0.00	0.00	168.00	22.10	6.82	0.00	0.00	28.92	82.79%
EF59	Public Works Lunch Room	CF	32	10.97	11.97	0.00	0.00	22.94	7.49	10.31	0.00	0.00	17.80	22.41%
EF28	Public Works Supervisors Office	PD	40	27.64	17.51	0.00	0.00	45.15	25.02	14.26	0.00	0.00	39.29	12.98%
EF6C	Recreation Center Buisness	GO	34	38.06	1.98	0.00	0.00	40.04	36.98	1.90	0.00	0.00	38.88	2.90%
EF94	Recreation Center Electrical	MR	34	43.60	6.24	0.00	0.00	49.84	21.80	0.74	0.00	0.00	22.53	54.80%
EEEE	Recreation Center Game	S	34	32.92	41.06	0.00	0.00	73.98	9.94	0.00	0.00	0.00	9.94	86.56%
EE17	Recreation Center Mens Room	R	34	44.14	1.38	0.00	0.00	45.52	11.38	0.36	0.00	0.00	11.74	74.21%
EEE3	Senior Center Kitchen	K	32	2.63	5.88	0.00	0.00	8.52	2.61	2.98	0.00	0.00	5.59	34.39%
EDF4	Senior Center Meeting Room	M	32	8.94	4.15	0.00	0.00	13.10	8.94	4.15	0.00	0.00	13.10	0.00%

# Building Summary Totals for Concord Engineering, Gloucester Township ESIP Page 1 of 1

Building Summary Totals			Lights On KWHR					Occupied KWHR					
Area Type		Qty	Watts	Peak	Off	Shldr 1	Shldr 2	Total	Peak	Off	Shldr 1	Shldr 2	Total
Private Office	PO	1	40	1.11	0.70	0.00	0.00	1.81	1.00	0.57	0.00	0.00	1.57
Meeting Rooms	M	1	32	0.29	0.13	0.00	0.00	0.42	0.29	0.13	0.00	0.00	0.42
Restroom	R	4	120	5.09	2.58	0.00	0.00	7.67	1.63	0.27	0.00	0.00	1.90
Storage	S	4	132	3.08	1.50	0.00	0.00	4.58	1.66	0.03	0.00	0.00	1.69
Hallway	H	1	40	2.80	3.92	0.00	0.00	6.72	0.88	0.27	0.00	0.00	1.16
Mechanical	MR	2	66	1.60	0.36	0.00	0.00	1.96	0.76	0.02	0.00	0.00	0.78
Kitchen	K	6	192	5.01	1.22	0.00	0.00	6.23	3.15	0.53	0.00	0.00	3.67
Cafeteria	CF	1	32	0.35	0.38	0.00	0.00	0.73	0.24	0.33	0.00	0.00	0.57
Office	O	10	330	7.88	0.78	0.00	0.00	8.66	5.83	0.32	0.00	0.00	6.15
Open Office	OO	4	136	6.94	6.77	0.00	0.00	13.71	5.47	2.85	0.00	0.00	8.32
Conference	CN	4	136	2.99	0.06	0.00	0.00	3.05	1.31	0.02	0.00	0.00	1.33
General Office	GO	2	66	2.87	0.41	0.00	0.00	3.29	2.79	0.40	0.00	0.00	3.18
Building Totals for 40 rooms			1322	40	19	0		59	25	6	0		31

# Academy Hall 2nd Flr Break Room

Area type: Kitchen. Logger: EDFC. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week



Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	14.000	0.000	0.000	0.000	0.000
Off	0.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.050	14.000	0.033	9.333	0.033	9.333
Off	0.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.050</b>	<b>24.000</b>	<b>0.033</b>	<b>9.333</b>	<b>0.033</b>	<b>9.333</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	14.000	0.000	0.000	0.000	0.000
Off	0.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	14.000	0.000	0.000	0.000	0.000
Off	0.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	14.000	0.000	0.000	0.000	0.000
Off	0.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	14.000	0.000	0.000	0.000	0.000
Off	0.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	14.000	0.000	0.000	0.000	0.000
Off	0.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	0.033	0.033	0.050	46.667	46.667	0.0%
Off	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>0.033</b>	<b>0.033</b>	<b>0.050</b>	<b>46.667</b>	<b>46.667</b>	<b>0.0%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	9.333	9.333	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Off Peak	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>9.333</b>	<b>9.333</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	0.033	0.033	0.050	^^ ^^	46.667	46.667	0.0%
Off Peak	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>0.033</b>	<b>0.033</b>	<b>0.050</b>		<b>46.667</b>	<b>46.667</b>	<b>0.0%</b>



# Academy Hall 2nd Flr Office

Area type: Office. Logger: EE5A. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	1.050	0.507	0.783	0.378
Dif	27.983	10.000	7.983	2.853	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>9.033</b>	<b>3.359</b>	<b>0.783</b>	<b>0.378</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	5.367	2.683	5.233	2.617
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>5.367</b>	<b>2.683</b>	<b>5.233</b>	<b>2.617</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	37.517	14.000	9.517	3.551	3.150	1.175
Dif	22.017	10.000	2.017	0.916	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>59.533</b>	<b>24.000</b>	<b>11.533</b>	<b>4.467</b>	<b>3.150</b>	<b>1.175</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		% Savings
	Lites On	Occupied	Logged	Lites On	Occupied	
Peak	15.933	9.167	150.533	7.409	4.263	42.5%
Dif Peak	10.000	0.000	206.000	4.757	0.000	100.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>25.933</b>	<b>9.167</b>	<b>356.533</b>	<b>12.166</b>	<b>4.263</b>	<b>65.0%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	3.551	1.175	0.507	0.378	0.000	0.000	2.683	2.617	0.000	0.000	0.000	0.000
Dif Peak	0.000	0.000	0.916	0.000	2.853	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>4.467</b>	<b>1.175</b>	<b>3.359</b>	<b>0.378</b>	<b>0.000</b>	<b>0.000</b>	<b>2.683</b>	<b>2.617</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	15.933	9.167	150.533	^^ ^^	7.409	4.263	42.5%
Dif Peak	10.000	0.000	206.000		4.757	0.000	100.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>25.933</b>	<b>9.167</b>	<b>356.533</b>		<b>12.166</b>	<b>4.263</b>	<b>65.0%</b>



# Academy Hall 3rd Flr Left Office

Area type: Office. Logger: EE1C. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	3.733	1.801	3.300	1.592
Off	27.983	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>3.733</b>	<b>1.801</b>	<b>3.300</b>	<b>1.592</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	9.167	4.583	5.433	2.717
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>9.167</b>	<b>4.583</b>	<b>5.433</b>	<b>2.717</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	37.467	14.000	3.267	1.221	1.933	0.722
Off	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>59.483</b>	<b>24.000</b>	<b>3.267</b>	<b>1.221</b>	<b>1.933</b>	<b>0.722</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	11.833	5.917	7.033	3.517
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>11.833</b>	<b>5.917</b>	<b>7.033</b>	<b>3.517</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	28.000	17.700	150.483	13.025	8.233	36.8%
Off Peak	0.000	0.000	206.000	0.000	0.000	0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>28.000</b>	<b>17.700</b>	<b>356.483</b>	<b>13.025</b>	<b>8.233</b>	<b>36.8%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	1.221	0.722	1.801	1.592	5.917	3.517	4.583	2.717	0.000	0.000	0.000	0.000
Off Peak	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>1.221</b>	<b>0.722</b>	<b>1.801</b>	<b>1.592</b>	<b>5.917</b>	<b>3.517</b>	<b>4.583</b>	<b>2.717</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	28.000	17.700	150.483	^^ ^^	13.025	8.233	36.8%
Off Peak	0.000	0.000	206.000		0.000	0.000	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>28.000</b>	<b>17.700</b>	<b>356.483</b>		<b>13.025</b>	<b>8.233</b>	<b>36.8%</b>



# Academy Hall Det. Sgt Office

Area type: Office. Logger: EEB0. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	2.733	1.319	1.767	0.852
Off	27.983	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>2.733</b>	<b>1.319</b>	<b>1.767</b>	<b>0.852</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.167	0.083	0.167	0.083
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.167</b>	<b>0.083</b>	<b>0.167</b>	<b>0.083</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	37.700	14.000	0.033	0.012	0.033	0.012
Off	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>59.717</b>	<b>24.000</b>	<b>0.033</b>	<b>0.012</b>	<b>0.033</b>	<b>0.012</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals			% Savings
	Lites On	Occupied	Logged	Lites On	Occupied		
Peak	2.933	1.967	150.717	1.362	0.913		33.0%
Off Peak	0.000	0.000	206.000	0.000	0.000		0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000		0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000		0.0%
<b>Total</b>	<b>2.933</b>	<b>1.967</b>	<b>356.717</b>	<b>1.362</b>	<b>0.913</b>		<b>33.0%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	0.012	0.012	1.319	0.852	0.000	0.000	0.083	0.083	0.000	0.000	0.000	0.000
Off Peak	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>0.012</b>	<b>0.012</b>	<b>1.319</b>	<b>0.852</b>	<b>0.000</b>	<b>0.000</b>	<b>0.083</b>	<b>0.083</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	2.933	1.967	150.717	^^ ^^	1.362	0.913	33.0%
Off Peak	0.000	0.000	206.000		0.000	0.000	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>2.933</b>	<b>1.967</b>	<b>356.717</b>		<b>1.362</b>	<b>0.913</b>	<b>33.0%</b>



# Academy Hall Storage

Area type: Storage. Logger: EEDB. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	24.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	23.617	14.000	0.100	0.059	0.100	0.059
Off	12.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>35.633</b>	<b>24.000</b>	<b>0.100</b>	<b>0.059</b>	<b>0.100</b>	<b>0.059</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>


Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	4.033	2.017	1.033	0.517
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>4.033</b>	<b>2.017</b>	<b>1.033</b>	<b>0.517</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	18.500	14.000	0.100	0.076	0.100	0.076
Off	17.983	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>36.483</b>	<b>24.000</b>	<b>0.100</b>	<b>0.076</b>	<b>0.100</b>	<b>0.076</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	14.000	14.000	0.000	0.000	0.000	0.000
Off	10.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	24.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals			% Savings
	Lites On	Occupied	Logged	Lites On	Occupied		
Peak	4.233	1.233	112.117	2.643	0.770	70.9%	
Off Peak	0.000	0.000	128.000	0.000	0.000	0.0%	
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%	
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%	
<b>Total</b>	<b>4.233</b>	<b>1.233</b>	<b>240.117</b>	<b>2.643</b>	<b>0.770</b>	<b>70.9%</b>	



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	0.059	0.059	0.000	0.000	2.017	0.517	0.076	0.076	0.000	0.000	0.000	0.000
Off Peak	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>0.059</b>	<b>0.059</b>	<b>0.000</b>	<b>0.000</b>	<b>2.017</b>	<b>0.517</b>	<b>0.076</b>	<b>0.076</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	4.233	1.233	112.117	^^ ^^	2.643	0.770	70.9%
Off Peak	0.000	0.000	128.000		0.000	0.000	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>4.233</b>	<b>1.233</b>	<b>240.117</b>		<b>2.643</b>	<b>0.770</b>	<b>70.9%</b>

# Library Circulation Office

Area type: General Office. Logger: F015. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	18.883	9.111	18.517	8.934
Dif	27.983	10.000	3.083	1.102	2.717	0.971
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>21.967</b>	<b>10.213</b>	<b>21.233</b>	<b>9.905</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	24.917	12.458	23.700	11.850
Dif	20.000	10.000	1.450	0.725	1.400	0.700
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>26.367</b>	<b>13.183</b>	<b>25.100</b>	<b>12.550</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	14.000	7.000	13.767	6.883
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>14.000</b>	<b>7.000</b>	<b>13.767</b>	<b>6.883</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	37.800	14.000	21.700	8.037	20.367	7.543
Dif	22.017	10.000	1.017	0.462	0.917	0.416
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>59.817</b>	<b>24.000</b>	<b>22.717</b>	<b>8.499</b>	<b>21.283</b>	<b>7.960</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	24.067	12.033	23.667	11.833
Dif	20.000	10.000	1.067	0.533	1.067	0.533
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>25.133</b>	<b>12.567</b>	<b>24.733</b>	<b>12.367</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	16.067	8.033	16.067	8.033
Dif	20.000	10.000	1.467	0.733	1.433	0.717
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>17.533</b>	<b>8.767</b>	<b>17.500</b>	<b>8.750</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	105.633	102.317	150.817	49.029	47.489	3.1%
Dif	22.083	21.300	206.000	10.506	10.133	3.5%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>127.717</b>	<b>123.617</b>	<b>356.817</b>	<b>59.534</b>	<b>57.622</b>	<b>3.2%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	8.037	7.543	9.111	8.934	12.033	11.833	12.458	11.850	8.033	8.033	0.000	0.000
Dif Peak	0.000	0.000	0.462	0.416	1.102	0.971	0.533	0.533	0.725	0.700	0.733	0.717	7.000	6.883
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>8.499</b>	<b>7.960</b>	<b>10.213</b>	<b>9.905</b>	<b>12.567</b>	<b>12.367</b>	<b>13.183</b>	<b>12.550</b>	<b>8.767</b>	<b>8.750</b>	<b>7.000</b>	<b>6.883</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	105.633	102.317	150.817	^^ ^^	49.029	47.489	3.1%
Dif Peak	22.083	21.300	206.000		10.506	10.133	3.5%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>127.717</b>	<b>123.617</b>	<b>356.817</b>		<b>59.534</b>	<b>57.622</b>	<b>3.2%</b>

# Library Lounge

Area type: Kitchen. Logger: ED71. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	19.450	9.384	7.700	3.715
Dif	27.983	10.000	3.233	1.155	0.667	0.238
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>22.683</b>	<b>10.540</b>	<b>8.367</b>	<b>3.953</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	23.533	11.767	10.833	5.417
Dif	20.000	10.000	0.533	0.267	0.233	0.117
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>24.067</b>	<b>12.033</b>	<b>11.067</b>	<b>5.533</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	11.600	5.800	6.733	3.367
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>11.600</b>	<b>5.800</b>	<b>6.733</b>	<b>3.367</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	37.617	14.000	20.867	7.766	8.300	3.089
Dif	22.017	10.000	0.867	0.394	0.200	0.091
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>59.633</b>	<b>24.000</b>	<b>21.733</b>	<b>8.160</b>	<b>8.500</b>	<b>3.180</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	20.133	10.067	10.167	5.083
Dif	20.000	10.000	1.200	0.600	0.400	0.200
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>21.333</b>	<b>10.667</b>	<b>10.567</b>	<b>5.283</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	15.433	7.717	6.667	3.333
Dif	20.000	10.000	1.567	0.783	0.633	0.317
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>17.000</b>	<b>8.500</b>	<b>7.300</b>	<b>3.650</b>

	Logged Totals			Normalized Totals		% Savings
	Lites On	Occupied	Logged	Lites On	Occupied	
Peak	99.417	43.667	150.633	46.199	20.292	56.1%
Dif	19.000	8.867	206.000	9.039	4.218	53.3%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>118.417</b>	<b>52.533</b>	<b>356.633</b>	<b>55.238</b>	<b>24.510</b>	<b>55.6%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	7.766	3.089	9.384	3.715	10.067	5.083	11.767	5.417	7.717	3.333	0.000	0.000
Dif Peak	0.000	0.000	0.394	0.091	1.155	0.238	0.600	0.200	0.267	0.117	0.783	0.317	5.800	3.367
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>8.160</b>	<b>3.180</b>	<b>10.540</b>	<b>3.953</b>	<b>10.667</b>	<b>5.283</b>	<b>12.033</b>	<b>5.533</b>	<b>8.500</b>	<b>3.650</b>	<b>5.800</b>	<b>3.367</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	99.417	43.667	150.633	^^ ^^	46.199	20.292	56.1%
Dif Peak	19.000	8.867	206.000		9.039	4.218	53.3%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>118.417</b>	<b>52.533</b>	<b>356.633</b>		<b>55.238</b>	<b>24.510</b>	<b>55.6%</b>



# Library Mens Room

Area type: Restroom. Logger: EDDBA. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	37.800	14.000	22.000	8.148	9.633	3.568
Off	22.017	10.000	1.033	0.469	0.367	0.167
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>59.817</b>	<b>24.000</b>	<b>23.033</b>	<b>8.617</b>	<b>10.000</b>	<b>3.734</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	20.883	10.076	8.867	4.278
Off	27.983	10.000	4.133	1.477	1.500	0.536
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>25.017</b>	<b>11.553</b>	<b>10.367</b>	<b>4.814</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	26.033	13.017	9.933	4.967
Off	20.000	10.000	2.833	1.417	0.900	0.450
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>28.867</b>	<b>14.433</b>	<b>10.833</b>	<b>5.417</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	26.100	13.050	11.667	5.833
Off	20.000	10.000	1.867	0.933	0.833	0.417
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>27.967</b>	<b>13.983</b>	<b>12.500</b>	<b>6.250</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	18.067	9.033	7.933	3.967
Off	20.000	10.000	3.300	1.650	0.900	0.450
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>21.367</b>	<b>10.683</b>	<b>8.833</b>	<b>4.417</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	14.167	7.083	5.700	2.850
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>14.167</b>	<b>7.083</b>	<b>5.700</b>	<b>2.850</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	113.083	48.033	150.817	52.486	22.294	57.5%
Off Peak	27.333	10.200	206.000	13.003	4.852	62.7%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>140.417</b>	<b>58.233</b>	<b>356.817</b>	<b>65.490</b>	<b>27.147</b>	<b>58.5%</b>



### Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	8.148	3.568	10.076	4.278	13.017	4.967	13.050	5.833	9.033	3.967	0.000	0.000
Off Peak	0.000	0.000	0.469	0.167	1.477	0.536	1.417	0.450	0.933	0.417	1.650	0.450	7.083	2.850
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>8.617</b>	<b>3.734</b>	<b>11.553</b>	<b>4.814</b>	<b>14.433</b>	<b>5.417</b>	<b>13.983</b>	<b>6.250</b>	<b>10.683</b>	<b>4.417</b>	<b>7.083</b>	<b>2.850</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	113.083	48.033	150.817	^ ^ ^ ^	52.486	22.294	57.5%
Off Peak	27.333	10.200	206.000		13.003	4.852	62.7%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>140.417</b>	<b>58.233</b>	<b>356.817</b>		<b>65.490</b>	<b>27.147</b>	<b>58.5%</b>

# Municipal Clerk Licensing Office

Area type: Office. Logger: EFF3. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dff	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	40.067	14.000	21.100	7.373	14.433	5.043
Dff	22.017	10.000	0.067	0.030	0.067	0.030
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>62.083</b>	<b>24.000</b>	<b>21.167</b>	<b>7.403</b>	<b>14.500</b>	<b>5.074</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	20.717	9.995	17.183	8.291
Dff	27.983	10.000	0.567	0.203	0.567	0.203
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>21.283</b>	<b>10.198</b>	<b>17.750</b>	<b>8.493</b>


Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	19.467	9.733	17.100	8.550
Dff	20.000	10.000	0.333	0.167	0.333	0.167
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>19.800</b>	<b>9.900</b>	<b>17.433</b>	<b>8.717</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	19.600	9.800	17.467	8.733
Dff	20.000	10.000	0.500	0.250	0.500	0.250
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>20.100</b>	<b>10.050</b>	<b>17.967</b>	<b>8.983</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	2.100	1.050	1.767	0.883
Dff	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>2.100</b>	<b>1.050</b>	<b>1.767</b>	<b>0.883</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dff	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	82.983	67.950	153.083	37.946	31.071	18.1%
Dff	1.467	1.467	206.000	0.698	0.698	0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>84.450</b>	<b>69.417</b>	<b>359.083</b>	<b>38.643</b>	<b>31.769</b>	<b>17.8%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	7.373	5.043	9.995	8.291	9.733	8.550	9.800	8.733	1.050	0.883	0.000	0.000
Dff Peak	0.000	0.000	0.030	0.030	0.203	0.203	0.167	0.167	0.250	0.250	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>7.403</b>	<b>5.074</b>	<b>10.198</b>	<b>8.493</b>	<b>9.900</b>	<b>8.717</b>	<b>10.050</b>	<b>8.983</b>	<b>1.050</b>	<b>0.883</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	82.983	67.950	153.083	^ ^ ^ ^	37.946	31.071	18.1%
Dff Peak	1.467	1.467	206.000		0.698	0.698	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>84.450</b>	<b>69.417</b>	<b>359.083</b>		<b>38.643</b>	<b>31.769</b>	<b>17.8%</b>



# Municipal Clerk Office

Area type: Open Office. Logger: EFE5. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	48.000	24.000	0.567	0.283
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>48.000</b>	<b>24.000</b>	<b>0.567</b>	<b>0.283</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	29.017	14.000	20.717	9.995
Off	27.983	10.000	27.983	10.000	1.400	0.500
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>57.000</b>	<b>24.000</b>	<b>22.117</b>	<b>10.496</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	28.000	14.000	19.900	9.950
Off	20.000	10.000	20.000	10.000	0.867	0.433
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>48.000</b>	<b>24.000</b>	<b>20.767</b>	<b>10.383</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	48.000	24.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	40.200	14.000	40.200	14.000	17.767	6.187
Off	22.017	10.000	22.017	10.000	0.233	0.106
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>62.217</b>	<b>24.000</b>	<b>62.217</b>	<b>24.000</b>	<b>18.000</b>	<b>6.293</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	28.000	14.000	20.033	10.017
Off	20.000	10.000	20.000	10.000	0.833	0.417
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>48.000</b>	<b>24.000</b>	<b>20.867</b>	<b>10.433</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	28.000	14.000	1.167	0.583
Off	20.000	10.000	20.000	10.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>48.000</b>	<b>24.000</b>	<b>1.167</b>	<b>0.583</b>

	Logged Totals			Normalized Totals			% Savings
	Lites On	Occupied	Logged	Lites On	Occupied		
Peak	153.217	79.583	153.217	70.000	36.359	48.1%	
Off Peak	206.000	3.900	206.000	98.000	1.855	98.1%	
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%	
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%	
<b>Total</b>	<b>359.217</b>	<b>83.483</b>	<b>359.217</b>	<b>168.000</b>	<b>38.215</b>	<b>77.3%</b>	

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	14.000	6.187	14.000	9.995	14.000	10.017	14.000	9.950	14.000	0.583	0.000	0.000
Off Peak	24.000	0.283	10.000	0.106	10.000	0.500	10.000	0.417	10.000	0.433	10.000	0.000	24.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>0.283</b>	<b>24.000</b>	<b>6.293</b>	<b>24.000</b>	<b>10.496</b>	<b>24.000</b>	<b>10.433</b>	<b>24.000</b>	<b>10.383</b>	<b>24.000</b>	<b>0.583</b>	<b>24.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	153.217	79.583	153.217	^^ ^^	70.000	36.359	48.1%
Off Peak	206.000	3.900	206.000		98.000	1.855	98.1%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>359.217</b>	<b>83.483</b>	<b>359.217</b>		<b>168.000</b>	<b>38.215</b>	<b>77.3%</b>



# Municipal Clerk Office Conference

Area type: Conference. Logger: EE5C. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.033	0.017	0.033	0.017
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.033</b>	<b>0.017</b>	<b>0.033</b>	<b>0.017</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	20.583	9.931	6.567	3.168
Off	27.983	10.000	0.133	0.048	0.133	0.048
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>20.717</b>	<b>9.979</b>	<b>6.700</b>	<b>3.216</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	20.800	10.400	8.800	4.400
Off	20.000	10.000	0.067	0.033	0.067	0.033
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>20.867</b>	<b>10.433</b>	<b>8.867</b>	<b>4.433</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	40.050	14.000	20.650	7.218	6.700	2.342
Off	22.017	10.000	0.033	0.015	0.033	0.015
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>62.067</b>	<b>24.000</b>	<b>20.683</b>	<b>7.234</b>	<b>6.733</b>	<b>2.357</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	19.633	9.817	8.833	4.417
Off	20.000	10.000	0.133	0.067	0.133	0.067
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>19.767</b>	<b>9.883</b>	<b>8.967</b>	<b>4.483</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.167	0.083	0.167	0.083
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.167</b>	<b>0.083</b>	<b>0.167</b>	<b>0.083</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	81.833	31.067	153.067	37.424	14.207	62.0%
Off Peak	0.400	0.400	206.000	0.190	0.190	0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>82.233</b>	<b>31.467</b>	<b>359.067</b>	<b>37.614</b>	<b>14.398</b>	<b>61.7%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	7.218	2.342	9.931	3.168	9.817	4.417	10.400	4.400	0.083	0.083	0.000	0.000
Off Peak	0.017	0.017	0.015	0.015	0.048	0.048	0.067	0.067	0.033	0.033	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.017</b>	<b>0.017</b>	<b>7.234</b>	<b>2.357</b>	<b>9.979</b>	<b>3.216</b>	<b>9.883</b>	<b>4.483</b>	<b>10.433</b>	<b>4.433</b>	<b>0.083</b>	<b>0.083</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	81.833	31.067	153.067	^ ^ ^ ^	37.424	14.207	62.0%
Off Peak	0.400	0.400	206.000		0.190	0.190	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>82.233</b>	<b>31.467</b>	<b>359.067</b>		<b>37.614</b>	<b>14.398</b>	<b>61.7%</b>

# Municipal Construction File Storage

Area type: Storage. Logger: EDA3. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.600	14.000	15.233	5.386	13.567	4.796
Off	22.017	10.000	0.067	0.030	0.067	0.030
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.617</b>	<b>24.000</b>	<b>15.300</b>	<b>5.416</b>	<b>13.633</b>	<b>4.827</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	9.033	4.358	8.767	4.230
Off	27.983	10.000	0.033	0.012	0.033	0.012
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>9.067</b>	<b>4.370</b>	<b>8.800</b>	<b>4.242</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	15.867	7.933	15.333	7.667
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>15.867</b>	<b>7.933</b>	<b>15.333</b>	<b>7.667</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	4.133	2.067	3.500	1.750
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>4.133</b>	<b>2.067</b>	<b>3.500</b>	<b>1.750</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	44.267	41.167	152.617	20.304	18.882	7.0%
Off Peak	0.100	0.100	206.000	0.048	0.048	0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>44.367</b>	<b>41.267</b>	<b>358.617</b>	<b>20.351</b>	<b>18.929</b>	<b>7.0%</b>

### Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	5.386	4.796	4.358	4.230	7.933	7.667	2.067	1.750	0.000	0.000	0.000	0.000
Off Peak	0.000	0.000	0.030	0.030	0.012	0.012	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>5.416</b>	<b>4.827</b>	<b>4.370</b>	<b>4.242</b>	<b>7.933</b>	<b>7.667</b>	<b>2.067</b>	<b>1.750</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	44.267	41.167	152.617	^ ^ ^ ^	20.304	18.882	7.0%
Off Peak	0.100	0.100	206.000		0.048	0.048	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>44.367</b>	<b>41.267</b>	<b>358.617</b>		<b>20.351</b>	<b>18.929</b>	<b>7.0%</b>



# Municipal Construction Office Lechner

Area type: Office. Logger: EDE8. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dff	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	22.983	11.089	18.750	9.047
Dff	27.983	10.000	0.417	0.149	0.417	0.149
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>23.400</b>	<b>11.238</b>	<b>19.167</b>	<b>9.195</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	17.233	8.617	14.533	7.267
Dff	20.000	10.000	0.033	0.017	0.033	0.017
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>17.267</b>	<b>8.633</b>	<b>14.567</b>	<b>7.283</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dff	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.717	14.000	11.717	4.130	7.417	2.614
Dff	22.017	10.000	0.950	0.250	0.950	0.250
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.733</b>	<b>24.000</b>	<b>12.267</b>	<b>4.380</b>	<b>7.967</b>	<b>2.864</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	24.300	12.150	19.667	9.833
Dff	20.000	10.000	0.467	0.233	0.467	0.233
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>24.767</b>	<b>12.383</b>	<b>20.133</b>	<b>10.067</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Dff	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals			% Savings
	Lites On	Occupied	Logged	Lites On	Occupied		
Peak	76.233	60.367	152.733	34.939	27.667	20.8%	
Dff Peak	1.467	1.467	206.000	0.698	0.698	0.0%	
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%	
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%	
<b>Total</b>	<b>77.700</b>	<b>61.833</b>	<b>358.733</b>	<b>35.637</b>	<b>28.365</b>	<b>20.4%</b>	

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	4.130	2.614	11.089	9.047	12.150	9.833	8.617	7.267	0.000	0.000	0.000	0.000
Dff Peak	0.000	0.000	0.250	0.250	0.149	0.149	0.233	0.233	0.017	0.017	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>4.380</b>	<b>2.864</b>	<b>11.238</b>	<b>9.195</b>	<b>12.383</b>	<b>10.067</b>	<b>8.633</b>	<b>7.283</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	76.233	60.367	152.733	^^ ^^	34.939	27.667	20.8%
Dff Peak	1.467	1.467	206.000		0.698	0.698	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>77.700</b>	<b>61.833</b>	<b>358.733</b>		<b>35.637</b>	<b>28.365</b>	<b>20.4%</b>



# Municipal Constuction Offices Kittchenette

Area type: Kitchen. Logger: EFEF. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.233	0.117	0.233	0.117
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.233</b>	<b>0.117</b>	<b>0.233</b>	<b>0.117</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	20.200	9.746	9.567	4.616
Dif	27.983	10.000	2.667	0.953	1.633	0.584
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>22.867</b>	<b>10.699</b>	<b>11.200</b>	<b>5.199</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	18.317	9.158	9.517	4.758
Dif	20.000	10.000	0.217	0.108	0.217	0.108
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>18.533</b>	<b>9.267</b>	<b>9.733</b>	<b>4.867</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.700	14.000	16.500	5.819	7.700	2.715
Dif	22.017	10.000	0.033	0.015	0.033	0.015
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.717</b>	<b>24.000</b>	<b>16.533</b>	<b>5.834</b>	<b>7.733</b>	<b>2.731</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	18.650	9.325	9.983	4.992
Dif	20.000	10.000	1.217	0.608	0.717	0.358
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>19.867</b>	<b>9.933</b>	<b>10.700</b>	<b>5.350</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.233	0.117	0.200	0.100
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.233</b>	<b>0.117</b>	<b>0.200</b>	<b>0.100</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	73.900	36.967	152.717	33.873	16.944	50.0%
Dif Peak	4.367	2.833	206.000	2.077	1.348	35.1%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>78.267</b>	<b>39.800</b>	<b>358.717</b>	<b>35.951</b>	<b>18.292</b>	<b>49.1%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	5.819	2.715	9.746	4.616	9.325	4.992	9.158	4.758	0.117	0.100	0.000	0.000
Dif Peak	0.117	0.117	0.015	0.015	0.953	0.584	0.608	0.358	0.108	0.108	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.117</b>	<b>0.117</b>	<b>5.834</b>	<b>2.731</b>	<b>10.699</b>	<b>5.199</b>	<b>9.933</b>	<b>5.350</b>	<b>9.267</b>	<b>4.867</b>	<b>0.117</b>	<b>0.100</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	73.900	36.967	152.717	^^ ^^	33.873	16.944	50.0%
Dif Peak	4.367	2.833	206.000		2.077	1.348	35.1%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>78.267</b>	<b>39.800</b>	<b>358.717</b>		<b>35.951</b>	<b>18.292</b>	<b>49.1%</b>



# Municipal Electrical Room

Area type: Mechanical. Logger: EEE4. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	7.317	3.530	0.300	0.145
Off	27.983	10.000	2.017	0.721	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>9.333</b>	<b>4.251</b>	<b>0.300</b>	<b>0.145</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.200	0.100	0.200	0.100
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.200</b>	<b>0.100</b>	<b>0.200</b>	<b>0.100</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.817	14.000	1.900	0.668	1.533	0.539
Off	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.833</b>	<b>24.000</b>	<b>1.900</b>	<b>0.668</b>	<b>1.533</b>	<b>0.539</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	1.350	0.675	0.533	0.267
Off	20.000	10.000	7.983	3.992	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>9.333</b>	<b>4.667</b>	<b>0.533</b>	<b>0.267</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.033	0.017	0.033	0.017
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.033</b>	<b>0.017</b>	<b>0.033</b>	<b>0.017</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	10.800	2.600	152.833	4.947	1.191	75.9%
Off Peak	10.000	0.000	206.000	4.757	0.000	100.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>20.800</b>	<b>2.600</b>	<b>358.833</b>	<b>9.704</b>	<b>1.191</b>	<b>87.7%</b>

### Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	0.668	0.539	3.530	0.145	0.675	0.267	0.100	0.100	0.017	0.017	0.000	0.000
Off Peak	0.000	0.000	0.000	0.000	0.721	0.000	3.992	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>0.668</b>	<b>0.539</b>	<b>4.251</b>	<b>0.145</b>	<b>4.667</b>	<b>0.267</b>	<b>0.100</b>	<b>0.100</b>	<b>0.017</b>	<b>0.017</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	10.800	2.600	152.833	^^ ^^	4.947	1.191	75.9%
Off Peak	10.000	0.000	206.000		4.757	0.000	100.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>20.800</b>	<b>2.600</b>	<b>358.833</b>	<b>9.704</b>	<b>1.191</b>	<b>87.7%</b>	



# Municipal Mayor Conference Room

Area type: Conference. Logger: ED69. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	6.667	3.217	6.067	2.927
Off	27.983	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>6.667</b>	<b>3.217</b>	<b>6.067</b>	<b>2.927</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	4.600	2.300	3.400	1.700
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>4.600</b>	<b>2.300</b>	<b>3.400</b>	<b>1.700</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.667	14.000	3.167	1.118	3.167	1.118
Off	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.683</b>	<b>24.000</b>	<b>3.167</b>	<b>1.118</b>	<b>3.167</b>	<b>1.118</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	7.167	3.583	6.600	3.300
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>7.167</b>	<b>3.583</b>	<b>6.600</b>	<b>3.300</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		% Savings
	Lites On	Occupied	Logged	Lites On	Occupied	
Peak	21.600	19.233	152.683	9.903	8.818	11.0%
Off Peak	0.000	0.000	206.000	0.000	0.000	0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>21.600</b>	<b>19.233</b>	<b>358.683</b>	<b>9.903</b>	<b>8.818</b>	<b>11.0%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	1.118	1.118	3.217	2.927	3.583	3.300	2.300	1.700	0.000	0.000	0.000	0.000
Off Peak	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>1.118</b>	<b>1.118</b>	<b>3.217</b>	<b>2.927</b>	<b>3.583</b>	<b>3.300</b>	<b>2.300</b>	<b>1.700</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	21.600	19.233	152.683	^^ ^^	9.903	8.818	11.0%
Off Peak	0.000	0.000	206.000		0.000	0.000	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>21.600</b>	<b>19.233</b>	<b>358.683</b>		<b>9.903</b>	<b>8.818</b>	<b>11.0%</b>

# Municipal Mayors Office

Area type: Office. Logger: EE56. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	6.733	3.367	1.800	0.900
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>6.733</b>	<b>3.367</b>	<b>1.800</b>	<b>0.900</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	20.083	9.690	9.750	4.704
Dif	27.983	10.000	0.267	0.095	0.233	0.083
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>20.350</b>	<b>9.785</b>	<b>9.983</b>	<b>4.788</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	20.367	10.183	8.500	4.250
Dif	20.000	10.000	0.267	0.133	0.267	0.133
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>20.633</b>	<b>10.317</b>	<b>8.767</b>	<b>4.383</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	40.033	14.000	19.033	6.656	6.333	2.215
Dif	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>62.050</b>	<b>24.000</b>	<b>19.033</b>	<b>6.656</b>	<b>6.333</b>	<b>2.215</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	23.133	11.567	14.133	7.067
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>23.133</b>	<b>11.567</b>	<b>14.133</b>	<b>7.067</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	1.733	0.867	1.667	0.833
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>1.733</b>	<b>0.867</b>	<b>1.667</b>	<b>0.833</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	84.350	40.383	153.050	38.579	18.470	52.1%
Dif Peak	7.267	2.300	206.000	3.457	1.094	68.3%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>91.617</b>	<b>42.683</b>	<b>359.050</b>	<b>42.036</b>	<b>19.564</b>	<b>53.5%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	6.656	2.215	9.690	4.704	11.567	7.067	10.183	4.250	0.867	0.833	0.000	0.000
Dif Peak	3.367	0.900	0.000	0.000	0.095	0.083	0.000	0.000	0.133	0.133	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>3.367</b>	<b>0.900</b>	<b>6.656</b>	<b>2.215</b>	<b>9.785</b>	<b>4.788</b>	<b>11.567</b>	<b>7.067</b>	<b>10.317</b>	<b>4.383</b>	<b>0.867</b>	<b>0.833</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	84.350	40.383	153.050	^ ^ ^ ^	38.579	18.470	52.1%
Dif Peak	7.267	2.300	206.000		3.457	1.094	68.3%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>91.617</b>	<b>42.683</b>	<b>359.050</b>		<b>42.036</b>	<b>19.564</b>	<b>53.5%</b>



# Municipal Mayors Office Kitchenette

Area type: Kitchen. Logger: ED77. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	2.167	1.045	1.533	0.740
Off	27.983	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>2.167</b>	<b>1.045</b>	<b>1.533</b>	<b>0.740</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	6.933	3.467	3.633	1.817
Off	20.000	10.000	0.367	0.183	0.200	0.100
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>7.300</b>	<b>3.650</b>	<b>3.833</b>	<b>1.917</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.933	14.000	7.367	2.583	3.067	1.075
Off	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.950</b>	<b>24.000</b>	<b>7.367</b>	<b>2.583</b>	<b>3.067</b>	<b>1.075</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.167	0.083	0.167	0.083
Off	20.000	10.000	0.033	0.017	0.033	0.017
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.200</b>	<b>0.100</b>	<b>0.200</b>	<b>0.100</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.133	0.067	0.133	0.067
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.133</b>	<b>0.067</b>	<b>0.133</b>	<b>0.067</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	16.767	8.533	152.950	7.674	3.905	49.1%
Off Peak	0.400	0.233	206.000	0.190	0.111	41.7%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>17.167</b>	<b>8.767</b>	<b>358.950</b>	<b>7.864</b>	<b>4.016</b>	<b>48.9%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	2.583	1.075	1.045	0.740	0.083	0.083	3.467	1.917	0.067	0.067	0.000	0.000
Off Peak	0.000	0.000	0.000	0.000	0.000	0.000	0.017	0.017	0.183	0.100	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>2.583</b>	<b>1.075</b>	<b>1.045</b>	<b>0.740</b>	<b>0.100</b>	<b>0.100</b>	<b>3.650</b>	<b>1.917</b>	<b>0.067</b>	<b>0.067</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	16.767	8.533	152.950	^ ^ ^ ^	7.674	3.905	49.1%
Off Peak	0.400	0.233	206.000		0.190	0.111	41.7%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>17.167</b>	<b>8.767</b>	<b>358.950</b>		<b>7.864</b>	<b>4.016</b>	<b>48.9%</b>

# Municipal Mens Room

Area type: Restroom. Logger: EDC3. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	16.683	8.342	0.633	0.317
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>16.683</b>	<b>8.342</b>	<b>0.633</b>	<b>0.317</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	21.267	10.261	9.383	4.527
Dif	27.983	10.000	13.117	4.687	0.367	0.131
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>34.383</b>	<b>14.948</b>	<b>9.750</b>	<b>4.658</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	19.283	9.642	5.100	2.550
Dif	20.000	10.000	17.983	8.992	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>37.267</b>	<b>18.633</b>	<b>5.100</b>	<b>2.550</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.367	0.183	0.367	0.183
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.367</b>	<b>0.183</b>	<b>0.367</b>	<b>0.183</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	40.250	14.000	20.900	7.270	7.900	2.748
Dif	22.017	10.000	7.200	3.270	0.067	0.030
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>62.267</b>	<b>24.000</b>	<b>28.100</b>	<b>10.540</b>	<b>7.967</b>	<b>2.778</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	21.600	10.800	5.900	2.950
Dif	20.000	10.000	17.500	8.750	0.033	0.017
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>39.100</b>	<b>19.550</b>	<b>5.933</b>	<b>2.967</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	10.383	5.192	1.550	0.775
Dif	20.000	10.000	8.267	4.133	0.017	0.008
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>18.650</b>	<b>9.325</b>	<b>1.567</b>	<b>0.783</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	93.433	29.833	153.267	42.673	13.625	68.1%
Dif Peak	81.117	1.483	206.000	38.589	0.706	98.2%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>174.550</b>	<b>31.317</b>	<b>359.267</b>	<b>81.262</b>	<b>14.331</b>	<b>82.4%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	7.270	2.748	10.261	4.527	10.800	2.950	9.642	2.550	5.192	0.775	0.000	0.000
Dif Peak	8.342	0.317	3.270	0.030	4.687	0.131	8.750	0.017	8.992	0.000	4.133	0.008	0.183	0.183
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>8.342</b>	<b>0.317</b>	<b>10.540</b>	<b>2.778</b>	<b>14.948</b>	<b>4.658</b>	<b>19.550</b>	<b>2.967</b>	<b>18.633</b>	<b>2.550</b>	<b>9.325</b>	<b>0.783</b>	<b>0.183</b>	<b>0.183</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	93.433	29.833	153.267	^ ^ ^ ^	42.673	13.625	68.1%
Dif Peak	81.117	1.483	206.000		38.589	0.706	98.2%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>174.550</b>	<b>31.317</b>	<b>359.267</b>		<b>81.262</b>	<b>14.331</b>	<b>82.4%</b>

# Municipal Tax Office Corner Office

Area type: Office. Logger: EDB3. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dff	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	20.183	9.738	14.783	7.133
Dff	27.983	10.000	0.167	0.060	0.167	0.060
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>20.350</b>	<b>9.798</b>	<b>14.950</b>	<b>7.192</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	12.733	6.367	7.733	3.867
Dff	20.000	10.000	0.167	0.083	0.167	0.083
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>12.900</b>	<b>6.450</b>	<b>7.900</b>	<b>3.950</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dff	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	40.417	14.000	13.050	4.520	3.483	1.207
Dff	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>62.433</b>	<b>24.000</b>	<b>13.050</b>	<b>4.520</b>	<b>3.483</b>	<b>1.207</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	18.600	9.300	16.933	8.467
Dff	20.000	10.000	0.233	0.117	0.233	0.117
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>18.833</b>	<b>9.417</b>	<b>17.167</b>	<b>8.583</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.933	0.467	0.933	0.467
Dff	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.933</b>	<b>0.467</b>	<b>0.933</b>	<b>0.467</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	65.500	43.867	153.433	29.883	20.013	33.0%
Dff Peak	0.567	0.567	206.000	0.270	0.270	0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>66.067</b>	<b>44.433</b>	<b>359.433</b>	<b>30.152</b>	<b>20.283</b>	<b>32.7%</b>

### Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	4.520	1.207	9.738	7.133	9.300	8.467	6.367	3.867	0.467	0.467	0.000	0.000
Dff Peak	0.000	0.000	0.000	0.000	0.060	0.060	0.117	0.117	0.083	0.083	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>4.520</b>	<b>1.207</b>	<b>9.798</b>	<b>7.192</b>	<b>9.417</b>	<b>8.583</b>	<b>6.450</b>	<b>3.950</b>	<b>0.467</b>	<b>0.467</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	65.500	43.867	153.433	^ ^ ^ ^	29.883	20.013	33.0%
Dff Peak	0.567	0.567	206.000		0.270	0.270	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>66.067</b>	<b>44.433</b>	<b>359.433</b>		<b>30.152</b>	<b>20.283</b>	<b>32.7%</b>



# Municipal Tax Office Storage

Area type: Storage. Logger: EFFB. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	40.383	14.000	17.950	6.223	10.950	3.796
Off	22.017	10.000	0.400	0.182	0.300	0.136
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>62.400</b>	<b>24.000</b>	<b>18.350</b>	<b>6.405</b>	<b>11.250</b>	<b>3.932</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	24.850	11.990	12.517	6.039
Off	27.983	10.000	2.617	0.935	0.567	0.203
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>27.467</b>	<b>12.925</b>	<b>13.083</b>	<b>6.242</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	19.500	9.750	12.367	6.183
Off	20.000	10.000	5.817	2.908	0.567	0.283
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>25.317</b>	<b>12.658</b>	<b>12.933</b>	<b>6.467</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	18.767	9.383	8.700	4.350
Off	20.000	10.000	0.167	0.083	0.167	0.083
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>18.933</b>	<b>9.467</b>	<b>8.867</b>	<b>4.433</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	1.333	0.667	0.800	0.400
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>1.333</b>	<b>0.667</b>	<b>0.800</b>	<b>0.400</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	82.400	45.333	153.400	37.601	20.687	45.0%
Off Peak	9.000	1.600	206.000	4.282	0.761	82.2%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>91.400</b>	<b>46.933</b>	<b>359.400</b>	<b>41.883</b>	<b>21.448</b>	<b>48.8%</b>

### Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	6.223	3.796	11.990	6.039	9.750	6.183	9.383	4.350	0.667	0.400	0.000	0.000
Off Peak	0.000	0.000	0.182	0.136	0.935	0.203	2.908	0.283	0.083	0.083	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>6.405</b>	<b>3.932</b>	<b>12.925</b>	<b>6.242</b>	<b>12.658</b>	<b>6.467</b>	<b>9.467</b>	<b>4.433</b>	<b>0.667</b>	<b>0.400</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	82.400	45.333	153.400	^^ ^^	37.601	20.687	45.0%
Off Peak	9.000	1.600	206.000		4.282	0.761	82.2%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>91.400</b>	<b>46.933</b>	<b>359.400</b>		<b>41.883</b>	<b>21.448</b>	<b>48.8%</b>



# Municipal Vital Statistics Office

Area type: Office. Logger: EFF4. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dff	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	21.400	10.325	21.367	10.309
Dff	27.983	10.000	1.633	0.584	1.633	0.584
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>23.033</b>	<b>10.909</b>	<b>23.000</b>	<b>10.893</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	18.967	9.483	18.067	9.033
Dff	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>18.967</b>	<b>9.483</b>	<b>18.067</b>	<b>9.033</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dff	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.817	14.000	17.200	6.048	17.100	6.013
Dff	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.833</b>	<b>24.000</b>	<b>17.200</b>	<b>6.048</b>	<b>17.100</b>	<b>6.013</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	19.450	9.725	17.883	8.942
Dff	20.000	10.000	0.117	0.058	0.117	0.058
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>19.567</b>	<b>9.783</b>	<b>18.000</b>	<b>9.000</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Dff	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		% Savings
	Lites On	Occupied	Logged	Lites On	Occupied	
Peak	77.017	74.417	152.833	35.275	34.084	3.4%
Dff Peak	1.750	1.750	206.000	0.833	0.833	0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>78.767</b>	<b>76.167</b>	<b>358.833</b>	<b>36.107</b>	<b>34.916</b>	<b>3.3%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	6.048	6.013	10.325	10.309	9.725	8.942	9.483	9.033	0.000	0.000	0.000	0.000
Dff Peak	0.000	0.000	0.000	0.000	0.584	0.584	0.058	0.058	0.000	0.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>6.048</b>	<b>6.013</b>	<b>10.909</b>	<b>10.893</b>	<b>9.783</b>	<b>9.000</b>	<b>9.483</b>	<b>9.033</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	77.017	74.417	152.833	^^ ^^	35.275	34.084	3.4%
Dff Peak	1.750	1.750	206.000		0.833	0.833	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>78.767</b>	<b>76.167</b>	<b>358.833</b>		<b>36.107</b>	<b>34.916</b>	<b>3.3%</b>



# Police Admin Area Conference Room

Area type: Conference. Logger: F008. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	2.500	1.250	0.300	0.150
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>2.500</b>	<b>1.250</b>	<b>0.300</b>	<b>0.150</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	22.817	11.009	8.433	4.069
Off	27.983	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>22.817</b>	<b>11.009</b>	<b>8.433</b>	<b>4.069</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	20.633	10.317	7.867	3.933
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>20.633</b>	<b>10.317</b>	<b>7.867</b>	<b>3.933</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.083	14.000	7.483	2.681	2.750	0.985
Off	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.100</b>	<b>24.000</b>	<b>7.483</b>	<b>2.681</b>	<b>2.750</b>	<b>0.985</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	23.133	11.567	8.200	4.100
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>23.133</b>	<b>11.567</b>	<b>8.200</b>	<b>4.100</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	1.333	0.667	0.667	0.333
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>1.333</b>	<b>0.667</b>	<b>0.667</b>	<b>0.333</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	75.400	27.917	152.100	34.701	12.848	63.0%
Off Peak	2.500	0.300	206.000	1.189	0.143	88.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>77.900</b>	<b>28.217</b>	<b>358.100</b>	<b>35.890</b>	<b>12.991</b>	<b>63.8%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	2.681	0.985	11.009	4.069	11.567	4.100	10.317	3.933	0.667	0.333	0.000	0.000
Off Peak	1.250	0.150	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>1.250</b>	<b>0.150</b>	<b>2.681</b>	<b>0.985</b>	<b>11.009</b>	<b>4.069</b>	<b>11.567</b>	<b>4.100</b>	<b>10.317</b>	<b>3.933</b>	<b>0.667</b>	<b>0.333</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	75.400	27.917	152.100	^ ^ ^ ^	34.701	12.848	63.0%
Off Peak	2.500	0.300	206.000		1.189	0.143	88.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>77.900</b>	<b>28.217</b>	<b>358.100</b>		<b>35.890</b>	<b>12.991</b>	<b>63.8%</b>



# Police Building Chief Office

Area type: Office. Logger: EE58. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	9.900	4.950	3.167	1.583
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>9.900</b>	<b>4.950</b>	<b>3.167</b>	<b>1.583</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	12.950	6.055	7.617	3.675
Dif	27.983	10.000	2.033	0.727	1.633	0.584
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>14.583</b>	<b>6.782</b>	<b>9.250</b>	<b>4.259</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	16.667	8.333	14.067	7.033
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>16.667</b>	<b>8.333</b>	<b>14.067</b>	<b>7.033</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.567	0.283	0.567	0.283
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.567</b>	<b>0.283</b>	<b>0.567</b>	<b>0.283</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.300	14.000	12.267	4.370	8.367	2.980
Dif	22.017	10.000	0.633	0.288	0.433	0.197
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.317</b>	<b>24.000</b>	<b>12.900</b>	<b>4.657</b>	<b>8.800</b>	<b>3.177</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	9.267	4.633	9.200	4.600
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>9.267</b>	<b>4.633</b>	<b>9.200</b>	<b>4.600</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	3.267	1.633	0.733	0.367
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>3.267</b>	<b>1.633</b>	<b>0.733</b>	<b>0.367</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	54.017	39.983	152.317	24.824	18.375	26.0%
Dif	13.133	5.800	206.000	6.248	2.759	55.8%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>67.150</b>	<b>45.783</b>	<b>358.317</b>	<b>31.072</b>	<b>21.134</b>	<b>32.0%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	4.370	2.980	6.055	3.675	4.633	4.600	8.333	7.033	1.633	0.367	0.000	0.000
Dif Peak	4.950	1.583	0.288	0.197	0.727	0.584	0.000	0.000	0.000	0.000	0.000	0.000	0.283	0.283
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>4.950</b>	<b>1.583</b>	<b>4.657</b>	<b>3.177</b>	<b>6.782</b>	<b>4.259</b>	<b>4.633</b>	<b>4.600</b>	<b>8.333</b>	<b>7.033</b>	<b>1.633</b>	<b>0.367</b>	<b>0.283</b>	<b>0.283</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	54.017	39.983	152.317	^^ ^^	24.824	18.375	26.0%
Dif Peak	13.133	5.800	206.000		6.248	2.759	55.8%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>67.150</b>	<b>45.783</b>	<b>358.317</b>		<b>31.072</b>	<b>21.134</b>	<b>32.0%</b>

# Police Building Dispatch Kitchenette

Area type: Kitchen. Logger: EE4C. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	10.567	5.283	6.667	3.333
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>10.567</b>	<b>5.283</b>	<b>6.667</b>	<b>3.333</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	2.650	1.279	0.933	0.450
Dif	27.983	10.000	13.950	4.985	2.817	1.007
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>16.600</b>	<b>6.264</b>	<b>3.750</b>	<b>1.457</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	4.600	2.300	1.033	0.517
Dif	20.000	10.000	1.383	0.692	0.750	0.375
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>5.983</b>	<b>2.992</b>	<b>1.783</b>	<b>0.892</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	2.467	1.233	1.267	0.633
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>2.467</b>	<b>1.233</b>	<b>1.267</b>	<b>0.633</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.200	14.000	8.433	3.012	2.900	1.036
Dif	22.017	10.000	1.750	0.795	0.917	0.416
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.217</b>	<b>24.000</b>	<b>10.183</b>	<b>3.807</b>	<b>3.817</b>	<b>1.452</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Dif	20.000	10.000	2.517	1.258	1.550	0.775
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>2.517</b>	<b>1.258</b>	<b>1.550</b>	<b>0.775</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	26.533	13.267	12.467	6.233
Dif	20.000	10.000	11.333	5.667	2.400	1.200
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>37.867</b>	<b>18.933</b>	<b>14.867</b>	<b>7.433</b>

	Logged Totals			Normalized Totals			% Savings
	Lites On	Occupied	Logged	Lites On	Occupied		
Peak	42.217	17.333	152.217	19.414	7.971	58.9%	
Dif Peak	43.967	16.367	206.000	20.916	7.786	62.8%	
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%	
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%	
<b>Total</b>	<b>86.183</b>	<b>33.700</b>	<b>358.217</b>	<b>40.330</b>	<b>15.757</b>	<b>60.9%</b>	



### Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	3.012	1.036	1.279	0.450	0.000	0.000	2.300	0.517	13.267	6.233	0.000	0.000
Dif Peak	5.283	3.333	0.795	0.416	4.985	1.007	1.258	0.775	0.692	0.375	5.667	1.200	1.233	0.633
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>5.283</b>	<b>3.333</b>	<b>3.807</b>	<b>1.452</b>	<b>6.264</b>	<b>1.457</b>	<b>1.258</b>	<b>0.775</b>	<b>2.992</b>	<b>0.892</b>	<b>18.933</b>	<b>7.433</b>	<b>1.233</b>	<b>0.633</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	42.217	17.333	152.217	^^ ^^	19.414	7.971	58.9%
Dif Peak	43.967	16.367	206.000		20.916	7.786	62.8%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>86.183</b>	<b>33.700</b>	<b>358.217</b>		<b>40.330</b>	<b>15.757</b>	<b>60.9%</b>



# Police Building Lt. Office

Area type: Office. Logger: EFEC. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	10.133	5.067	3.967	1.983
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>10.133</b>	<b>5.067</b>	<b>3.967</b>	<b>1.983</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	7.033	3.393	3.400	1.640
Dif	27.983	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>7.033</b>	<b>3.393</b>	<b>3.400</b>	<b>1.640</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	2.067	1.033	2.033	1.017
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>2.067</b>	<b>1.033</b>	<b>2.033</b>	<b>1.017</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	2.733	1.367	2.000	1.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>2.733</b>	<b>1.367</b>	<b>2.000</b>	<b>1.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.383	14.000	13.483	4.793	13.483	4.793
Dif	22.017	10.000	1.050	0.477	1.050	0.477
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.400</b>	<b>24.000</b>	<b>14.533</b>	<b>5.270</b>	<b>14.533</b>	<b>5.270</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	9.100	4.550	9.100	4.550
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>9.100</b>	<b>4.550</b>	<b>9.100</b>	<b>4.550</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	2.400	1.200	1.800	0.900
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>2.400</b>	<b>1.200</b>	<b>1.800</b>	<b>0.900</b>

	Logged Totals			Normalized Totals			% Savings
	Lites On	Occupied	Logged	Lites On	Occupied		
Peak	34.083	29.817	152.400	15.655	13.695		12.5%
Dif Peak	13.917	7.017	206.000	6.621	3.338		49.6%
Sh 1	0.000	0.000	0.000	0.000	0.000		0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000		0.0%
<b>Total</b>	<b>48.000</b>	<b>36.833</b>	<b>358.400</b>	<b>22.276</b>	<b>17.033</b>		<b>23.5%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	4.793	4.793	3.393	1.640	4.550	4.550	1.033	1.017	1.200	0.900	0.000	0.000
Dif Peak	5.067	1.983	0.477	0.477	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	1.367	1.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>5.067</b>	<b>1.983</b>	<b>5.270</b>	<b>5.270</b>	<b>3.393</b>	<b>1.640</b>	<b>4.550</b>	<b>4.550</b>	<b>1.033</b>	<b>1.017</b>	<b>1.200</b>	<b>0.900</b>	<b>1.367</b>	<b>1.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	34.083	29.817	152.400	^^ ^^	15.655	13.695	12.5%
Dif Peak	13.917	7.017	206.000		6.621	3.338	49.6%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>48.000</b>	<b>36.833</b>	<b>358.400</b>		<b>22.276</b>	<b>17.033</b>	<b>23.5%</b>



# Police Court Clerks Office

Area type: Open Office. Logger: EFFA. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.100	0.050	0.100	0.050
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.100</b>	<b>0.050</b>	<b>0.100</b>	<b>0.050</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.200	14.000	16.600	5.929	16.433	5.869
Off	22.017	10.000	0.767	0.348	0.733	0.333
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.217</b>	<b>24.000</b>	<b>17.367</b>	<b>6.277</b>	<b>17.167</b>	<b>6.202</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	21.483	10.365	21.183	10.221
Off	27.983	10.000	2.367	0.846	2.267	0.810
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>23.850</b>	<b>11.211</b>	<b>23.450</b>	<b>11.031</b>


Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	19.367	9.683	19.267	9.633
Off	20.000	10.000	1.933	0.967	1.800	0.900
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>21.300</b>	<b>10.650</b>	<b>21.067</b>	<b>10.533</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	19.400	9.700	19.233	9.617
Off	20.000	10.000	1.533	0.767	1.500	0.750
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>20.933</b>	<b>10.467</b>	<b>20.733</b>	<b>10.367</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	76.850	76.117	152.217	35.341	35.004	1.0%
Off Peak	6.700	6.400	206.000	3.187	3.045	4.5%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>83.550</b>	<b>82.517</b>	<b>358.217</b>	<b>38.528</b>	<b>38.048</b>	<b>1.2%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	5.929	5.869	10.365	10.221	9.683	9.633	9.700	9.617	0.000	0.000	0.000	0.000
Off Peak	0.050	0.050	0.348	0.333	0.846	0.810	0.967	0.900	0.767	0.750	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.050</b>	<b>0.050</b>	<b>6.277</b>	<b>6.202</b>	<b>11.211</b>	<b>11.031</b>	<b>10.650</b>	<b>10.533</b>	<b>10.467</b>	<b>10.367</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	76.850	76.117	152.217	^^ ^^	35.341	35.004	1.0%
Off Peak	6.700	6.400	206.000		3.187	3.045	4.5%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>83.550</b>	<b>82.517</b>	<b>358.217</b>		<b>38.528</b>	<b>38.048</b>	<b>1.2%</b>

# Police Mens Room

Area type: Restroom. Logger: F010. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	6.317	3.158	2.250	1.125
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>6.317</b>	<b>3.158</b>	<b>2.250</b>	<b>1.125</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	12.433	5.999	4.467	2.155
Dif	27.983	10.000	2.283	0.816	0.267	0.095
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>14.717</b>	<b>6.815</b>	<b>4.733</b>	<b>2.250</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	17.400	8.700	3.333	1.667
Dif	20.000	10.000	10.417	5.208	0.667	0.333
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>27.817</b>	<b>13.908</b>	<b>4.000</b>	<b>2.000</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	21.500	10.750	2.183	1.092
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>21.500</b>	<b>10.750</b>	<b>2.183</b>	<b>1.092</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	39.067	14.000	14.833	5.316	3.400	1.218
Dif	22.017	10.000	8.417	3.823	0.483	0.220
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>61.083</b>	<b>24.000</b>	<b>23.250</b>	<b>9.139</b>	<b>3.883</b>	<b>1.438</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	8.133	4.067	2.633	1.317
Dif	20.000	10.000	8.517	4.258	0.300	0.150
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>16.650</b>	<b>8.325</b>	<b>2.933</b>	<b>1.467</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	13.167	6.583	1.433	0.717
Dif	20.000	10.000	11.950	5.975	0.417	0.208
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>25.117</b>	<b>12.558</b>	<b>1.950</b>	<b>0.925</b>

	Logged Totals			Normalized Totals			% Savings
	Lites On	Occupied	Logged	Lites On	Occupied		
Peak	65.967	15.267	152.083	30.363	7.027		76.9%
Dif	69.400	6.567	206.000	33.016	3.124		90.5%
Sh 1	0.000	0.000	0.000	0.000	0.000		0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000		0.0%
<b>Total</b>	<b>135.367</b>	<b>21.833</b>	<b>358.083</b>	<b>63.378</b>	<b>10.151</b>		<b>84.0%</b>



### Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	5.316	1.218	5.999	2.155	4.067	1.317	8.700	1.667	6.583	0.717	0.000	0.000
Dif Peak	3.158	1.125	3.823	0.220	0.816	0.095	4.258	0.150	5.208	0.333	5.975	0.208	10.750	1.092
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>3.158</b>	<b>1.125</b>	<b>9.139</b>	<b>1.438</b>	<b>6.815</b>	<b>2.250</b>	<b>8.325</b>	<b>1.467</b>	<b>13.908</b>	<b>2.000</b>	<b>12.558</b>	<b>0.925</b>	<b>10.750</b>	<b>1.092</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	65.967	15.267	152.083	^ ^ ^ ^	30.363	7.027	76.9%
Dif Peak	69.400	6.567	206.000		33.016	3.124	90.5%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>135.367</b>	<b>21.833</b>	<b>358.083</b>		<b>63.378</b>	<b>10.151</b>	<b>84.0%</b>

# Police Squad Room

Area type: Open Office. Logger: EF77. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	37.750	18.875	28.167	14.083
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>37.750</b>	<b>18.875</b>	<b>28.167</b>	<b>14.083</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	15.017	14.000	13.650	12.726	12.850	11.980
Dif	17.983	10.000	17.983	10.000	15.617	8.684
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>33.000</b>	<b>24.000</b>	<b>31.633</b>	<b>22.726</b>	<b>28.467</b>	<b>20.664</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	26.133	13.067	24.200	12.100
Dif	20.000	10.000	18.233	9.117	13.733	6.867
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>44.367</b>	<b>22.183</b>	<b>37.933</b>	<b>18.967</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	40.883	20.442	34.517	17.258
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>40.883</b>	<b>20.442</b>	<b>34.517</b>	<b>17.258</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	22.333	11.167	19.733	9.867
Dif	20.000	10.000	18.467	9.233	17.117	8.558
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>40.800</b>	<b>20.400</b>	<b>36.850</b>	<b>18.425</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	16.200	14.000	14.533	12.560	12.400	10.716
Dif	12.017	10.000	11.650	9.695	11.517	9.584
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>28.217</b>	<b>24.000</b>	<b>26.183</b>	<b>22.255</b>	<b>23.917</b>	<b>20.300</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	22.900	11.450	20.133	10.067
Dif	20.000	10.000	19.300	9.650	16.467	8.233
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>42.200</b>	<b>21.100</b>	<b>36.600</b>	<b>18.300</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	99.550	89.317	115.217	60.482	54.264	10.3%
Dif Peak	164.267	137.133	186.000	86.549	72.253	16.5%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>263.817</b>	<b>226.450</b>	<b>301.217</b>	<b>147.031</b>	<b>126.518</b>	<b>14.0%</b>



### Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	11.167	9.867	12.726	11.980	12.560	11.450	13.067	12.100	11.450	10.067	0.000	0.000
Dif Peak	18.875	14.083	9.233	8.558	10.000	8.684	9.695	9.584	9.117	6.867	9.650	8.233	20.442	17.258
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>18.875</b>	<b>14.083</b>	<b>20.400</b>	<b>18.425</b>	<b>22.726</b>	<b>20.664</b>	<b>22.255</b>	<b>20.300</b>	<b>22.183</b>	<b>18.967</b>	<b>21.100</b>	<b>18.300</b>	<b>20.442</b>	<b>17.258</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	99.550	89.317	115.217	^^ ^^	60.482	54.264	10.3%
Dif Peak	164.267	137.133	186.000		86.549	72.253	16.5%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>263.817</b>	<b>226.450</b>	<b>301.217</b>		<b>147.031</b>	<b>126.518</b>	<b>14.0%</b>

# Public Works Conference Room

Area type: Conference. Logger: F00E. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

<b>Sun</b>	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	0.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

<b>Mon</b>	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	10.267	14.000	0.067	0.091	0.067	0.091
Off	2.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>12.283</b>	<b>24.000</b>	<b>0.067</b>	<b>0.091</b>	<b>0.067</b>	<b>0.091</b>

<b>Tue</b>	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	14.000	14.000	0.000	0.000	0.000	0.000
Off	10.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>


<b>Wed</b>	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	14.000	14.000	1.800	1.800	1.233	1.233
Off	10.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>24.000</b>	<b>1.800</b>	<b>1.800</b>	<b>1.233</b>	<b>1.233</b>

<b>Thu</b>	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	14.000	14.000	2.900	2.900	0.733	0.733
Off	10.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>24.000</b>	<b>2.900</b>	<b>2.900</b>	<b>0.733</b>	<b>0.733</b>

<b>Fri</b>	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	4.750	14.000	0.100	0.295	0.100	0.295
Off	7.983	10.000	0.100	0.125	0.100	0.125
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>12.733</b>	<b>24.000</b>	<b>0.200</b>	<b>0.420</b>	<b>0.200</b>	<b>0.420</b>

<b>Sat</b>	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	0.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	4.867	2.133	57.017	5.975	2.619	56.2%
Off Peak	0.100	0.100	40.000	0.245	0.245	0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>4.967</b>	<b>2.233</b>	<b>97.017</b>	<b>6.220</b>	<b>2.864</b>	<b>54.0%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	0.091	0.091	0.000	0.000	1.800	1.233	2.900	0.733	0.295	0.295	0.000	0.000
Off Peak	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.125	0.125	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>0.091</b>	<b>0.091</b>	<b>0.000</b>	<b>0.000</b>	<b>1.800</b>	<b>1.233</b>	<b>2.900</b>	<b>0.733</b>	<b>0.420</b>	<b>0.420</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	4.867	2.133	57.017	^^ ^^	5.975	2.619	56.2%
Off Peak	0.100	0.100	40.000		0.245	0.245	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>4.967</b>	<b>2.233</b>	<b>97.017</b>		<b>6.220</b>	<b>2.864</b>	<b>54.0%</b>

# Public Works Front Office

Area type: Open Office. Logger: EF5D. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	1.767	0.883	1.600	0.800
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>1.767</b>	<b>0.883</b>	<b>1.600</b>	<b>0.800</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	20.250	9.770	18.767	9.055
Off	27.983	10.000	9.550	3.413	4.700	1.680
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>29.800</b>	<b>13.183</b>	<b>23.467</b>	<b>10.734</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	19.367	9.683	18.633	9.317
Off	20.000	10.000	3.900	1.950	2.533	1.267
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>23.267</b>	<b>11.633</b>	<b>21.167</b>	<b>10.583</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	38.183	14.000	15.417	5.653	14.100	5.170
Off	22.017	10.000	1.883	0.855	1.067	0.484
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>60.200</b>	<b>24.000</b>	<b>17.300</b>	<b>6.508</b>	<b>15.167</b>	<b>5.654</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	19.967	9.983	19.167	9.583
Off	20.000	10.000	4.467	2.233	2.833	1.417
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>24.433</b>	<b>12.217</b>	<b>22.000</b>	<b>11.000</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	7.817	3.908	5.633	2.817
Off	20.000	10.000	2.083	1.042	1.367	0.683
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>9.900</b>	<b>4.950</b>	<b>7.000</b>	<b>3.500</b>

	Logged Totals			Normalized Totals			% Savings
	Lites On	Occupied	Logged	Lites On	Occupied		
Peak	82.817	76.300	151.200	38.341	35.324	7.9%	
Off Peak	23.650	14.100	206.000	11.251	6.708	40.4%	
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%	
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%	
<b>Total</b>	<b>106.467</b>	<b>90.400</b>	<b>357.200</b>	<b>49.592</b>	<b>42.032</b>	<b>15.2%</b>	



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	5.653	5.170	9.770	9.055	9.983	9.583	9.683	9.317	3.908	2.817	0.000	0.000
Off Peak	0.883	0.800	0.855	0.484	3.413	1.680	2.233	1.417	1.950	1.267	1.042	0.683	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.883</b>	<b>0.800</b>	<b>6.508</b>	<b>5.654</b>	<b>13.183</b>	<b>10.734</b>	<b>12.217</b>	<b>11.000</b>	<b>11.633</b>	<b>10.583</b>	<b>4.950</b>	<b>3.500</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	82.817	76.300	151.200	^^ ^^	38.341	35.324	7.9%
Off Peak	23.650	14.100	206.000		11.251	6.708	40.4%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>106.467</b>	<b>90.400</b>	<b>357.200</b>		<b>49.592</b>	<b>42.032</b>	<b>15.2%</b>

# Public Works Hallway

Area type: Hallway. Logger: EF58. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	48.000	24.000	4.267	2.133
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>48.000</b>	<b>24.000</b>	<b>4.267</b>	<b>2.133</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	38.117	14.000	38.117	14.000	7.967	2.926
Off	22.017	10.000	22.017	10.000	0.867	0.394
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>60.133</b>	<b>24.000</b>	<b>60.133</b>	<b>24.000</b>	<b>8.833</b>	<b>3.320</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	29.017	14.000	11.883	5.733
Off	27.983	10.000	27.983	10.000	3.033	1.084
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>57.000</b>	<b>24.000</b>	<b>14.917</b>	<b>6.817</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	28.000	14.000	12.683	6.342
Off	20.000	10.000	20.000	10.000	1.950	0.975
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>48.000</b>	<b>24.000</b>	<b>14.633</b>	<b>7.317</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	28.000	14.000	11.617	5.808
Off	20.000	10.000	20.000	10.000	1.850	0.925
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>48.000</b>	<b>24.000</b>	<b>13.467</b>	<b>6.733</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	28.000	14.000	3.567	1.783
Off	20.000	10.000	20.000	10.000	0.900	0.450
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>48.000</b>	<b>24.000</b>	<b>4.467</b>	<b>2.233</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	48.000	24.000	1.467	0.733
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>48.000</b>	<b>24.000</b>	<b>1.467</b>	<b>0.733</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	151.133	47.717	151.133	70.000	22.101	68.4%
Off Peak	206.000	14.333	206.000	98.000	6.819	93.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>357.133</b>	<b>62.050</b>	<b>357.133</b>	<b>168.000</b>	<b>28.920</b>	<b>82.8%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	14.000	2.926	14.000	5.733	14.000	6.342	14.000	5.808	14.000	1.783	0.000	0.000
Off Peak	24.000	2.133	10.000	0.394	10.000	1.084	10.000	0.975	10.000	0.925	10.000	0.450	24.000	0.733
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>2.133</b>	<b>24.000</b>	<b>3.320</b>	<b>24.000</b>	<b>6.817</b>	<b>24.000</b>	<b>7.317</b>	<b>24.000</b>	<b>6.733</b>	<b>24.000</b>	<b>2.233</b>	<b>24.000</b>	<b>0.733</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	151.133	47.717	151.133	^^ ^^	70.000	22.101	68.4%
Off Peak	206.000	14.333	206.000		98.000	6.819	93.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>357.133</b>	<b>62.050</b>	<b>357.133</b>		<b>168.000</b>	<b>28.920</b>	<b>82.8%</b>



# Public Works Lunch Room

Area type: Cafeteria. Logger: EF59. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	5.233	2.617	3.267	1.633
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>5.233</b>	<b>2.617</b>	<b>3.267</b>	<b>1.633</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	1.400	0.675	1.033	0.499
Off	27.983	10.000	6.000	2.144	5.600	2.001
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>7.400</b>	<b>2.820</b>	<b>6.633</b>	<b>2.500</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	7.800	3.900	5.533	2.787
Off	20.000	10.000	3.233	1.617	3.133	1.567
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>11.033</b>	<b>5.517</b>	<b>8.667</b>	<b>4.333</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	2.767	1.383	2.633	1.317
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>2.767</b>	<b>1.383</b>	<b>2.633</b>	<b>1.317</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	38.000	14.000	2.800	1.032	0.833	0.307
Off	22.017	10.000	1.867	0.848	1.667	0.757
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>60.017</b>	<b>24.000</b>	<b>4.667</b>	<b>1.879</b>	<b>2.500</b>	<b>1.064</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	10.233	5.117	7.467	3.733
Off	20.000	10.000	4.067	2.033	3.833	1.917
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>14.300</b>	<b>7.150</b>	<b>11.300</b>	<b>5.650</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	1.433	0.717	1.300	0.650
Off	20.000	10.000	2.000	1.000	1.533	0.767
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>3.433</b>	<b>1.717</b>	<b>2.833</b>	<b>1.417</b>

	Logged Totals			Normalized Totals		% Savings
	Lites On	Occupied	Logged	Lites On	Occupied	
Peak	23.667	16.167	151.017	10.970	7.494	31.7%
Off Peak	25.167	21.667	206.000	11.972	10.307	13.9%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>48.833</b>	<b>37.833</b>	<b>357.017</b>	<b>22.943</b>	<b>17.801</b>	<b>22.4%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	1.032	0.307	0.675	0.499	5.117	3.733	3.900	2.767	0.717	0.650	0.000	0.000
Off Peak	2.617	1.633	0.848	0.757	2.144	2.001	2.033	1.917	1.617	1.567	1.000	0.767	1.383	1.317
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>2.617</b>	<b>1.633</b>	<b>1.879</b>	<b>1.064</b>	<b>2.820</b>	<b>2.500</b>	<b>7.150</b>	<b>5.650</b>	<b>5.517</b>	<b>4.333</b>	<b>1.717</b>	<b>1.417</b>	<b>1.383</b>	<b>1.317</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	23.667	16.167	151.017	^ ^ ^ ^	10.970	7.494	31.7%
Off Peak	25.167	21.667	206.000		11.972	10.307	13.9%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>48.833</b>	<b>37.833</b>	<b>357.017</b>		<b>22.943</b>	<b>17.801</b>	<b>22.4%</b>



# Public Works Supervisors Office

Area type: Private Office. Logger: EF28. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	11.233	5.617	7.967	3.983
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>11.233</b>	<b>5.617</b>	<b>7.967</b>	<b>3.983</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	16.250	7.840	14.150	6.827
Off	27.983	10.000	6.817	2.436	6.150	2.198
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>23.067</b>	<b>10.276</b>	<b>20.300</b>	<b>9.025</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	17.000	8.500	16.000	8.000
Off	20.000	10.000	4.100	2.050	3.967	1.983
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>21.100</b>	<b>10.550</b>	<b>19.967</b>	<b>9.983</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	6.367	3.183	4.133	2.067
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>6.367</b>	<b>3.183</b>	<b>4.133</b>	<b>2.067</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	38.083	14.000	5.183	1.905	4.683	1.722
Off	22.017	10.000	1.983	0.901	1.850	0.840
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>60.100</b>	<b>24.000</b>	<b>7.167</b>	<b>2.806</b>	<b>6.533</b>	<b>2.562</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	18.400	9.200	16.350	8.175
Off	20.000	10.000	4.167	2.083	4.083	2.042
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>22.567</b>	<b>11.283</b>	<b>20.433</b>	<b>10.217</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	2.833	1.417	2.833	1.417
Off	20.000	10.000	2.133	1.067	1.833	0.917
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>4.967</b>	<b>2.483</b>	<b>4.667</b>	<b>2.333</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	59.667	54.017	151.100	27.642	25.024	9.5%
Off Peak	36.800	29.983	206.000	17.507	14.264	18.5%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>96.467</b>	<b>84.000</b>	<b>357.100</b>	<b>45.149</b>	<b>39.288</b>	<b>13.0%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	1.905	1.722	7.840	6.827	9.200	8.175	8.500	8.000	1.417	1.417	0.000	0.000
Off Peak	5.617	3.983	0.901	0.840	2.436	2.198	2.083	2.042	2.050	1.983	1.067	0.917	3.183	2.067
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>5.617</b>	<b>3.983</b>	<b>2.806</b>	<b>2.562</b>	<b>10.276</b>	<b>9.025</b>	<b>11.283</b>	<b>10.217</b>	<b>10.550</b>	<b>9.983</b>	<b>2.483</b>	<b>2.333</b>	<b>3.183</b>	<b>2.067</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	59.667	54.017	151.100	^^ ^^	27.642	25.024	9.5%
Off Peak	36.800	29.983	206.000		17.507	14.264	18.5%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>96.467</b>	<b>84.000</b>	<b>357.100</b>		<b>45.149</b>	<b>39.288</b>	<b>13.0%</b>

# Recreation Center Buisness Office

Area type: General Office. Logger: EF6C. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	38.567	14.000	16.467	5.978	16.467	5.978
Off	22.017	10.000	0.083	0.038	0.083	0.038
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>60.583</b>	<b>24.000</b>	<b>16.550</b>	<b>6.015</b>	<b>16.550</b>	<b>6.015</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	22.400	10.808	22.200	10.711
Off	27.983	10.000	1.633	0.584	1.467	0.524
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>24.033</b>	<b>11.391</b>	<b>23.667</b>	<b>11.235</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	22.100	11.050	19.967	9.983
Off	20.000	10.000	0.033	0.017	0.033	0.017
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>22.133</b>	<b>11.067</b>	<b>20.000</b>	<b>10.000</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	21.450	10.725	21.450	10.725
Off	20.000	10.000	0.250	0.125	0.250	0.125
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>21.700</b>	<b>10.950</b>	<b>21.700</b>	<b>10.850</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Off	20.000	10.000	0.733	0.367	0.733	0.367
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.733</b>	<b>0.367</b>	<b>0.733</b>	<b>0.367</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	1.433	0.717	1.433	0.717
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>1.433</b>	<b>0.717</b>	<b>1.433</b>	<b>0.717</b>

	Logged Totals			Normalized Totals		% Savings
	Lites On	Occupied	Logged	Lites On	Occupied	
Peak	82.417	80.083	151.583	38.059	36.982	2.8%
Off Peak	4.167	4.000	206.000	1.982	1.903	4.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>86.583</b>	<b>84.083</b>	<b>357.583</b>	<b>40.042</b>	<b>38.885</b>	<b>2.9%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	5.978	5.978	10.808	10.711	11.050	9.983	10.725	10.725	0.000	0.000	0.000	0.000
Off Peak	0.000	0.000	0.038	0.038	0.584	0.524	0.017	0.017	0.125	0.125	0.367	0.367	0.717	0.717
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>6.015</b>	<b>6.015</b>	<b>11.391</b>	<b>11.235</b>	<b>11.067</b>	<b>10.000</b>	<b>10.850</b>	<b>10.850</b>	<b>0.367</b>	<b>0.367</b>	<b>0.717</b>	<b>0.717</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	82.417	80.083	151.583	^ ^ ^ ^	38.059	36.982	2.8%
Off Peak	4.167	4.000	206.000		1.982	1.903	4.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>86.583</b>	<b>84.083</b>	<b>357.583</b>		<b>40.042</b>	<b>38.885</b>	<b>2.9%</b>



# Recreation Center Electrical Room

Area type: Mechanical. Logger: EF94. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	18.583	8.966	5.650	2.726
Dif	27.983	10.000	9.517	3.401	0.850	0.304
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>28.100</b>	<b>12.367</b>	<b>6.500</b>	<b>3.030</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	17.183	8.592	12.617	6.308
Dif	20.000	10.000	0.117	0.058	0.117	0.058
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>17.300</b>	<b>8.650</b>	<b>12.733</b>	<b>6.367</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	38.517	14.000	20.383	7.409	6.333	2.302
Dif	22.017	10.000	2.017	0.916	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>60.533</b>	<b>24.000</b>	<b>22.400</b>	<b>8.325</b>	<b>6.333</b>	<b>2.302</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	20.633	10.317	12.633	6.317
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>20.633</b>	<b>10.317</b>	<b>12.633</b>	<b>6.317</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	17.600	8.800	9.950	4.975
Dif	20.000	10.000	1.467	0.733	0.583	0.292
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>19.067</b>	<b>9.533</b>	<b>10.533</b>	<b>5.267</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	94.383	47.183	151.533	43.600	21.796	50.0%
Dif Peak	13.117	1.550	206.000	6.240	0.737	88.2%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>107.500</b>	<b>48.733</b>	<b>357.533</b>	<b>49.840</b>	<b>22.533</b>	<b>54.8%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	7.409	2.302	8.966	2.726	10.317	6.317	8.592	6.308	8.800	4.975	0.000	0.000
Dif Peak	0.000	0.000	0.916	0.000	3.401	0.304	0.000	0.000	0.058	0.058	0.733	0.292	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>8.325</b>	<b>2.302</b>	<b>12.367</b>	<b>3.030</b>	<b>10.317</b>	<b>6.317</b>	<b>8.650</b>	<b>6.367</b>	<b>9.533</b>	<b>5.267</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	94.383	47.183	151.533	^^ ^^	43.600	21.796	50.0%
Dif Peak	13.117	1.550	206.000		6.240	0.737	88.2%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>107.500</b>	<b>48.733</b>	<b>357.533</b>		<b>49.840</b>	<b>22.533</b>	<b>54.8%</b>

# Recreation Center Game Storage

Area type: Storage. Logger: EEEE. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	24.000	12.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>24.000</b>	<b>12.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	11.533	5.565	6.900	3.329
Off	27.983	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>11.533</b>	<b>5.565</b>	<b>6.900</b>	<b>3.329</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	10.050	5.025	1.267	0.633
Off	20.000	10.000	7.983	3.992	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>18.033</b>	<b>9.017</b>	<b>1.267</b>	<b>0.633</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	40.300	20.150	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>40.300</b>	<b>20.150</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	38.650	14.000	9.817	3.556	5.867	2.125
Off	22.017	10.000	7.983	3.626	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>60.667</b>	<b>24.000</b>	<b>17.800</b>	<b>7.182</b>	<b>5.867</b>	<b>2.125</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	16.450	8.225	6.833	3.417
Off	20.000	10.000	2.017	1.008	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>18.467</b>	<b>9.233</b>	<b>6.833</b>	<b>3.417</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	23.467	11.733	0.667	0.333
Off	20.000	10.000	4.033	2.017	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>27.500</b>	<b>13.750</b>	<b>0.667</b>	<b>0.333</b>

	Logged Totals			Normalized Totals			% Savings
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings	
Peak	71.317	21.533	151.667	32.915	9.938	69.8%	
Off Peak	86.317	0.000	206.000	41.063	0.000	100.0%	
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%	
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%	
<b>Total</b>	<b>157.633</b>	<b>21.533</b>	<b>357.667</b>	<b>73.979</b>	<b>9.938</b>	<b>86.6%</b>	



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	3.556	2.125	5.565	3.329	8.225	3.417	5.025	0.633	11.733	0.333	0.000	0.000
Off Peak	12.000	0.000	3.626	0.000	0.000	0.000	1.008	0.000	3.992	0.000	2.017	0.000	20.150	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>12.000</b>	<b>0.000</b>	<b>7.182</b>	<b>2.125</b>	<b>5.565</b>	<b>3.329</b>	<b>9.233</b>	<b>3.417</b>	<b>9.017</b>	<b>0.633</b>	<b>13.750</b>	<b>0.333</b>	<b>20.150</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	71.317	21.533	151.667	^ ^ ^ ^	32.915	9.938	69.8%
Off Peak	86.317	0.000	206.000		41.063	0.000	100.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>157.633</b>	<b>21.533</b>	<b>357.667</b>		<b>73.979</b>	<b>9.938</b>	<b>86.6%</b>

# Recreation Center Mens Room

Area type: Restroom. Logger: EE17. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	20.950	9.915	4.483	2.163
Off	27.983	10.000	1.333	0.476	0.367	0.131
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>21.883</b>	<b>10.391</b>	<b>4.850</b>	<b>2.294</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	21.033	10.517	5.933	2.967
Off	20.000	10.000	0.133	0.067	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>21.167</b>	<b>10.583</b>	<b>5.933</b>	<b>2.967</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Off	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	38.667	14.000	16.167	5.853	4.167	1.509
Off	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>60.683</b>	<b>24.000</b>	<b>16.167</b>	<b>5.853</b>	<b>4.167</b>	<b>1.509</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	20.367	10.183	5.633	2.817
Off	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>20.367</b>	<b>10.183</b>	<b>5.633</b>	<b>2.817</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	17.533	8.767	4.433	2.217
Off	20.000	10.000	1.433	0.717	0.400	0.200
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>18.967</b>	<b>9.483</b>	<b>4.833</b>	<b>2.417</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	95.650	24.650	151.683	44.141	11.376	74.2%
Off Peak	2.900	0.767	206.000	1.380	0.365	73.6%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>98.550</b>	<b>25.417</b>	<b>357.683</b>	<b>45.521</b>	<b>11.740</b>	<b>74.2%</b>

## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	5.853	1.509	9.915	2.163	10.183	2.817	10.517	2.967	8.767	2.217	0.000	0.000
Off Peak	0.000	0.000	0.000	0.000	0.476	0.131	0.000	0.000	0.067	0.000	0.717	0.200	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>5.853</b>	<b>1.509</b>	<b>10.391</b>	<b>2.294</b>	<b>10.183</b>	<b>2.817</b>	<b>10.583</b>	<b>2.967</b>	<b>9.483</b>	<b>2.417</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	95.650	24.650	151.683	^^ ^^	44.141	11.376	74.2%
Off Peak	2.900	0.767	206.000		1.380	0.365	73.6%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>98.550</b>	<b>25.417</b>	<b>357.683</b>		<b>45.521</b>	<b>11.740</b>	<b>74.2%</b>



# Senior Center Kitchen

Area type: Kitchen. Logger: EEE3. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	24.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	14.000	14.000	0.067	0.067	0.067	0.067
Dif	10.000	10.000	0.100	0.100	0.100	0.100
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>24.000</b>	<b>0.167</b>	<b>0.167</b>	<b>0.167</b>	<b>0.167</b>


Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	24.000	24.000	6.867	6.867	3.400	3.400
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>24.000</b>	<b>6.867</b>	<b>6.867</b>	<b>3.400</b>	<b>3.400</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	26.550	14.000	0.200	0.105	0.200	0.105
Dif	12.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>38.567</b>	<b>24.000</b>	<b>0.200</b>	<b>0.105</b>	<b>0.200</b>	<b>0.105</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	14.000	14.000	3.367	3.367	3.333	3.333
Dif	17.167	10.000	0.067	0.039	0.067	0.039
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>31.167</b>	<b>24.000</b>	<b>3.433</b>	<b>3.406</b>	<b>3.400</b>	<b>3.372</b>

Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	14.000	14.000	0.000	0.000	0.000	0.000
Dif	10.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>24.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		
	Lites On	Occupied	Logged	Lites On	Occupied	% Savings
Peak	3.633	3.600	96.550	2.634	2.610	0.9%
Dif Peak	7.033	3.567	117.183	5.882	2.983	49.3%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>10.667</b>	<b>7.167</b>	<b>213.733</b>	<b>8.516</b>	<b>5.593</b>	<b>34.3%</b>



## Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	0.105	0.105	0.000	0.000	3.367	3.333	0.067	0.067	0.000	0.000	0.000	0.000
Dif Peak	0.000	0.000	0.000	0.000	0.000	0.000	0.039	0.039	0.100	0.100	0.000	0.000	6.867	3.400
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>0.105</b>	<b>0.105</b>	<b>0.000</b>	<b>0.000</b>	<b>3.406</b>	<b>3.372</b>	<b>0.167</b>	<b>0.167</b>	<b>0.000</b>	<b>0.000</b>	<b>6.867</b>	<b>3.400</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	3.633	3.600	96.550	^^ ^^	2.634	2.610	0.9%
Dif Peak	7.033	3.567	117.183		5.882	2.983	49.3%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>10.667</b>	<b>7.167</b>	<b>213.733</b>		<b>8.516</b>	<b>5.593</b>	<b>34.3%</b>

# Senior Center Meeting Room

Area type: Meeting Rooms. Logger: EDF4. Time delay 10 minutes. Concord Engineering, Gloucester Township ESIP

## Energy Analysis

### Data by Day of Week

Sun	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

Tue	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	29.017	14.000	4.433	2.139	4.433	2.139
Dif	27.983	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>57.000</b>	<b>24.000</b>	<b>4.433</b>	<b>2.139</b>	<b>4.433</b>	<b>2.139</b>

Thu	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	2.567	1.283	2.567	1.283
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>2.567</b>	<b>1.283</b>	<b>2.567</b>	<b>1.283</b>

Sat	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	0.000	0.000	0.000	0.000	0.000	0.000
Dif	48.000	24.000	8.733	4.367	8.733	4.367
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>8.733</b>	<b>4.367</b>	<b>8.733</b>	<b>4.367</b>

Mon	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	40.383	14.000	3.133	1.086	3.133	1.086
Dif	22.017	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>62.400</b>	<b>24.000</b>	<b>3.133</b>	<b>1.086</b>	<b>3.133</b>	<b>1.086</b>

Wed	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	9.467	4.733	9.467	4.733
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>9.467</b>	<b>4.733</b>	<b>9.467</b>	<b>4.733</b>


Fri	Total Log Time	Hours /Day	Logged Lites On	Normlzd Lites On per Day	Logged Occ	Normlzd Occ per Day
Peak	28.000	14.000	0.000	0.000	0.000	0.000
Dif	20.000	10.000	0.000	0.000	0.000	0.000
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>48.000</b>	<b>24.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>	<b>0.000</b>

	Logged Totals			Normalized Totals		% Savings
	Lites On	Occupied	Logged	Lites On	Occupied	
Peak	19.600	19.600	153.400	8.944	8.944	0.0%
Dif	8.733	8.733	206.000	4.155	4.155	0.0%
Sh 1	0.000	0.000	0.000	0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000	0.000	0.000	0.0%
<b>Total</b>	<b>28.333</b>	<b>28.333</b>	<b>359.400</b>	<b>13.099</b>	<b>13.099</b>	<b>0.0%</b>

### Normalized Data

	Sun		Mon		Tue		Wed		Thu		Fri		Sat	
	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ	LO	Occ
Peak	0.000	0.000	1.086	1.086	2.139	2.139	4.733	4.733	1.283	1.283	0.000	0.000	0.000	0.000
Dif Peak	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	4.367	4.367
Sh 1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
Sh 2	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
<b>Total</b>	<b>0.000</b>	<b>0.000</b>	<b>1.086</b>	<b>1.086</b>	<b>2.139</b>	<b>2.139</b>	<b>4.733</b>	<b>4.733</b>	<b>1.283</b>	<b>1.283</b>	<b>0.000</b>	<b>0.000</b>	<b>4.367</b>	<b>4.367</b>

	Logged Totals			Normalized by Day	Normalized Weekly Totals		
	Lites On	Occupied	Logged		Lites On	Occupied	% Savings
Peak	19.600	19.600	153.400	^^ ^^	8.944	8.944	0.0%
Dif Peak	8.733	8.733	206.000		4.155	4.155	0.0%
Sh 1	0.000	0.000	0.000		0.000	0.000	0.0%
Sh 2	0.000	0.000	0.000		0.000	0.000	0.0%
<b>Total</b>	<b>28.333</b>	<b>28.333</b>	<b>359.400</b>		<b>13.099</b>	<b>13.099</b>	<b>0.0%</b>



**APPENDIX D**






## New Jersey Office of Clean Energy Direct Install Program Energy Assessment Tool



General Project Information			
Participating Customer:	Gloucester Township	Facility Type:	Other
Contractor / Project #:	Hutchinson	Total Facility Square Footage:	
Facility Name:	DWP Old/Office	Avg Weekly Hrs of Operation:	
Street Address:	1729 Erial Rd	# of Full-Time Employees:	
City / Zip Code:	Blackwood 08012	Year Constructed:	
Will the project receive EECBG funding?:	Y	Tax Exempt?:	Y
ELECTRIC UTILITY INFORMATION		GAS UTILITY INFORMATION	
Electric Provider:	Atlantic City Electric	Gas Provider:	<Select Gas Provider>
Service Class:	Monthly General Service	Service Class:	
Account #:	0388 9889 9976	Account #:	
Billing Period Start Date:	05/26/11	Billing Period Start Date:	
Billing Period End Date:	06/27/11	Billing Period End Date:	
Billing Period kWh Consumption:	14,840	Billing Period Therm Consumption:	
Billing Period Total Cost:	\$ 1,029.40	Billing Period Total Cost:	
Total Taxes + Fees on Bill:	\$ 82.69	Total Taxes + Fees on Bill:	

Project Summary							
Electric - Average Cost (\$/kWh):	\$0.064	Gas - Average Cost (\$/Therm):	\$0.00				
	<u>kWh Saved per Year</u>	<u>Annual Savings</u>	<u>Total Measure Cost</u>	<u>Estimated Incentive Amount</u>	<u>Total Cost to Customer</u>	<u>Simple Payback (Yrs)</u>	
Lighting Measures Total:	12,736	\$ 812.50	\$ 10,375.57	\$ 6,225.34	\$ 4,150.23	5.11	
Motors & VFD Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-	
HVAC Electric Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-	
Refrigeration Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-	
<b>TOTAL ELECTRIC MEASURES:</b>	<b>12,736</b>	<b>\$ 812.50</b>	<b>\$ 10,375.57</b>	<b>\$ 6,225.34</b>	<b>\$ 4,150.23</b>	<b>5.11</b>	
<b>TOTAL GAS MEASURES:</b>	-	\$ -	\$ -	\$ -	\$ -	-	
<b>TOTAL OIL MEASURES:</b>	-	\$ -	\$ -	\$ -	\$ -	-	
<b>CONVERSION MEASURES:</b>	-	\$ -	\$ -	\$ -	\$ -	-	
(OIL TO GAS)							
<b>TOTAL PROPANE MEASURES:</b>	-	\$ -	\$ -	\$ -	\$ -	-	
<b>COMBINED PROJECT TOTALS:</b>		<b>\$ 812.50</b>	<b>\$ 10,375.57</b>	<b>\$ 6,225.34</b>	<b>\$ 4,150.23</b>	<b>5.11</b>	
<b>PROJECT TRC TEST:</b>						<b>1.69</b>	





**DIRECT INSTALL PROGRAM  
PARTICIPATION AGREEMENT  
SCOPE OF WORK ATTACHMENT**

<b>“Parties”:</b>				
Participating Customer*:	<u>Gloucester Township</u>			
Participating Contractor*:	<u>Hutchinson</u>			
Facility Name*:	<u>DWP Old/Office</u>			
Facility Address:	<u>1729 Erial Rd</u>	<u>Blackwood,</u>	<u>NJ</u>	<u>08012</u>
	Street	City		Zip
*as listed on Application				

When fully signed and upon receipt of the project funding approval letter, this Scope of Work Attachment (“Attachment”) shall become part of the Direct Install Program Participation Agreement (“Participation Agreement”) previously executed by the Parties in connection with the installation of energy efficiency retrofit Measures to be performed by the Participating Contractor (or “Contractor”) at the above listed Facility. This Attachment, together with the Participation Agreement and funding letter, shall constitute the full Agreement between the Parties. Terms capitalized herein are defined in the Participation Agreement.

The Participating Customer (or “Customer”) agrees to have Contractor perform retrofit work in connection with the Measures listed on page 2 of this form (attached) once this agreement is reviewed and approved for funding by the Market Manager (TRC). Until that time, it is simply a description of the recommended measures for the defined project. Once official approval for funding is received in writing from TRC, this defined project can move ahead. At that time, in consideration of the Contractor’s performance of such work, Customer agrees to pay Contractor based on the measure costs listed below under Customer Unit Cost for the number of completed units for each Measure upon receipt of invoice; provided the Contractor may collect a deposit from Customer prior to performing such work, in which case the final invoice shall be net of such deposit. Customer and Contractor understand that conditions discovered during installation may require that some measures identified in the energy assessment cannot be installed, or some areas may require additional measures/quantities to be installed. Should conditions in the field dictate that the Estimated Program Total Cost shown on page 2 increase by more than 10%, Contractor must obtain both Market Manager and Customer written approval in the form of an amended Scope of Work Attachment before proceeding with such additional work.

By signing below, the Parties agree the above listed Measures shall be installed by the Contractor. The Customer shall pay the Contractor as described herein following Completion and Acceptance of Measures. Customer certifies that he/she has the authority to contract for retrofit work in the Facility in connection with the Measures listed and, if the Customer does not own the Facility, the Owner has granted permission to Customer for performance of such work.

Participating Customer	Date	Participating Contractor	Date
------------------------	------	--------------------------	------

Savings values are estimates. Actual savings will vary.  
 Incentives and participation subject to program rules and Participation Agreement.

**Page 2**  
**Scope of Work**

The work to be performed by the Participating Contractor in connection with the Project shall be comprised of the below listed Measures in the estimated quantities listed:

<u>Measure Description / Location</u>	<u>Quantity</u>	<u>Total</u>	<u>Estimated</u>	<u>Estimated</u>
	<u>To Be</u>	<u>Measure</u>	<u>Customer</u>	<u>Incentive</u>
	<u>Installed</u>	<u>Cost</u>	<u>Total Cost</u>	<u>Amount</u>
4 LAMP T5 HIGH BAY HO FIXTURE / BAY AREA	18	\$ 6,659.92	\$ 2,663.97	\$ 3,995.95
4' T8 4-lamp with EB / BAY AREA	1	\$ 85.67	\$ 34.27	\$ 51.40
4' T8 2-lamp with EB / BAY AREA	1	\$ 68.71	\$ 27.48	\$ 41.23
CF 13-1L SCREW IN CFL / BATHROOM	2	\$ 64.85	\$ 25.94	\$ 38.91
4' T8 4-lamp with EB / FILE ROOM	8	\$ 685.35	\$ 274.14	\$ 411.21
CF 13-1L SCREW IN CFL / BATHROOM	3	\$ 97.28	\$ 38.91	\$ 58.37
4' T8 2-lamp with EB / KITCHEN	1	\$ 68.71	\$ 27.48	\$ 41.23
4' T8 4-lamp with EB / HALLWAY	6	\$ 514.01	\$ 205.60	\$ 308.41
CF 13-1L SCREW IN CFL / SIDE FILE AREA	2	\$ 64.85	\$ 25.94	\$ 38.91
CF 13-1L SCREW IN CFL / BATHROOM / MENS	2	\$ 64.85	\$ 25.94	\$ 38.91
CF 13-1L SCREW IN CFL / BATHROOM / WOMENS	2	\$ 64.85	\$ 25.94	\$ 38.91
4' T8 4-lamp with EB / OFFICE 1	2	\$ 171.34	\$ 68.53	\$ 102.80
4' T8 4-lamp with EB / OFFICE 2	2	\$ 171.34	\$ 68.53	\$ 102.80
4' T8 2-lamp with EB / HALL CAFETERIA	11	\$ 755.80	\$ 302.32	\$ 453.48
CF 13-1L SCREW IN CFL / BATHROOM	1	\$ 32.43	\$ 12.97	\$ 19.46
4' T8 4-lamp with EB / OLD MAINTENANCE GARAGE	6	\$ 634.30	\$ 253.72	\$ 380.58
4' T8 4-lamp with EB / BACK STORAGE AREA	2	\$ 171.34	\$ 68.53	\$ 102.80
<b>TOTALS**</b>		\$ 10,375.57	\$ 4,150.23	\$ 6,225.34

\*\* Maximum incentive amount per project is **\$50,000**. Measures that would qualify the project for funding through the American Recovery and Reinvestment Act (ARRA), are highlighted above with an 'A'. If any "ARRA measures" are included then the total incentive amount for all measures will be paid with ARRA funds, otherwise the total incentive amount will come from NJ Clean Energy funds.




## New Jersey Office of Clean Energy Direct Install Program Energy Assessment Tool



General Project Information			
Participating Customer:	Gloucester Twp	Facility Type:	Other
Contractor / Project #:	Hutchinson	Total Facility Square Footage:	
Facility Name:	Library	Avg Weekly Hrs of Operation:	
Street Address:	15 South Blackhorse Pike	# of Full-Time Employees:	
City / Zip Code:	Turnersville 08012	Year Constructed:	
Will the project receive EECBG funding?:	Y	Tax Exempt?:	Y
ELECTRIC UTILITY INFORMATION		GAS UTILITY INFORMATION	
Electric Provider:	PSE&G	Gas Provider:	South Jersey Gas
Service Class:	GLP	Service Class:	General Service
Account #:	69 443 149 08	Account #:	2 06 30 3002 0 8
Billing Period Start Date:	05/27/11	Billing Period Start Date:	04/27/11
Billing Period End Date:	06/28/11	Billing Period End Date:	05/25/11
Billing Period kWh Consumption:	15,510	Billing Period Therm Consumption:	265
Billing Period Total Cost:	\$ 2,859.05	Billing Period Total Cost:	\$ 339.20
Total Taxes + Fees on Bill:	\$ 138.28	Total Taxes + Fees on Bill:	\$ 22.22

Project Summary							
Electric - Average Cost (\$/kWh):	\$0.175	Gas - Average Cost (\$/Therm):	\$1.20				
	kWh Saved per Year	Annual Savings	Total Measure Cost	Estimated Incentive Amount	Total Cost to Customer	Simple Payback (Yrs)	
Lighting Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-	
Motors & VFD Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-	
HVAC Electric Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-	
Refrigeration Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-	
<b>TOTAL ELECTRIC MEASURES:</b>	<b>-</b>	<b>\$ -</b>	<b>\$ -</b>	<b>\$ -</b>	<b>\$ -</b>	<b>-</b>	
<u>Therms /yr.</u>							
<b>TOTAL GAS MEASURES:</b>	4,374	\$ 5,238.08	\$ 20,908.21	\$ 12,544.93	\$ 8,363.29	1.60	
<u>Gallons/yr.</u>							
<b>TOTAL OIL MEASURES:</b>	-	\$ -	\$ -	\$ -	\$ -	-	
<u>Oil Gallons/yr. Gas Therms/yr.</u>							
<b>CONVERSION MEASURES:</b> (OIL TO GAS)	-	\$ -	\$ -	\$ -	\$ -	-	
<u>Gallons/yr.</u>							
<b>TOTAL PROPANE MEASURES:</b>	-	\$ -	\$ -	\$ -	\$ -	-	
<b>COMBINED PROJECT TOTALS:</b>		<b>\$ 5,238.08</b>	<b>\$ 20,908.21</b>	<b>\$ 12,544.93</b>	<b>\$ 8,363.29</b>	<b>1.60</b>	
<b>PROJECT TRC TEST:</b>						<b>12.30</b>	





**DIRECT INSTALL PROGRAM  
PARTICIPATION AGREEMENT  
SCOPE OF WORK ATTACHMENT**

<b>“Parties”:</b>				
Participating Customer*:	<u>Gloucester Twp</u>			
Participating Contractor*:	<u>Hutchinson</u>			
Facility Name*:	<u>Library</u>			
Facility Address:	<u>15 South Blackhorse Pike</u>	<u>Turnersville,</u>	<u>NJ</u>	<u>08012</u>
	Street	City		Zip
*as listed on Application				

When fully signed and upon receipt of the project funding approval letter, this Scope of Work Attachment (“Attachment”) shall become part of the Direct Install Program Participation Agreement (“Participation Agreement”) previously executed by the Parties in connection with the installation of energy efficiency retrofit Measures to be performed by the Participating Contractor (or “Contractor”) at the above listed Facility. This Attachment, together with the Participation Agreement and funding letter, shall constitute the full Agreement between the Parties. Terms capitalized herein are defined in the Participation Agreement.

The Participating Customer (or “Customer”) agrees to have Contractor perform retrofit work in connection with the Measures listed on page 2 of this form (attached) once this agreement is reviewed and approved for funding by the Market Manager (TRC). Until that time, it is simply a description of the recommended measures for the defined project. Once official approval for funding is received in writing from TRC, this defined project can move ahead. At that time, in consideration of the Contractor’s performance of such work, Customer agrees to pay Contractor based on the measure costs listed below under Customer Unit Cost for the number of completed units for each Measure upon receipt of invoice; provided the Contractor may collect a deposit from Customer prior to performing such work, in which case the final invoice shall be net of such deposit. Customer and Contractor understand that conditions discovered during installation may require that some measures identified in the energy assessment cannot be installed, or some areas may require additional measures/quantities to be installed. Should conditions in the field dictate that the Estimated Program Total Cost shown on page 2 increase by more than 10%, Contractor must obtain both Market Manager and Customer written approval in the form of an amended Scope of Work Attachment before proceeding with such additional work.

By signing below, the Parties agree the above listed Measures shall be installed by the Contractor. The Customer shall pay the Contractor as described herein following Completion and Acceptance of Measures. Customer certifies that he/she has the authority to contract for retrofit work in the Facility in connection with the Measures listed and, if the Customer does not own the Facility, the Owner has granted permission to Customer for performance of such work.

\_\_\_\_\_ Date

\_\_\_\_\_ Date

Participating Customer

Participating Contractor

Date

Savings values are estimates. Actual savings will vary.  
 Incentives and participation subject to program rules and Participation Agreement.

**Page 2**  
**Scope of Work**

The work to be performed by the Participating Contractor in connection with the Project shall be comprised of the below listed Measures in the estimated quantities listed:

<u>Measure Description / Location</u>	<u>Quantity</u>	<u>Total</u>	<u>Estimated</u>	<u>Estimated</u>
	<u>To Be</u>	<u>Measure</u>	<u>Customer</u>	<u>Incentive</u>
	<u>Installed</u>	<u>Cost</u>	<u>Total Cost</u>	<u>Amount</u>
Gas-Fired Boiler / Boiler Room	1	\$ 20,482.74	\$ 8,193.10	\$ 12,289.64
Electronic Fuel-Use Economizers (for Hot Water Heat) / Boiler Room	1	\$ 425.48	\$ 170.19	\$ 255.29
<b>TOTALS**</b>		\$ 20,908.21	\$ 8,363.29	\$ 12,544.93

\*\* Maximum incentive amount per project is **\$50,000**. Measures that would qualify the project for funding through the American Recovery and Reinvestment Act (ARRA), are highlighted above with an 'A'. If any "ARRA measures" are included then the total incentive amount for all measures will be paid with ARRA funds, otherwise the total incentive amount will come from NJ Clean Energy funds.



## New Jersey Office of Clean Energy Direct Install Program Energy Assessment Tool




General Project Information			
Participating Customer:	Gloucester Township	Facility Type:	Other
Contractor / Project #:	Hutchinson	Total Facility Square Footage:	
Facility Name:	Recreation Center	Avg Weekly Hrs of Operation:	
Street Address:	80 Broad Acres	# of Full-Time Employees:	
City / Zip Code:	Blackwood 08012	Year Constructed:	
Will the project receive EECBG funding?:	Y	Tax Exempt?:	Y

ELECTRIC UTILITY INFORMATION	GAS UTILITY INFORMATION
Electric Provider: Atlantic City Electric	Gas Provider: South Jersey Gas
Service Class: Annual General Service	Service Class: General Service
Account #: 1143 3009 9994	Account #: 2 05 39 5601 0 0
Billing Period Start Date: 05/06/11	Billing Period Start Date: 06/06/11
Billing Period End Date: 06/07/11	Billing Period End Date: 07/06/11
Billing Period kWh Consumption: 23,380	Billing Period Therm Consumption: 9
Billing Period Total Cost: \$ 4,310.70	Billing Period Total Cost: \$ 39.50
Total Taxes + Fees on Bill: \$ 227.46	Total Taxes + Fees on Bill: \$ 23.81

Project Summary						
Electric - Average Cost (\$/kWh):	\$0.175	Gas - Average Cost (\$/Therm):	\$1.68			
	<u>kWh Saved per Year</u>	<u>Annual Savings</u>	<u>Total Measure Cost</u>	<u>Estimated Incentive Amount</u>	<u>Total Cost to Customer</u>	<u>Simple Payback (Yrs)</u>
Lighting Measures Total:	184,553	\$ 32,231.57	\$ 11,431.04	\$ 6,858.62	\$ 4,572.42	0.14
Motors & VFD Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-
HVAC Electric Measures Total:	2,695	\$ 470.70	\$ 8,137.92	\$ 4,882.75	\$ 3,255.17	6.92
Refrigeration Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-
<b>TOTAL ELECTRIC MEASURES:</b>	<b>187,248</b>	<b>\$ 32,702.27</b>	<b>\$ 19,568.96</b>	<b>\$ 11,741.38</b>	<b>\$ 7,827.58</b>	<b>0.24</b>
	<u>Therms /yr.</u>					
<b>TOTAL GAS MEASURES:</b>	<b>153</b>	<b>\$ 256.40</b>	<b>\$ 5,434.29</b>	<b>\$ 3,260.57</b>	<b>\$ 2,173.71</b>	<b>8.48</b>
	<u>Gallons/yr.</u>					
<b>TOTAL OIL MEASURES:</b>	<b>-</b>	<b>\$ -</b>	<b>\$ -</b>	<b>\$ -</b>	<b>\$ -</b>	<b>-</b>
	<u>Oil Gallons/yr.</u>	<u>Gas Therms/yr.</u>				
<b>CONVERSION MEASURES:</b>	<b>-</b>	<b>-</b>	<b>\$ -</b>	<b>\$ -</b>	<b>\$ -</b>	<b>-</b>
(OIL TO GAS)	<u>Gallons/yr.</u>					
<b>TOTAL PROPANE MEASURES:</b>	<b>-</b>	<b>\$ -</b>	<b>\$ -</b>	<b>\$ -</b>	<b>\$ -</b>	<b>-</b>
<b>COMBINED PROJECT TOTALS:</b>	<b>\$ 32,958.67</b>	<b>\$ 25,003.24</b>	<b>\$ 15,001.95</b>	<b>\$ 10,001.30</b>		
	<b>PROJECT TRC TEST:</b>					<b>16.20</b>





**DIRECT INSTALL PROGRAM  
PARTICIPATION AGREEMENT  
SCOPE OF WORK ATTACHMENT**

“Parties”:

Participating Customer\*: Gloucester Township

Participating Contractor\*: Hutchinson

Facility Name\*: Recreation Center

Facility Address: 80 Broad Acres Blackwood, NJ 08012

Street City Zip

\*as listed on Application

When fully signed and upon receipt of the project funding approval letter, this Scope of Work Attachment (“Attachment”) shall become part of the Direct Install Program Participation Agreement (“Participation Agreement”) previously executed by the Parties in connection with the installation of energy efficiency retrofit Measures to be performed by the Participating Contractor (or “Contractor”) at the above listed Facility. This Attachment, together with the Participation Agreement and funding letter, shall constitute the full Agreement between the Parties. Terms capitalized herein are defined in the Participation Agreement.

The Participating Customer (or “Customer”) agrees to have Contractor perform retrofit work in connection with the Measures listed on page 2 of this form (attached) once this agreement is reviewed and approved for funding by the Market Manager (TRC). Until that time, it is simply a description of the recommended measures for the defined project. Once official approval for funding is received in writing from TRC, this defined project can move ahead. At that time, in consideration of the Contractor’s performance of such work, Customer agrees to pay Contractor based on the measure costs listed below under Customer Unit Cost for the number of completed units for each Measure upon receipt of invoice; provided the Contractor may collect a deposit from Customer prior to performing such work, in which case the final invoice shall be net of such deposit. Customer and Contractor understand that conditions discovered during installation may require that some measures identified in the energy assessment cannot be installed, or some areas may require additional measures/quantities to be installed. Should conditions in the field dictate that the Estimated Program Total Cost shown on page 2 increase by more than 10%, Contractor must obtain both Market Manager and Customer written approval in the form of an amended Scope of Work Attachment before proceeding with such additional work.

By signing below, the Parties agree the above listed Measures shall be installed by the Contractor. The Customer shall pay the Contractor as described herein following Completion and Acceptance of Measures. Customer certifies that he/she has the authority to contract for retrofit work in the Facility in connection with the Measures listed and, if the Customer does not own the Facility, the Owner has granted permission to Customer for performance of such work.

\_\_\_\_\_  
Participating Customer Date

\_\_\_\_\_  
Participating Contractor Date



Savings values are estimates. Actual savings will vary.  
 Incentives and participation subject to program rules and Participation Agreement.

**Page 2**

**Scope of Work**

The work to be performed by the Participating Contractor in connection with the Project shall be comprised of the below listed Measures in the estimated quantities listed:

<u>Measure Description / Location</u>	<u>Quantity To Be Installed</u>	<u>Total Measure Cost</u>	<u>Estimated Customer Total Cost</u>	<u>Estimated Incentive Amount</u>
T8 3-lamp fixture with EB & reflector / LOBBY	2	\$ 554.84	\$ 221.94	\$ 332.90
T8 3-lamp fixture with EB & reflector / 2ND LOBBY	6	\$ 1,664.52	\$ 665.81	\$ 998.71
T8 3-lamp fixture with EB & reflector / MENS ROOM	3	\$ 832.26	\$ 332.90	\$ 499.36
4' T8 2-lamp with EB / MENS ROOM	6	\$ 412.25	\$ 164.90	\$ 247.35
T8 3-lamp fixture with EB & reflector / WOMENS ROOM	3	\$ 832.26	\$ 332.90	\$ 499.36
4' T8 2-lamp with EB / WOMENS ROOM	6	\$ 412.25	\$ 164.90	\$ 247.35
4' T8 2-lamp with EB / JANITORIAL CLOSET	1	\$ 68.71	\$ 27.48	\$ 41.23
T8 3-lamp fixture with EB & reflector / OFFICE WITH SODA MACHINE	1	\$ 277.42	\$ 110.97	\$ 166.45
T8 3-lamp fixture with EB & reflector / ALL OFFICES	10	\$ 2,774.20	\$ 1,109.68	\$ 1,664.52
4' T8 2-lamp with EB / ELECTRICAL ROOM	9	\$ 618.38	\$ 247.35	\$ 371.03
T8 3-lamp fixture with EB & reflector / GYM ENTRANCE AREA	4	\$ 1,109.68	\$ 443.87	\$ 665.81
4' T8 2-lamp with EB / STORAGE AREA	8	\$ 549.67	\$ 219.87	\$ 329.80
LED EXIT Sign w/ Batt. Backup / EXIT SIGNS	10	\$ 1,324.59	\$ 529.84	\$ 794.76
5-Ton Electric Split System A/C / rear of Building	1	\$ 8,137.92	\$ 3,255.17	\$ 4,882.75
Gas-Fired Furnace / Storage Room	1	\$ 5,434.29	\$ 2,173.71	\$ 3,260.57
<b>TOTALS**</b>		\$ 25,003.24	\$ 10,001.30	\$ 15,001.95

\*\*Maximum incentive amount per project is \$50,000. Measures that would qualify the project for funding through the American Recovery and Reinvestment Act (ARRA), are highlighted above with an 'A'. If any "ARRA measures" are included then the total incentive amount for all measures will be paid with ARRA funds, otherwise the total incentive amount will come from NJ Clean Energy funds.




## New Jersey Office of Clean Energy Direct Install Program Energy Assessment Tool



General Project Information			
Participating Customer:	Gloucester Township	Facility Type:	Other
Contractor / Project #:	Hutchinson	Total Facility Square Footage:	
Facility Name:	Academy Hall	Avg Weekly Hrs of Operation:	
Street Address:	27 S. Blackhorse Pike	# of Full-Time Employees:	
City / Zip Code:	Turnersville 08012	Year Constructed:	
Will the project receive EECBG funding?:	Y	Tax Exempt?:	Y
ELECTRIC UTILITY INFORMATION		GAS UTILITY INFORMATION	
Electric Provider:	PSE&G	Gas Provider:	South Jersey Gas
Service Class:	GLV	Service Class:	General Service
Account #:	69 438 189 02	Account #:	2 06 30 3000 0 0
Billing Period Start Date:	04/28/11	Billing Period Start Date:	04/27/11
Billing Period End Date:	06/28/11	Billing Period End Date:	05/25/11
Billing Period kWh Consumption:	10,080	Billing Period Therm Consumption:	67
Billing Period Total Cost:	\$ 1,804.60	Billing Period Total Cost:	\$ 118.91
Total Taxes + Fees on Bill:	\$ 95.67	Total Taxes + Fees on Bill:	\$ 22.22

Project Summary						
Electric - Average Cost (\$/kWh):	\$0.170	Gas - Average Cost (\$/Therm):	\$1.45			
	<u>kWh Saved per Year</u>	<u>Annual Savings</u>	<u>Total Measure Cost</u>	<u>Estimated Incentive Amount</u>	<u>Total Cost to Customer</u>	<u>Simple Payback (Yrs)</u>
Lighting Measures Total:	5,397	\$ 915.06	\$ 24,573.00	\$ 14,743.80	\$ 9,829.20	10.74
Motors & VFD Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-
HVAC Electric Measures Total:	2,430	\$ 411.97	\$ 12,626.79	\$ 7,576.08	\$ 5,050.72	12.26
Refrigeration Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-
<b>TOTAL ELECTRIC MEASURES:</b>	<b>7,827</b>	<b>\$ 1,327.04</b>	<b>\$ 37,199.79</b>	<b>\$ 22,319.88</b>	<b>\$ 14,879.92</b>	<b>11.21</b>
	<u>Therms /yr.</u>					
<b>TOTAL GAS MEASURES:</b>	<b>5,857</b>	<b>\$ 8,482.14</b>	<b>\$ 26,260.36</b>	<b>\$ 15,756.21</b>	<b>\$ 10,504.14</b>	<b>1.24</b>
	<u>Gallons/yr.</u>					
<b>TOTAL OIL MEASURES:</b>	-	\$ -	\$ -	\$ -	\$ -	-
	<u>Oil Gallons/yr.</u>	<u>Gas Therms/yr.</u>				
<b>CONVERSION MEASURES:</b>	-	-	\$ -	\$ -	\$ -	-
(OIL TO GAS)						
	<u>Gallons/yr.</u>					
<b>TOTAL PROPANE MEASURES:</b>	-	\$ -	\$ -	\$ -	\$ -	-
<b>COMBINED PROJECT TOTALS:</b>	<b>\$ 9,809.18</b>	<b>\$ 63,460.15</b>	<b>\$ 38,076.09</b>	<b>\$ 25,384.06</b>	<b>2.59</b>	
<b>PROJECT TRC TEST:</b>						<b>2.32</b>





**DIRECT INSTALL PROGRAM  
PARTICIPATION AGREEMENT  
SCOPE OF WORK ATTACHMENT**

“Parties”:

Participating Customer*:	_____
	<b>Gloucester Township</b>
Participating Contractor*:	_____
	<b>Hutchinson</b>
Facility Name*:	_____
	<b>Academy Hall</b>
Facility Address:	_____
	<b>27 S. Blackhorse Pike      Turnersville,      NJ      08012</b>
	Street    City    Zip

\*as listed on Application

When fully signed and upon receipt of the project funding approval letter, this Scope of Work Attachment (“Attachment”) shall become part of the Direct Install Program Participation Agreement (“Participation Agreement”) previously executed by the Parties in connection with the installation of energy efficiency retrofit Measures to be performed by the Participating Contractor (or “Contractor”) at the above listed Facility. This Attachment, together with the Participation Agreement and funding letter, shall constitute the full Agreement between the Parties. Terms capitalized herein are defined in the Participation Agreement.

The Participating Customer (or “Customer”) agrees to have Contractor perform retrofit work in connection with the Measures listed on page 2 of this form (attached) once this agreement is reviewed and approved for funding by the Market Manager (TRC). Until that time, it is simply a description of the recommended measures for the defined project. Once official approval for funding is received in writing from TRC, this defined project can move ahead. At that time, in consideration of the Contractor’s performance of such work, Customer agrees to pay Contractor based on the measure costs listed below under Customer Unit Cost for the number of completed units for each Measure upon receipt of invoice; provided the Contractor may collect a deposit from Customer prior to performing such work, in which case the final invoice shall be net of such deposit. Customer and Contractor understand that conditions discovered during installation may require that some measures identified in the energy assessment cannot be installed, or some areas may require additional measures/quantities to be installed. Should conditions in the field dictate that the Estimated Program Total Cost shown on page 2 increase by more than 10%, Contractor must obtain both Market Manager and Customer written approval in the form of an amended Scope of Work Attachment before proceeding with such additional work.

By signing below, the Parties agree the above listed Measures shall be installed by the Contractor. The Customer shall pay the Contractor as described herein following Completion and Acceptance of Measures. Customer certifies that he/she has the authority to contract for retrofit work in the Facility in connection with the Measures listed and, if the Customer does not own the Facility, the Owner has granted permission to Customer for performance of such work.

\_\_\_\_\_  
Participating Customer    Date

\_\_\_\_\_  
Participating Contractor    Date

Savings values are estimates. Actual savings will vary.  
 Incentives and participation subject to program rules and Participation Agreement.

**Page 2**  
**Scope of Work**

The work to be performed by the Participating Contractor in connection with the Project shall be comprised of the below listed Measures in the estimated quantities listed:

<u>Measure Description / Location</u>	<u>Quantity</u>	<u>Total</u>	<u>Estimated</u>	<u>Estimated</u>
	<u>To Be</u>	<u>Measure</u>	<u>Customer</u>	<u>Incentive</u>
	<u>Installed</u>	<u>Cost</u>	<u>Total Cost</u>	<u>Amount</u>
T8 3-lamp fixture with EB & reflector / MAIN OFFICE AREA	14	\$ 3,883.88	\$ 1,553.55	\$ 2,330.33
CF 13-1L SCREW IN CFL / BATHROOM	2	\$ 64.85	\$ 25.94	\$ 38.91
T8 3-lamp fixture with EB & reflector / LOBBY TO STAIRS	2	\$ 554.84	\$ 221.94	\$ 332.90
T8 3-lamp fixture with EB & reflector / ENTIRE 1ST FLOOR OFFICE AREA	31	\$ 8,600.03	\$ 3,440.01	\$ 5,160.02
CF 13-1L SCREW IN CFL / BATHROOMS	2	\$ 64.85	\$ 25.94	\$ 38.91
T8 3-lamp fixture with EB & reflector / STAIRWELL	1	\$ 277.42	\$ 110.97	\$ 166.45
T8 3-lamp fixture with EB & reflector / ENTIRE 2ND FLOOR OFFICE AREA	32	\$ 8,877.45	\$ 3,550.98	\$ 5,326.47
CF 13-1L SCREW IN CFL / BATHROOM	1	\$ 32.43	\$ 12.97	\$ 19.46
CF 13-1L SCREW IN CFL / CLOSET	1	\$ 32.43	\$ 12.97	\$ 19.46
CF 13-1L SCREW IN CFL / STAIRWELL DOWN	5	\$ 162.13	\$ 64.85	\$ 97.28
CF 13-1L SCREW IN CFL / STAIRWELL UP	1	\$ 32.43	\$ 12.97	\$ 19.46
LED EXIT Sign w/ Batt. Backup / EXIT SIGNS OVERALL	7	\$ 927.22	\$ 370.89	\$ 556.33
4' T8 2-lamp with EB / 3RD FLOOR OVERALL AREA	15	\$ 1,030.63	\$ 412.25	\$ 618.38
CF 13-1L SCREW IN CFL / MECHANICAL ROOM	1	\$ 32.43	\$ 12.97	\$ 19.46
3-Ton Electric Split System A/C / Rear Building	1	\$ 6,916.69	\$ 2,766.68	\$ 4,150.02
2-Ton Electric Split System A/C / Rear Building	1	\$ 5,710.10	\$ 2,284.04	\$ 3,426.06
Gas-Fired Boiler / Boiler Room	1	\$ 24,399.40	\$ 9,759.76	\$ 14,639.64
Electronic Fuel-Use Economizers (for Hot Water Heat) / Boiler Room	1	\$ 1,860.95	\$ 744.38	\$ 1,116.57
<b>TOTALS**</b>		\$ 63,460.15	\$ 25,384.06	\$ 38,076.09

\*\*Maximum incentive amount per project is \$50,000. Measures that would qualify the project for funding through the American Recovery and Reinvestment Act (ARRA), are highlighted above with an 'A'. If any "ARRA measures" are included then the total incentive amount for all measures will be paid with ARRA funds, otherwise the total incentive amount will come from NJ Clean Energy funds.




## New Jersey Office of Clean Energy Direct Install Program Energy Assessment Tool



General Project Information			
Participating Customer:	Gloucester Township	Facility Type:	Other
Contractor / Project #:	Hutchinson	Total Facility Square Footage:	
Facility Name:	Senior Center	Avg Weekly Hrs of Operation:	
Street Address:	1261 Chews landing Road	# of Full-Time Employees:	
City / Zip Code:	Turnersville 08012	Year Constructed:	
Will the project receive EECBG funding?:	Y	Tax Exempt?:	Y
ELECTRIC UTILITY INFORMATION		GAS UTILITY INFORMATION	
Electric Provider:	PSE&G	Gas Provider:	South Jersey Gas
Service Class:	LPLS	Service Class:	General Service
Account #:	69 441 714 06	Account #:	2 05 34 3489 0 7
Billing Period Start Date:	05/25/11	Billing Period Start Date:	06/03/11
Billing Period End Date:	06/24/11	Billing Period End Date:	07/06/11
Billing Period kWh Consumption:	3,678	Billing Period Therm Consumption:	20
Billing Period Total Cost:	\$ 846.21	Billing Period Total Cost:	\$ 106.59
Total Taxes + Fees on Bill:	\$ 36.07	Total Taxes + Fees on Bill:	\$ 26.19

Project Summary						
Electric - Average Cost (\$/kWh):	<b>\$0.220</b>	Gas - Average Cost (\$/Therm):	<b>\$4.08</b>			
	<u>kWh Saved per Year</u>	<u>Annual Savings</u>	<u>Total Measure Cost</u>	<u>Estimated Incentive Amount</u>	<u>Total Cost to Customer</u>	<u>Simple Payback (Yrs)</u>
Lighting Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-
Motors & VFD Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-
HVAC Electric Measures Total:	11,601	\$ 2,555.38	\$ 24,610.70	\$ 14,766.42	\$ 9,844.28	3.85
Refrigeration Measures Total:	-	\$ -	\$ -	\$ -	\$ -	-
<b>TOTAL ELECTRIC MEASURES:</b>	<b>11,601</b>	<b>\$ 2,555.38</b>	<b>\$ 24,610.70</b>	<b>\$ 14,766.42</b>	<b>\$ 9,844.28</b>	<b>3.85</b>
	<u>Therms /yr.</u>					
<b>TOTAL GAS MEASURES:</b>	<b>1,224</b>	<b>\$ 4,989.02</b>	<b>\$ 13,060.01</b>	<b>\$ 7,836.00</b>	<b>\$ 5,224.00</b>	<b>1.05</b>
	<u>Gallons/yr.</u>					
<b>TOTAL OIL MEASURES:</b>	-	\$ -	\$ -	\$ -	\$ -	-
	<u>Oil Gallons/yr.</u>	<u>Gas Therms/yr.</u>				
<b>CONVERSION MEASURES:</b>	-	-	\$ -	\$ -	\$ -	-
(OIL TO GAS)	<u>Gallons/yr.</u>					
<b>TOTAL PROPANE MEASURES:</b>	-	\$ -	\$ -	\$ -	\$ -	-
<b>COMBINED PROJECT TOTALS:</b>	<b>\$ 7,544.40</b>	<b>\$ 37,670.71</b>	<b>\$ 22,602.42</b>	<b>\$ 15,068.28</b>	<b>2.00</b>	
<b>PROJECT TRC TEST:</b>						<b>2.59</b>





Savings values are estimates. Actual savings will vary.  
 Incentives and participation subject to program rules and Participation Agreement.

**Page 2**  
**Scope of Work**

The work to be performed by the Participating Contractor in connection with the Project shall be comprised of the below listed Measures in the estimated quantities listed:

<u>Measure Description / Location</u>	<u>Quantity</u>	<u>Total</u>	<u>Estimated</u>	<u>Estimated</u>
	<u>To Be</u>	<u>Measure</u>	<u>Customer</u>	<u>Incentive</u>
	<u>Installed</u>	<u>Cost</u>	<u>Total Cost</u>	<u>Amount</u>
5-Ton Electric Split System A/C / Rear Bldg	1	\$ 8,137.92	\$ 3,255.17	\$ 4,882.75
5-Ton Electric Split System A/C / Rear Bldg	1	\$ 8,137.92	\$ 3,255.17	\$ 4,882.75
5-Ton Electric Split System A/C / Rear Bldg	1	\$ 8,137.92	\$ 3,255.17	\$ 4,882.75
Faucet Aerators (lavatory) / Throughout	3	\$ 196.94	\$ 78.78	\$ 118.17
Gas-Fired Furnace / Heater Room	1	\$ 6,196.19	\$ 2,478.48	\$ 3,717.71
Gas-Fired Furnace / Heater Room	1	\$ 6,196.19	\$ 2,478.48	\$ 3,717.71
Programmable Thermostats / Throughout	3	\$ 667.63	\$ 267.05	\$ 400.58
<b>TOTALS**</b>		\$ 37,670.71	\$ 15,068.28	\$ 22,602.42

\*\*Maximum incentive amount per project is \$50,000. Measures that would qualify the project for funding through the American Recovery and Reinvestment Act (ARRA), are highlighted above with an 'A'. If any "ARRA measures" are included then the total incentive amount for all measures will be paid with ARRA funds, otherwise the total incentive amount will come from NJ Clean Energy funds.